

NSF Standard 245 (Nitrogen-Reducing) Certified Aerobic Treatment Units (ATUs) in Florida (Rule 62-6.012, Florida Administrative Code)

Manufacturer	Equipment Series	NSF Tested Model	Third Party Certifying Organization	Florida-Approved NSF 245-Certified Models	Average Total Nitrogen Reduction - NSF 245 Completion Report ¹	NSF 245 Report Date
Anua	PuraSys	PekaSys CRB1 (PuraSys PS1-4)	NSF International	PS1-5, PS1-6, PS1-7, PS1-8, PS1-9, PS1-10, PS1-11, PS1-12, PS1-13, and PS1-14	58%	July 2011
Aquaklear, Inc.	AquaKlear	AK6S245	Gulf Coast Testing	AK6S245C, AK10S245C, AK6S245F, AK6S245C/UV ⁵	59.4%	April 2021
Bio-Microbics, Inc.	BioBarrier	MBR 0.5	NSF International	MBR 0.5-N; MBR 1.0-N; MBR 1.5-N	79%	October 2011
Bio-Microbics, Inc.	MicroFAST ²	0.5	NSF International	MicroFast 0.4, 0.5, 0.625, 0.75, 0.9, 1.5	55%	October 2008
Clearstream Wastewater Systems, Inc.	Clearstream	500 D	Gulf Coast Testing	500D, 500DT, 500DST, 600D, 600DT, 600DC3, 750D, 750DT, 800D, 1000D, 1000DT, 1500D	52.9%	March 2013
Clearstream Wastewater Systems, Inc.	Clearstream	500 DA	Gulf Coast Testing	500DA, 500DAT, 500DAST, 600DA, 600DAT, 600DAC3, 800DA	54.1%	August 2015
Delta Treatment Systems, LLC.	ECOPOD-N	E50-N	NSF International	E50-N, E-50-N-IM1060, E-60-N E-60-N-IM1060, E75-N, E-75-N-IM1060, E100-N, and E-100-N-IM1530	53%	February 2010
Delta Treatment Systems, LLC.	ECOPOD-NR	E50-NR	Gulf Coast Testing	E50-NR	68.3%	March 2023

Please note that Florida requires approval of treatment receptacles prior to sale and installations. A list of approved treatment receptacles for use with ATUs can be found at: [Tanks - Approved for use with Aerobic Treatment Units \(ATUs\)](#). Be aware that the model identification in that list is not always complete.

¹ Systems installed to meet House Bill 1379 Enhanced Nutrient-Reducing Onsite Sewage Treatment and Disposal System (ENR-OSTDS) requirements differentiate between systems with 24 inches of separation between the bottom of the drainfield and the wettest season water table (WSWT) and those that do not. New systems and modifications/repairs installed with at least 24 inches between the bottom of the drainfield and the WSWT may use any system capable of at least 50% nitrogen removal to comply with ENR-OSTDS requirements. Existing systems (voluntary modifications/repairs) installed with less than 24 inches of water table separation between the bottom of the drainfield and the WSWT (as allowed per Rule 62-6 F.A.C.) must use systems that are capable of at least 65% nitrogen removal to meet ENR-OSTDS requirements. For more information, see [Permitting of Enhanced Nutrient Reducing Onsite Sewage Treatment and Disposal Systems \(ENR-OSTDS\)](#).

² See remarks in tank listings [Tanks - Approved for use with Aerobic Treatment Units \(ATUs\)](#) for information on pretreatment tank sizing required for NSF 245 certification when the Microfast is housed in a single compartment tank.

³ Norweco Singulair 960 and TNT-500 GPD are NSF certified for a rated treatment capacity of 500 gpd or 600 gpd.

⁴ Norweco Singulair 960 and TNT-750 GPD are NSF certified for a rated treatment capacity of 750 gpd or 800 gpd.

⁵ Norweco Singulair 500-R3 and AquaKlear AK6S245C/UV are NSF 350 certified.

Disclaimer: This list does not represent or imply an endorsement of any particular company, person, product, configuration, or technology. The list reflects the compiler's information as November 15, 2024.

NSF Standard 245 (Nitrogen-Reducing) Certified Aerobic Treatment Units (ATUs) in Florida (Rule 62-6.012, Florida Administrative Code)

Manufacturer	Equipment Series	NSF Tested Model	Third Party Certifying Organization	Florida-Approved NSF 245-Certified Models	Average Total Nitrogen Reduction - NSF 245 Completion Report ¹	NSF 245 Report Date
Delta Treatment Systems, LLC.	ECOPOD-NX	E50-NX	Gulf Coast Testing	E50-NX	80.1%	June 2023
Ecological Tanks	Aqua Aire NR	AA500-35NR	Gulf Coast Testing	AA500-35NR, AA600-4NR, AA800-5NR, AA1000-75NR, AA1200-75NR	63.1%	October 2023
Fuji Clean USA	CEN	5	NSF International	CEN 5, 7, 10, 14	74%	April 2015
Hoot Systems, LLC	Hoot ANR	Hoot ANR-450	NSF International	Hoot ANR-450, ANR-500	85%	August 2007
Jet	Jet-CF	500	Gulf Coast Testing	J-500CF, J-750CF, J-1000CF, J-1250CF, J-1500CF	67%	December 2008 (revised December 2018)
Norweco, Inc.	Singulair TNT	TNT-500	NSF International	Singulair TNT-500 ³ , Singulair Green TNT-500 ³ , Singulair TNT-750 ⁴ , Singulair TNT 1000, Singulair TNT 1250, Singulair TNT 1500	68%	November 2007
Norweco, Inc.	Singulair	R3-500	North American Testing, LLC	Singulair R3-500 ⁵	66%	December 2017
Orengo Systems	Advantex	AX20RTN	NSF International	AX20RTN	55%	May 2015

Please note that Florida requires approval of treatment receptacles prior to sale and installations. A list of approved treatment receptacles for use with ATUs can be found at: [Tanks - Approved for use with Aerobic Treatment Units \(ATUs\)](#) . Be aware that the model identification in that list is not always complete.

¹ Systems installed to meet House Bill 1379 Enhanced Nutrient-Reducing Onsite Sewage Treatment and Disposal System (ENR-OSTDS) requirements differentiate between systems with 24 inches of separation between the bottom of the drainfield and the wettest season water table (WSWT) and those that do not. New systems and modifications/repairs installed with at least 24 inches between the bottom of the drainfield and the WSWT may use any system capable of at least 50% nitrogen removal to comply with ENR-OSTDS requirements. Existing systems (voluntary modifications/repairs) installed with less than 24 inches of water table separation between the bottom of the drainfield and the WSWT (as allowed per Rule 62-6 F.A.C.) must use systems that are capable of at least 65% nitrogen removal to meet ENR-OSTDS requirements. For more information, see [Permitting of Enhanced Nutrient Reducing Onsite Sewage Treatment and Disposal Systems \(ENR-OSTDS\)](#).

² See remarks in tank listings [Tanks - Approved for use with Aerobic Treatment Units \(ATUs\)](#) for information on pretreatment tank sizing required for NSF 245 certification when the Microfast is housed in a single compartment tank.

³ Norweco Singulair 960 and TNT-500 GPD are NSF certified for a rated treatment capacity of 500 gpd or 600 gpd.

⁴ Norweco Singulair 960 and TNT-750 GPD are NSF certified for a rated treatment capacity of 750 gpd or 800 gpd.

⁵ Norweco Singulair 500-R3 and AquaKlear AK6S245C/UV are NSF 350 certified.

Disclaimer: This list does not represent or imply an endorsement of any particular company, person, product, configuration, or technology. The list reflects the compiler's information as November 15, 2024.