

EXAMPLE JET-A RELEASE COLLIER COUNTY MEDFLIGHT

- ▶ 190 gallons Jet A release
- ▶ 6,000 gallon aboveground tank
- ▶ No discharge to the environment
- ▶ Captured by Spill Containment
- ▶ Caused by siphoning
- ▶ Someone closed an isolation valve on the anti-siphon tube

Prevention is by anti-siphon or solenoid valve

Valve is now zip-tied open for lack of better solution



DEC/15/2015









