

OSTDS VARIANCE COMMITTEE MEETING MINUTES
Thursday, January 6, 2022

14550 Bay Pierce, Applicant Campbell, Agent

STATUTE/RULE CITATION:
62-6.015, Table V, FAC - Setback to irrigation well (15 ft requested, 50 ft required)
62-6.015, Table V, FAC - Inadequate drainfield size (300 sf requested, 375 sf required)
64E-6.005(2)(c), FAC - Setback to groundwater interceptor drain (10 ft requested, 15 ft required)
62-6.015, Table V, FAC - water table separation (10 inches requested, 12 inches required)

RECOMMENDATIONS: Variance Committee: P (SHO-Y CHD-Y DEP-Y STI-1 HBI-Y REI-2 ENG-Y) Health Officer: P
Approved subject to the following conditions:
The onsite sewage treatment and disposal system shall be set back from the adjacent property's irrigation well by the maximum distance attainable but not less than 15 feet when installed.
The water table elevation at the wettest season of the year shall be at least 10 inches below the bottom surface of the drainfield.

14658 Nassau Reese, Applicant BGRP Engineering Group, Agent

STATUTE/RULE CITATION:
381.0065(4)(g)2.b., F.S. - Estimated sewage flow exceeds 1500 gpd/acre (400 gpd requested, 290 gpd required)
381.0065(4)(e)1., F.S. - Setback to private potable well (60 ft requested, 75 ft required)
62-6.005(1)(a), F.A.C. - Same as 381.0065(4)(e)1., F.S.
62-6.005(4)(a), F.A.C. - Inadequate unobstructed area available

RECOMMENDATIONS: Variance Committee: P (SHO-Y CHD-Y DEP-Y STI-1 HBI-Y REI-2 ENG-Y) Health Officer: P
Approved subject to the following conditions:
The onsite sewage treatment and disposal system shall be a performance-based treatment system meeting advanced secondary treatment standards with drip irrigation.
The onsite sewage treatment and disposal system shall be set back from the adjacent property's private drinking water well by the maximum distance attainable but not less than 60 feet when installed.
The onsite sewage treatment and disposal system shall be abandoned, and the house connected to the central sewer system within 90 days of notification of the availability of such a

14659 Broward DeMarco, Applicant Campanile, Agent Rejected (up)

STATUTE/RULE CITATION:
62-6.006(4), F.A.C. - System subject to vehicular traffic

RECOMMENDATIONS: Variance Committee: D (SHO-1 CHD-Y DEP-Y STI-2 HBI-N REI-N ENG-N) Health Officer: P
Approved subject to the following conditions:
The onsite sewage treatment and disposal system shall include an aerobic treatment unit discharging to a low-pressure distribution system.

14660 Marion Jen Homes, LLC, Applicant

STATUTE/RULE CITATION:

381.0065(4)(a), F.S. - Lot is not 1/2 acre and 100 ft wide (0.24 ac, 82 ft requested, 0.5 ac, 100 ft required)

RECOMMENDATIONS: Variance Committee: P (SHO-Y CHD-Y DEP-Y STI-2 HBI-1 REI-Y ENG-Y) Health Officer: P

Approved subject to the following conditions:

This variance applies only to the lot size requirements of section 381.0065(4)(a), F.S. The structure shall comply with the authorized sewage flow provisions of section 381.0065(4)(a), F.S.

The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

14661 Marion Jen Homes, LLC, Applicant

STATUTE/RULE CITATION:

381.0065(4)(a), F.S. - Lot is not 1/2 acre (0.29 acre requested, 0.5 acre required)

RECOMMENDATIONS: Variance Committee: P (SHO-Y CHD-Y DEP-Y STI-2 HBI-1 REI-Y ENG-Y) Health Officer: P

Approved subject to the following conditions:

This variance applies only to the lot size requirements of section 381.0065(4)(a), F.S. The structure shall comply with the authorized sewage flow provisions of section 381.0065(4)(a), F.S.

The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

14662 Marion Raya, Applicant Terneus, Agent Modified

STATUTE/RULE CITATION:

381.0065(4)(a), F.S. - Lot is not 1/2 acre and 100 ft wide (0.24 ac, 82 ft requested, 0.5 ac, 100 ft required)

RECOMMENDATIONS: Variance Committee: P (SHO-Y CHD-Y DEP-Y STI-Y HBI-2 REI-Y ENG-1) Health Officer: P

Approved subject to the following conditions:

The onsite sewage treatment and disposal system shall include either an in-ground nitrogen reducing biofilter (INRB), an NSF 245 aerobic treatment unit, or a nitrogen-reducing performance-based treatment system designed to meet a 50% reduction in nitrogen before discharge to the drainfield.

*IMPORTANT NOTE: An INRB may not be able to be installed due to site restrictions.

This variance applies only to the lot size requirements of section 381.0065(4)(a), F.S. The structure shall comply with the authorized sewage flow provisions of section 381.0065(4)(a), F.S.

The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

14663 Marion Raya, Applicant Terneus, Agent Modified

STATUTE/RULE CITATION:

381.0065(4)(a), F.S. - Lot is not 1/2 acre and 100 ft wide (0.25 ac, 90 ft requested, 0.5 ac, 100 ft required)

RECOMMENDATIONS: Variance Committee: P (SHO-Y CHD-Y DEP-Y STI-Y HBI-2 REI-Y ENG-1) Health Officer: P

Approved subject to the following conditions:

The onsite sewage treatment and disposal system shall include either an in-ground nitrogen reducing biofilter (INRB), an NSF 245 aerobic treatment unit, or a nitrogen-reducing performance-based treatment system designed to meet a 50% reduction in nitrogen before discharge to the drainfield.

*IMPORTANT NOTE: An INRB may not be able to be installed due to site restrictions.

This variance applies only to the lot size requirements of section 381.0065(4)(a), F.S. The structure shall comply with the authorized sewage flow provisions of section 381.0065(4)(a), F.S.

The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

14664 Marion Raya, Applicant Terneus, Agent Modified

STATUTE/RULE CITATION:

381.0065(4)(a), F.S. - Lot is not 1/2 acre and 100 ft wide (0.25 ac, 80 ft requested, 0.5 ac, 100 ft required)

RECOMMENDATIONS: Variance Committee: P (SHO-Y CHD-Y DEP-Y STI-Y HBI-2 REI-Y ENG-1) Health Officer: P

Approved subject to the following conditions:

The onsite sewage treatment and disposal system shall include either an in-ground nitrogen reducing biofilter (INRB), an NSF 245 aerobic treatment unit, or a nitrogen-reducing performance-based treatment system designed to meet a 50% reduction in nitrogen before discharge to the drainfield.

*IMPORTANT NOTE: An INRB may not be able to be installed due to site restrictions.

This variance applies only to the lot size requirements of section 381.0065(4)(a), F.S. The structure shall comply with the authorized sewage flow provisions of section 381.0065(4)(a), F.S.

The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

14665 Pasco Prahasky, Applicant Caesar Environmental Services, LLC, Agent

STATUTE/RULE CITATION:

381.0065(4)(a), F.S. - Lot is not 1/2 acre and 100 ft wide (0.34 ac, X ft requested, 0.5 ac, 100 ft required)

RECOMMENDATIONS: Variance Committee: A (SHO-N CHD-N DEP-Y STI-1 HBI-Y REI-2 ENG-Y) Health Officer: A

Approved

14666 Marion Patrick Holdings LLC, Applicant Modified

STATUTE/RULE CITATION:

381.0065(4)(a), F.S. - Lot is not 1/2 acre and 100 ft wide (0.23 ac, 80 ft requested, 0.5 ac, 100 ft required)

RECOMMENDATIONS: Variance Committee: P (SHO-N CHD-N DEP-N STI-2 HBI-1 REI-Y ENG-Y) Health Officer: P

Approved subject to the following conditions:

This variance applies only to the lot size requirements of section 381.0065(4)(a), F.S. The structure shall comply with the authorized sewage flow provisions of section 381.0065(4)(a), F.S.

The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

*IMPORTANT NOTE: An INRB may not be able to be installed due to site restrictions.

This variance applies only to the lot size requirements of section 381.0065(4)(a), F.S. The structure shall comply with the authorized sewage flow provisions of section 381.0065(4)(a), F.S.

The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

14667 Marion Patrick Holdings LLC, Applicant Modified

STATUTE/RULE CITATION:

381.0065(4)(a), F.S. - Lot is not 1/2 acre and 100 ft wide (0.24 ac, 85 ft requested, 0.5 ac, 100 ft required)

RECOMMENDATIONS: Variance Committee: P (SHO-N CHD-N DEP-N STI-2 HBI-1 REI-Y ENG-Y) Health Officer: P

Approved subject to the following conditions:

This variance applies only to the lot size requirements of section 381.0065(4)(a), F.S. The structure shall comply with the authorized sewage flow provisions of section 381.0065(4)(a), F.S.

The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

*IMPORTANT NOTE: An INRB may not be able to be installed due to site restrictions.

This variance applies only to the lot size requirements of section 381.0065(4)(a), F.S. The structure shall comply with the authorized sewage flow provisions of section 381.0065(4)(a), F.S.

The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

14668 Marion Patrick Holdings LLC, Applicant

Modified

STATUTE/RULE CITATION:

381.0065(4)(a), F.S. - Lot is not 1/2 acre and 100 ft wide (0.37 ac, X ft requested, 0.5 ac, 100 ft required)

RECOMMENDATIONS: Variance Committee: P (SHO-N CHD-N DEP-N STI-2 HBI-1 REI-Y ENG-Y) Health Officer: P

Approved subject to the following conditions:

This variance applies only to the lot size requirements of section 381.0065(4)(a), F.S. The structure shall comply with the authorized sewage flow provisions of section 381.0065(4)(a), F.S.

The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

*IMPORTANT NOTE: An INRB may not be able to be installed due to site restrictions.

This variance applies only to the lot size requirements of section 381.0065(4)(a), F.S. The structure shall comply with the authorized sewage flow provisions of section 381.0065(4)(a), F.S.

The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

14669 Marion Patrick Holdings LLC, Applicant

Modified

STATUTE/RULE CITATION:

381.0065(4)(a), F.S. - Lot is not 1/2 acre and 100 ft wide (0.24 ac, 83 ft requested, 0.5 ac, 100 ft required)

RECOMMENDATIONS: Variance Committee: P (SHO-N CHD-N DEP-N STI-2 HBI-1 REI-Y ENG-Y) Health Officer: P

Approved subject to the following conditions:

This variance applies only to the lot size requirements of section 381.0065(4)(a), F.S. The structure shall comply with the authorized sewage flow provisions of section 381.0065(4)(a), F.S.

The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

*IMPORTANT NOTE: An INRB may not be able to be installed due to site restrictions.

This variance applies only to the lot size requirements of section 381.0065(4)(a), F.S. The structure shall comply with the authorized sewage flow provisions of section 381.0065(4)(a), F.S.

The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

14670 Marion Patrick Holdings LLC, Applicant

Modified

STATUTE/RULE CITATION:

381.0065(4)(a), F.S. - Lot is not 1/2 acre (0.31 acre requested, 0.5 acre required)

RECOMMENDATIONS: Variance Committee: P (SHO-N CHD-N DEP-N STI-2 HBI-1 REI-Y ENG-Y) Health Officer: P

Approved subject to the following conditions:

This variance applies only to the lot size requirements of section 381.0065(4)(a), F.S. The structure shall comply with the authorized sewage flow provisions of section 381.0065(4)(a), F.S.

The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

*IMPORTANT NOTE: An INRB may not be able to be installed due to site restrictions.

This variance applies only to the lot size requirements of section 381.0065(4)(a), F.S. The structure shall comply with the authorized sewage flow provisions of section 381.0065(4)(a), F.S.

The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

14671 Marion Patrick Holdings LLC, Applicant

Modified

STATUTE/RULE CITATION:

381.0065(4)(a), F.S. - Lot is not 1/2 acre and 100 ft wide (0.24 ac, 82 ft requested, 0.5 ac, 100 ft required)

RECOMMENDATIONS: Variance Committee: P (SHO-N CHD-N DEP-N STI-2 HBI-1 REI-Y ENG-Y) Health Officer: P

Approved subject to the following conditions:

This variance applies only to the lot size requirements of section 381.0065(4)(a), F.S. The structure shall comply with the authorized sewage flow provisions of section 381.0065(4)(a), F.S.

The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

*IMPORTANT NOTE: An INRB may not be able to be installed due to site restrictions.

This variance applies only to the lot size requirements of section 381.0065(4)(a), F.S. The structure shall comply with the authorized sewage flow provisions of section 381.0065(4)(a), F.S.

The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

14672 Marion Patrick Holdings LLC, Applicant Rogers, Agent Modified

STATUTE/RULE CITATION:

381.0065(4)(a), F.S. - Lot is not 1/2 acre and 100 ft wide (0.27 ac, 85 ft requested, 0.5 ac, 100 ft required)

RECOMMENDATIONS: Variance Committee: P (SHO-N CHD-N DEP-N STI-2 HBI-1 REI-Y ENG-Y) Health Officer: P

Approved subject to the following conditions:

This variance applies only to the lot size requirements of section 381.0065(4)(a), F.S. The structure shall comply with the authorized sewage flow provisions of section 381.0065(4)(a), F.S.

The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

*IMPORTANT NOTE: An INRB may not be able to be installed due to site restrictions.

This variance applies only to the lot size requirements of section 381.0065(4)(a), F.S. The structure shall comply with the authorized sewage flow provisions of section 381.0065(4)(a), F.S.

The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

14673 Marion Patrick Holdings LLC, Applicant Modified

STATUTE/RULE CITATION:

381.0065(4)(a), F.S. - Lot is not 1/2 acre and 100 ft wide (0.23 ac, 80 ft requested, 0.5 ac, 100 ft required)

RECOMMENDATIONS: Variance Committee: P (SHO-N CHD-N DEP-N STI-2 HBI-1 REI-Y ENG-Y) Health Officer: P

Approved subject to the following conditions:

This variance applies only to the lot size requirements of section 381.0065(4)(a), F.S. The structure shall comply with the authorized sewage flow provisions of section 381.0065(4)(a), F.S.

The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

*IMPORTANT NOTE: An INRB may not be able to be installed due to site restrictions.

This variance applies only to the lot size requirements of section 381.0065(4)(a), F.S. The structure shall comply with the authorized sewage flow provisions of section 381.0065(4)(a), F.S.

The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

14674 Marion Quiga Inc., Applicant Shuler, Agent Modified

STATUTE/RULE CITATION:

381.0065(4)(a), F.S. - Lot is not 1/2 acre and 100 ft wide (0.26 ac, 90 ft requested, 0.5 ac, 100 ft required)

RECOMMENDATIONS: Variance Committee: P (SHO-N CHD-N DEP-N STI-2 HBI-1 REI-Y ENG-Y) Health Officer: P

Approved subject to the following conditions:

This variance applies only to the lot size requirements of section 381.0065(4)(a), F.S. The structure shall comply with the authorized sewage flow provisions of section 381.0065(4)(a), F.S.

The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

*IMPORTANT NOTE: An INRB may not be able to be installed due to site restrictions.

This variance applies only to the lot size requirements of section 381.0065(4)(a), F.S. The structure shall comply with the authorized sewage flow provisions of section 381.0065(4)(a), F.S.

The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

14675 Marion Quiga Inc., Applicant Shuler, Agent Modified

STATUTE/RULE CITATION:

381.0065(4)(a), F.S. - Lot is not 1/2 acre and 100 ft wide (0.23 ac, 80 ft requested, 0.5 ac, 100 ft required)

RECOMMENDATIONS: Variance Committee: P (SHO-N CHD-N DEP-N STI-2 HBI-1 REI-Y ENG-Y) Health Officer: P

Approved subject to the following conditions:

This variance applies only to the lot size requirements of section 381.0065(4)(a), F.S. The structure shall comply with the authorized sewage flow provisions of section 381.0065(4)(a), F.S.

The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

*IMPORTANT NOTE: An INRB may not be able to be installed due to site restrictions.

This variance applies only to the lot size requirements of section 381.0065(4)(a), F.S. The structure shall comply with the authorized sewage flow provisions of section 381.0065(4)(a), F.S.

The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

14676 Marion Miranda, Applicant Terneus, Agent Modified

STATUTE/RULE CITATION:

381.0065(4)(a), F.S. - Lot is not 1/2 acre and 100 ft wide (0.23 ac, 80 ft requested, 0.5 ac, 100 ft required)

RECOMMENDATIONS:

Variance Committee: P (SHO-N CHD-N DEP-N STI-2 HBI-1 REI-Y ENG-Y) Health Officer: P

Approved subject to the following conditions:

This variance applies only to the lot size requirements of section 381.0065(4)(a), F.S. The structure shall comply with the authorized sewage flow provisions of section 381.0065(4)(a), F.S.

The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

*IMPORTANT NOTE: An INRB may not be able to be installed due to site restrictions.

This variance applies only to the lot size requirements of section 381.0065(4)(a), F.S. The structure shall comply with the authorized sewage flow provisions of section 381.0065(4)(a), F.S.

The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

14677 Marion Miranda, Applicant Terneus, Agent Modified

STATUTE/RULE CITATION:

381.0065(4)(a), F.S. - Lot is not 1/2 acre and 100 ft wide (0.25 ac, 90 ft requested, 0.5 ac, 100 ft required)

RECOMMENDATIONS:

Variance Committee: P (SHO-N CHD-N DEP-N STI-2 HBI-1 REI-Y ENG-Y) Health Officer: P

Approved subject to the following conditions:

This variance applies only to the lot size requirements of section 381.0065(4)(a), F.S. The structure shall comply with the authorized sewage flow provisions of section 381.0065(4)(a), F.S.

The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

*IMPORTANT NOTE: An INRB may not be able to be installed due to site restrictions.

This variance applies only to the lot size requirements of section 381.0065(4)(a), F.S. The structure shall comply with the authorized sewage flow provisions of section 381.0065(4)(a), F.S.

The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

14678 Marion CASA 21, LLC, Applicant Fitzpatrick, Agent Modified

STATUTE/RULE CITATION:

381.0065(4)(a), F.S. - Lot is not 1/2 acre and 100 ft wide (0.25 ac, 90 ft requested, 0.5 ac, 100 ft required)

RECOMMENDATIONS:

Variance Committee: P (SHO-N CHD-N DEP-N STI-2 HBI-1 REI-Y ENG-Y) Health Officer: P

Approved subject to the following conditions:

This variance applies only to the lot size requirements of section 381.0065(4)(a), F.S. The structure shall comply with the authorized sewage flow provisions of section 381.0065(4)(a), F.S.

The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

*IMPORTANT NOTE: An INRB may not be able to be installed due to site restrictions.

This variance applies only to the lot size requirements of section 381.0065(4)(a), F.S. The structure shall comply with the authorized sewage flow provisions of section 381.0065(4)(a), F.S.

The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

14679 Marion The X Connection, Inc., Applicant Bakan Homes, LLC, Agent

STATUTE/RULE CITATION:

381.0065(4)(a), F.S. - Lot is not 1/2 acre and 100 ft wide (0.23 ac, 80 ft requested, 0.5 ac, 100 ft required)

RECOMMENDATIONS:

Variance Committee: P (SHO-Y CHD-Y DEP-Y STI-2 HBI-1 REI-Y ENG-Y) Health Officer: P

Approved subject to the following conditions:

This variance applies only to the lot size requirements of section 381.0065(4)(a), F.S. The structure shall comply with the authorized sewage flow provisions of section 381.0065(4)(a), F.S.

The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

14680 Marion DRC24 LLC, Applicant Salvador, Agent

STATUTE/RULE CITATION:

381.0065(4)(a), F.S. - Lot is not 1/2 acre and 100 ft wide (0.24 ac, 85 ft requested, 0.5 ac, 100 ft required)

RECOMMENDATIONS: Variance Committee: P (SHO-Y CHD-Y DEP-Y STI-2 HBI-1 REI-Y ENG-Y) Health Officer: P

Approved subject to the following conditions:

This variance applies only to the lot size requirements of section 381.0065(4)(a), F.S. The structure shall comply with the authorized sewage flow provisions of section 381.0065(4)(a), F.S.
The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

14681 Marion DRC24 LLC, Applicant Salvador, Agent

STATUTE/RULE CITATION:

381.0065(4)(a), F.S. - Lot is not 1/2 acre and 100 ft wide (0.24 ac, 85 ft requested, 0.5 ac, 100 ft required)

RECOMMENDATIONS: Variance Committee: P (SHO-Y CHD-Y DEP-Y STI-2 HBI-1 REI-Y ENG-Y) Health Officer: P

Approved subject to the following conditions:

This variance applies only to the lot size requirements of section 381.0065(4)(a), F.S. The structure shall comply with the authorized sewage flow provisions of section 381.0065(4)(a), F.S.
The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

14682 Marion Carson Building and Oxendine, Agent Modified
Development, Applicant

STATUTE/RULE CITATION:

381.0065(4)(a), F.S. - Lot is not 1/2 acre and 100 ft wide (0.24 ac, 88 ft requested, 0.5 ac, 100 ft required)

RECOMMENDATIONS: Variance Committee: P (SHO-N CHD-N DEP-N STI-2 HBI-1 REI-Y ENG-Y) Health Officer: P

Approved subject to the following conditions:

This variance applies only to the lot size requirements of section 381.0065(4)(a), F.S. The structure shall comply with the authorized sewage flow provisions of section 381.0065(4)(a), F.S.
The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

*IMPORTANT NOTE: An INRB may not be able to be installed due to site restrictions.

This variance applies only to the lot size requirements of section 381.0065(4)(a), F.S. The structure shall comply with the authorized sewage flow provisions of section 381.0065(4)(a), F.S.
The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

14683 Marion Carson Building and Oxendine, Agent Modified
Development, Applicant

STATUTE/RULE CITATION:

381.0065(4)(a), F.S. - Lot is not 1/2 acre and 100 ft wide (0.25 ac, 80 ft requested, 0.5 ac, 100 ft required)

RECOMMENDATIONS: Variance Committee: P (SHO-N CHD-N DEP-N STI-2 HBI-1 REI-Y ENG-Y) Health Officer: P

Approved subject to the following conditions:

This variance applies only to the lot size requirements of section 381.0065(4)(a), F.S. The structure shall comply with the authorized sewage flow provisions of section 381.0065(4)(a), F.S.
The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

*IMPORTANT NOTE: An INRB may not be able to be installed due to site restrictions.

This variance applies only to the lot size requirements of section 381.0065(4)(a), F.S. The structure shall comply with the authorized sewage flow provisions of section 381.0065(4)(a), F.S.
The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

14684 **Marion** **Carson Building and** **Oxendine, Agent** **Modified**
Development, Applicant

STATUTE/RULE CITATION:

381.0065(4)(a), F.S. - Lot is not 1/2 acre and 100 ft wide (0.23 ac, 80 ft requested, 0.5 ac, 100 ft required)

RECOMMENDATIONS: **Variance Committee: P (SHO-N CHD-N DEP-N STI-2 HBI-1 REI-Y ENG-Y)** **Health Officer: P**

Approved subject to the following conditions:

This variance applies only to the lot size requirements of section 381.0065(4)(a), F.S. The structure shall comply with the authorized sewage flow provisions of section 381.0065(4)(a), F.S.

The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

*IMPORTANT NOTE: An INRB may not be able to be installed due to site restrictions.

This variance applies only to the lot size requirements of section 381.0065(4)(a), F.S. The structure shall comply with the authorized sewage flow provisions of section 381.0065(4)(a), F.S.

The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

14685 **Marion** **Carson Building and** **Oxendine, Agent** **Modified**
Development, Applicant

STATUTE/RULE CITATION:

381.0065(4)(a), F.S. - Lot is not 1/2 acre (0.34 acre requested, 0.5 acre required)

RECOMMENDATIONS: **Variance Committee: P (SHO-N CHD-N DEP-N STI-2 HBI-1 REI-Y ENG-Y)** **Health Officer: P**

Approved subject to the following conditions:

This variance applies only to the lot size requirements of section 381.0065(4)(a), F.S. The structure shall comply with the authorized sewage flow provisions of section 381.0065(4)(a), F.S.

The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

*IMPORTANT NOTE: An INRB may not be able to be installed due to site restrictions.

This variance applies only to the lot size requirements of section 381.0065(4)(a), F.S. The structure shall comply with the authorized sewage flow provisions of section 381.0065(4)(a), F.S.

The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

14686 **Marion** **Worldwide Alliance, LLC,** **Silva-Rice, Agent**
Applicant

STATUTE/RULE CITATION:

381.0065(4)(a), F.S. - Lot is not 1/2 acre (0.28 acre requested, 0.5 acre required)

RECOMMENDATIONS: **Variance Committee: P (SHO-Y CHD-Y DEP-Y STI-2 HBI-1 REI-Y ENG-Y)** **Health Officer: P**

Approved subject to the following conditions:

This variance applies only to the lot size requirements of section 381.0065(4)(a), F.S. The structure shall comply with the authorized sewage flow provisions of section 381.0065(4)(a), F.S.

The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

14687 **Marion** **Worldwide Alliance, LLC,** **Silva-Rice, Agent**
Applicant

STATUTE/RULE CITATION:

381.0065(4)(a), F.S. - Lot is not 1/2 acre and 100 ft wide (0.23 ac, 80 ft requested, 0.5 ac, 100 ft required)

RECOMMENDATIONS: **Variance Committee: P (SHO-Y CHD-Y DEP-Y STI-2 HBI-1 REI-Y ENG-Y)** **Health Officer: P**

Approved subject to the following conditions:

This variance applies only to the lot size requirements of section 381.0065(4)(a), F.S. The structure shall comply with the authorized sewage flow provisions of section 381.0065(4)(a), F.S.

The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

14688 Marion Adams Homes of Northwest Florida, Inc., Applicant Riale, Agent

STATUTE/RULE CITATION:
381.0065(4)(a), F.S. - Lot is not 1/2 acre and 100 ft wide (0.24 ac, 82 ft requested, 0.5 ac, 100 ft required)

RECOMMENDATIONS: Variance Committee: P (SHO-Y CHD-Y DEP-Y STI-2 HBI-1 REI-Y ENG-Y) Health Officer: P
Approved subject to the following conditions:
This variance applies only to the lot size requirements of section 381.0065(4)(a), F.S. The structure shall comply with the authorized sewage flow provisions of section 381.0065(4)(a), F.S.
The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

14689 Marion Adams Homes of Northwest Florida, Inc., Applicant Riale, Agent

STATUTE/RULE CITATION:
381.0065(4)(a), F.S. - Lot is not 1/2 acre (0.34 acre requested, 0.5 acre required)

RECOMMENDATIONS: Variance Committee: P (SHO-Y CHD-Y DEP-Y STI-2 HBI-1 REI-Y ENG-Y) Health Officer: P
Approved subject to the following conditions:
This variance applies only to the lot size requirements of section 381.0065(4)(a), F.S. The structure shall comply with the authorized sewage flow provisions of section 381.0065(4)(a), F.S.
The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

14690 Marion Land Investments Q&R LLC, Applicant Salvador, Agent

STATUTE/RULE CITATION:
381.0065(4)(a), F.S. - Lot is not 1/2 acre and 100 ft wide (0.23 ac, 80 ft requested, 0.5 ac, 100 ft required)

RECOMMENDATIONS: Variance Committee: P (SHO-Y CHD-Y DEP-Y STI-2 HBI-1 REI-Y ENG-Y) Health Officer: P
Approved subject to the following conditions:
This variance applies only to the lot size requirements of section 381.0065(4)(a), F.S. The structure shall comply with the authorized sewage flow provisions of section 381.0065(4)(a), F.S.
The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

14691 Marion Group Capital LLC, Applicant Salvador, Agent

STATUTE/RULE CITATION:
381.0065(4)(a), F.S. - Lot is not 1/2 acre and 100 ft wide (0.23 ac, X ft requested, 0.5 ac, 100 ft required)

RECOMMENDATIONS: Variance Committee: P (SHO-Y CHD-Y DEP-Y STI-2 HBI-1 REI-Y ENG-Y) Health Officer: P
Approved subject to the following conditions:
This variance applies only to the lot size requirements of section 381.0065(4)(a), F.S. The structure shall comply with the authorized sewage flow provisions of section 381.0065(4)(a), F.S.
The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

14692 Marion D32 Invest, Applicant King Septic, Agent Modified

STATUTE/RULE CITATION:

381.0065(4)(a), F.S. - Lot is not 1/2 acre and 100 ft wide (0.23 ac, 80 ft requested, 0.5 ac, 100 ft required)

RECOMMENDATIONS: Variance Committee: P (SHO-N CHD-N DEP-N STI-2 HBI-1 REI-Y ENG-Y) Health Officer: P

Approved subject to the following conditions:

This variance applies only to the lot size requirements of section 381.0065(4)(a), F.S. The structure shall comply with the authorized sewage flow provisions of section 381.0065(4)(a), F.S.

The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

*IMPORTANT NOTE: An INRB may not be able to be installed due to site restrictions.

This variance applies only to the lot size requirements of section 381.0065(4)(a), F.S. The structure shall comply with the authorized sewage flow provisions of section 381.0065(4)(a), F.S.

The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

14693 Marion D32 Invest, Applicant King Septic, Agent

STATUTE/RULE CITATION:

381.0065(4)(a), F.S. - Lot is not 1/2 acre and 100 ft wide (0.24 ac, 85 ft requested, 0.5 ac, 100 ft required)

RECOMMENDATIONS: Variance Committee: P (SHO-Y CHD-Y DEP-Y STI-2 HBI-1 REI-Y ENG-Y) Health Officer: P

Approved subject to the following conditions:

This variance applies only to the lot size requirements of section 381.0065(4)(a), F.S. The structure shall comply with the authorized sewage flow provisions of section 381.0065(4)(a), F.S.

The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

14694 Marion Space Available, LLC, Applicant Fitzpatrick, Agent

STATUTE/RULE CITATION:

381.0065(4)(e)1., F.S. - Setback to private potable well (74 ft requested, 75 ft required)

62-6.005(1)(a), F.A.C. - Same as 381.0065(4)(e)1., F.S.

62-6.005(2), F.A.C. - Setback to property line/building foundation (2 ft requested, 5 ft required)

62-6.005(4)(a), F.A.C. - Inadequate unobstructed area available

RECOMMENDATIONS: Variance Committee: P (SHO-Y CHD-Y DEP-Y STI-2 HBI-Y REI-Y ENG-1) Health Officer: P

Approved subject to the following conditions:

The onsite sewage treatment and disposal system shall include an NSF 245 aerobic treatment unit.

The onsite sewage treatment and disposal system shall be set back from the adjacent property's private drinking water well by the maximum distance attainable but not less than 74 feet when installed.

14695 Marion Luxar Construction, Applicant Yameen, Agent

STATUTE/RULE CITATION:

381.0065(4)(a), F.S. - Lot is not 1/2 acre and 100 ft wide (0.47 ac, X ft requested, 0.5 ac, 100 ft required)

RECOMMENDATIONS: Variance Committee: P (SHO-Y CHD-Y DEP-Y STI-2 HBI-1 REI-Y ENG-Y) Health Officer: P

Approved subject to the following conditions:

This variance applies only to the lot size requirements of section 381.0065(4)(a), F.S. The structure shall comply with the authorized sewage flow provisions of section 381.0065(4)(a), F.S.

The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

14696 Marion NE 33rd Street LLC, Applicant Houck, Agent Modified

STATUTE/RULE CITATION:

381.0065(4)(a), F.S. - Lot is not 1/2 acre and 100 ft wide (0.34 ac, 85 ft requested, 0.5 ac, 100 ft required)

RECOMMENDATIONS: Variance Committee: P (SHO-N CHD-N DEP-N STI-2 HBI-1 REI-Y ENG-Y) Health Officer: P

Approved subject to the following conditions:

This variance applies only to the lot size requirements of section 381.0065(4)(a), F.S. The structure shall comply with the authorized sewage flow provisions of section 381.0065(4)(a), F.S.

The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

*IMPORTANT NOTE: An INRB may not be able to be installed due to site restrictions.

This variance applies only to the lot size requirements of section 381.0065(4)(a), F.S. The structure shall comply with the authorized sewage flow provisions of section 381.0065(4)(a), F.S.

The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

14697 Marion Seenanan, Applicant H&S Mobile Homes, Agent Modified

STATUTE/RULE CITATION:

381.0065(4)(e)1., F.S. - Setback to private potable well (65 ft requested, 75 ft required)

62-6.005(1)(a), F.A.C. - Same as 381.0065(4)(e)1., F.S.

62-6.005(4)(a), F.A.C. - Inadequate unobstructed area available

RECOMMENDATIONS: Variance Committee: P (SHO-N CHD-N DEP-N STI-1 HBI-Y REI-2 ENG-Y) Health Officer: P

Approved subject to the following conditions:

The onsite sewage treatment and disposal system shall be set back from the applicants private drinking water well by the maximum distance attainable but not less than 65 feet when installed.

To maximize the setback to the private drinking water well, the drainfield shall be installed in a bed configuration.

*IMPORTANT NOTE: An INRB may not be able to be installed due to site restrictions.

This variance applies only to the lot size requirements of section 381.0065(4)(a), F.S. The structure shall comply with the authorized sewage flow provisions of section 381.0065(4)(a), F.S.

The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

14698 Marion Aldana Contracting, LLC, Applicant

STATUTE/RULE CITATION:

381.0065(4)(a), F.S. - Lot is not 1/2 acre and 100 ft wide (0.23 ac, X ft requested, 0.5 ac, 100 ft required)

RECOMMENDATIONS: Variance Committee: P (SHO-Y CHD-Y DEP-Y STI-2 HBI-1 REI-Y ENG-Y) Health Officer: P

Approved subject to the following conditions:

This variance applies only to the lot size requirements of section 381.0065(4)(a), F.S. The structure shall comply with the authorized sewage flow provisions of section 381.0065(4)(a), F.S.

The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

14699 Marion Good Ol Boys, Applicant Ream, Agent Modified

STATUTE/RULE CITATION:

381.0065(4)(a), F.S. - Lot is not 1/2 acre and 100 ft wide (0.24 ac, 90 ft requested, 0.5 ac, 100 ft required)

RECOMMENDATIONS: Variance Committee: P (SHO-Y CHD-Y DEP-Y STI-Y HBI-2 REI-Y ENG-1) Health Officer: P

Approved subject to the following conditions:

The onsite sewage treatment and disposal system shall include either an in-ground nitrogen reducing biofilter (INRB), an NSF 245 aerobic treatment unit,

or a nitrogen-reducing performance-based treatment system designed to meet a 50% reduction in nitrogen before discharge to the drainfield.

*IMPORTANT NOTE: An INRB may not be able to be installed due to site restrictions.

This variance applies only to the lot size requirements of section 381.0065(4)(a), F.S. The structure shall comply with the authorized sewage flow provisions of section 381.0065(4)(a), F.S.

The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

14700 Marion Jen Homes, LLC, Applicant

STATUTE/RULE CITATION:

381.0065(4)(a), F.S. - Lot is not 1/2 acre and 100 ft wide (0.27 ac, X ft requested, 0.5 ac, 100 ft required)

RECOMMENDATIONS: Variance Committee: P (SHO-N CHD-N DEP-N STI-2 HBI-1 REI-Y ENG-Y) Health Officer: P

Approved subject to the following conditions:

This variance applies only to the lot size requirements of section 381.0065(4)(a), F.S. The structure shall comply with the authorized sewage flow provisions of section 381.0065(4)(a), F.S.

The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

*IMPORTANT NOTE: An INRB may not be able to be installed due to site restrictions.

This variance applies only to the lot size requirements of section 381.0065(4)(a), F.S. The structure shall comply with the authorized sewage flow provisions of section 381.0065(4)(a), F.S.

The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

14701 Lee Wei Song Realty Investment, LLC, Applicant

STATUTE/RULE CITATION:

381.0065(4)(g)2., F.S. - Setback to surface water body (25 ft requested, 50 ft required)

62-6.005(4)(a), F.A.C. - Inadequate unobstructed area available

RECOMMENDATIONS: Variance Committee: P (SHO-Y CHD-Y DEP-1 STI-Y HBI-Y REI-Y ENG-2) Health Officer: P

Approved subject to the following conditions:

The onsite sewage treatment and disposal system shall include an NSF 245 aerobic treatment unit.

The onsite sewage treatment and disposal system treatment receptacle shall be set back from the surface water by the maximum distance attainable but not less than 25 feet when installed.

The onsite sewage treatment and disposal system drainfield shall be set back from surface water by the maximum distance attainable but not less than 31 feet when installed.

14702 Lee NFP Builders LLC, Applicant

STATUTE/RULE CITATION:

381.0065(4)(a), F.S. - Lot is not 1/2 acre and 100 ft wide (0.23 ac, 80 ft requested, 0.5 ac, 100 ft required)

62-6.005(4)(a), F.A.C. - Inadequate unobstructed area available

RECOMMENDATIONS: Variance Committee: P (SHO-Y CHD-Y DEP-2 STI-1 HBI-Y REI-Y ENG-Y) Health Officer: P

Approved subject to the following conditions:

The onsite sewage treatment and disposal system shall include either an in-ground nitrogen reducing biofilter (INRB), an NSF 245 aerobic treatment unit,

or a nitrogen-reducing performance-based treatment system designed to meet a 50% reduction in nitrogen before discharge to the drainfield.

*IMPORTANT NOTE: An INRB may not be able to be installed due to site restrictions.

This variance applies only to the lot size requirements of section 381.0065(4)(a), F.S. The structure shall comply with the authorized sewage flow provisions of section 381.0065(4)(a), F.S.

The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

14703 Lee Otano, Applicant

STATUTE/RULE CITATION:

381.0065(4)(a), F.S. - Lot is not 1/2 acre and 100 ft wide (0.46 ac, X ft requested, 0.5 ac, 100 ft required)

RECOMMENDATIONS: Variance Committee: P (SHO-Y CHD-Y DEP-Y STI-2 HBI-Y REI-Y ENG-1) Health Officer: P

Approved subject to the following conditions:

The onsite sewage treatment and disposal system shall include either an in-ground nitrogen reducing biofilter (INRB), an NSF 245 aerobic treatment unit, or a nitrogen-reducing performance-based treatment system designed to meet a 50% reduction in nitrogen before discharge to the drainfield.

*IMPORTANT NOTE: An INRB may not be able to be installed due to site restrictions.

This variance applies only to the lot size requirements of section 381.0065(4)(a), F.S. The structure shall comply with the authorized sewage flow provisions of section 381.0065(4)(a), F.S. The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

14704 Volusia Lara M F Investments LLC, John C Cascio Septic Service, Applicant Inc., Agent

STATUTE/RULE CITATION:

381.0065(4)(g)2.b., F.S. - Estimated sewage flow exceeds 1500 gpd/acre (300 gpd requested, 285 gpd required)

RECOMMENDATIONS: Variance Committee: P (SHO-N CHD-Y DEP-Y STI-1 HBI-Y REI-2 ENG-Y) Health Officer: P

Approved subject to the following conditions:

The onsite sewage treatment and disposal system shall include an NSF 245 aerobic treatment unit.

14705 Volusia Maronda Homes, LLC, Applicant Franz, Agent

STATUTE/RULE CITATION:

381.0065(4)(e)1., F.S. - Setback to private potable well (59/60 ft requested, 75 ft required)

62-6.005(1)(a), F.A.C. - Same as 381.0065(4)(e)1., F.S.

62-6.005(4)(a), F.A.C. - Inadequate unobstructed area available

RECOMMENDATIONS: Variance Committee: P (SHO-Y CHD-N DEP-Y STI-Y HBI-2 REI-Y ENG-1) Health Officer: P

Approved subject to the following conditions:

The onsite sewage treatment and disposal system shall include an NSF 245 aerobic treatment unit with drip irrigation.

The onsite sewage treatment and disposal system shall be set back from the private drinking water wells by the maximum distance attainable but not less than proposed in the application (59' and 60').

14706 Bay Don & Bubba Properties LLC, Wilson, Agent Applicant

STATUTE/RULE CITATION:

381.0065(4)(b), F.S. - Lot density exceeds 4/acre

RECOMMENDATIONS: Variance Committee: P (SHO-Y CHD-Y DEP-Y STI-1 HBI-Y REI-Y ENG-2) Health Officer: P

Approved subject to the following conditions:

The onsite sewage treatment and disposal system shall include an NSF 245 aerobic treatment unit.

14711 Duval BCEL 8B, LLC, Applicant Septic Services Inc., Agent
STATUTE/RULE CITATION:
381.0065(4)(e)1., F.S. - Setback to private potable well (65/67/69 ft requested, 75 ft required)
62-6.005(1)(a), F.A.C. - Same as 381.0065(4)(e)1., F.S.
62-6.005(4)(a), F.A.C. - Inadequate unobstructed area available

RECOMMENDATIONS: Variance Committee: P (SHO-Y CHD-Y DEP-Y STI-1 HBI-Y REI-2 ENG-Y) Health Officer: P
Approved subject to the following conditions:
The onsite sewage treatment and disposal system shall be a performance-based treatment system meeting advanced secondary treatment standards with drip irrigation.
The onsite sewage treatment and disposal system shall be set back from the private drinking water wells by the maximum distance attainable but not less than proposed in the application (65', 67' and 69').

14712 Duval BCEL 10B, LLC, Applicant Septic Services Inc., Agent
STATUTE/RULE CITATION:
381.0065(4)(e)1., F.S. - Setback to private potable well (63/64/68 ft requested, 75 ft required)
62-6.005(1)(a), F.A.C. - Same as 381.0065(4)(e)1., F.S.
62-6.005(4)(a), F.A.C. - Inadequate unobstructed area available

RECOMMENDATIONS: Variance Committee: P (SHO-Y CHD-Y DEP-Y STI-2 HBI-Y REI-Y ENG-1) Health Officer: P
Approved subject to the following conditions:
The onsite sewage treatment and disposal system shall be a performance-based treatment system meeting advanced secondary treatment standards with drip irrigation.
The onsite sewage treatment and disposal system shall be set back from the private drinking water wells by the maximum distance attainable but not less than proposed in the application (63', 64' and 68').

14713 Duval Hoose Home and Investments, Septic Services Inc., Agent
LLC, Applicant
STATUTE/RULE CITATION:
381.0065(4)(a), F.S. - Lot is not 1/2 acre (0.4 acre requested, 0.5 acre required)

RECOMMENDATIONS: Variance Committee: P (SHO-N CHD-N DEP-Y STI-2 HBI-1 REI-Y ENG-Y) Health Officer: P
Approved subject to the following conditions:
The onsite sewage treatment and disposal system shall include an NSF 245 aerobic treatment unit with drip irrigation.

14714 Brevard Carharp Ventures Palm Bay LLC, Davis, Agent
Applicant

STATUTE/RULE CITATION:
381.0065(4)(g)2., F.S. - Setback to surface water body (35 ft requested, 50 ft required)
62-6.005(4)(a), F.A.C. - Inadequate unobstructed area available

RECOMMENDATIONS: Variance Committee: P (SHO-N CHD-N DEP-2 STI-Y HBI-1 REI-Y ENG-Y) Health Officer: P
Approved subject to the following conditions:
The onsite sewage treatment and disposal system shall include an NSF 245 aerobic treatment unit with drip irrigation.
The onsite sewage treatment and disposal system shall be set back from the surface water by the maximum distance attainable but not less than 35 feet when installed.

14719 Brevard Sharp, Applicant ASAP Onsite Septic & Sewer, Agent

STATUTE/RULE CITATION:

62-6.005(4)(a), F.A.C. - Inadequate unobstructed area available
62-6, Table IV, F.A.C. - Reduced ATU plant size (450 gpd requested, 500 gpd required)

RECOMMENDATIONS: Variance Committee: P (SHO-Y CHD-N DEP-Y STI-Y HBI-1 REI-2 ENG-Y) Health Officer: P

Approved subject to the following conditions:

The onsite sewage treatment and disposal system shall include an NSF 245 aerobic treatment unit with drip irrigation.

14720 Brevard Adams Homes, Applicant Davis, Agent

STATUTE/RULE CITATION:

381.0065(4)(g)2., F.S. - Setback to surface water body (37 ft to tank requested, 50 ft required)
62-6.005(4)(a), F.A.C. - Inadequate unobstructed area available

RECOMMENDATIONS: Variance Committee: P (SHO-Y CHD-Y DEP-Y STI-1 HBI-2 REI-Y ENG-Y) Health Officer: P

Approved subject to the following conditions:

The onsite sewage treatment and disposal system shall include an NSF 245 aerobic treatment unit with drip irrigation.

The onsite sewage treatment and disposal system treatment receptacles shall be set back from the surface water by the maximum distance attainable but not less than 37 feet when installed.

14721 Brevard RDMA LLC, Applicant Davis, Agent

STATUTE/RULE CITATION:

381.0065(4)(a), F.S. - Lot is not 100 ft wide (80 ft requested, 100 ft required)

RECOMMENDATIONS: Variance Committee: P (SHO-Y CHD-Y DEP-Y STI-1 HBI-Y REI-Y ENG-2) Health Officer: P

Approved subject to the following conditions:

The onsite sewage treatment and disposal system shall include an NSF 245 aerobic treatment unit.

14722 Brevard Adams Homes, Applicant Davis, Agent

STATUTE/RULE CITATION:

381.0065(4)(e)1., F.S. - Setback to private potable well (68/69/71 ft requested, 75 ft required)
62-6.005(1)(a), F.A.C. - Same as 381.0065(4)(e)1., F.S.
62-6.005(4)(a), F.A.C. - Inadequate unobstructed area available

RECOMMENDATIONS: Variance Committee: P (SHO-Y CHD-Y DEP-2 STI-Y HBI-Y REI-Y ENG-1) Health Officer: P

Approved subject to the following conditions:

The onsite sewage treatment and disposal system shall be a performance-based treatment system meeting secondary treatment standards with drip irrigation. The aerobic treatment unit shall meet NSF 245 standards.

The onsite sewage treatment and disposal system shall be set back from the private drinking water wells by the maximum distance attainable but not less than proposed in the application (68', 69' and 71').

14723 Brevard Adams Homes, Applicant Davis, Agent

STATUTE/RULE CITATION:

381.0065(4)(e)1., F.S. - Setback to private potable well (50/68/51 ft requested, 75 ft required)
62-6.005(1)(a), F.A.C. - Same as 381.0065(4)(e)1., F.S.
62-6.005(4)(a), F.A.C. - Inadequate unobstructed area available
62-6.009(5)(a)15., F.A.C. - Inadequate mound shoulders (0 ft requested, 1.5 ft required)

RECOMMENDATIONS: Variance Committee: P (SHO-N CHD-N DEP-Y STI-Y HBI-2 REI-Y ENG-1) Health Officer: P

Approved subject to the following conditions:

The onsite sewage treatment and disposal system shall include an NSF 245 aerobic treatment unit with drip irrigation.
The onsite sewage treatment and disposal system shall be set back from the private drinking water wells by the maximum distance attainable but not less than proposed in the application (50', 51', and 68').

14724 Jackson Greenwood Supermarket Inc, Gorman Environmental
Applicant Services LLC, Agent

STATUTE/RULE CITATION:

381.0065(4)(i), F.S. - System likely to dispose of hazardous/toxic/industrial waste (Ind, tox, haz waste requested, Domestic, Commercial required)

RECOMMENDATIONS: Variance Committee: A (SHO-Y CHD-Y DEP-Y STI-Y HBI-Y REI-2 ENG-1) Health Officer: A

Approved

14725 Dade City of Coral Gables, Applicant Winklejohn, Agent

STATUTE/RULE CITATION:

381.0065(2)(l), F.S. - lot description
(0 requested, required)

RECOMMENDATIONS: Variance Committee: P (SHO-Y CHD-Y DEP-Y STI-2 HBI-1 REI-Y ENG-Y) Health Officer: P

Approved subject to the following conditions:

The onsite sewage treatment and disposal system shall be a performance-based treatment system meeting baseline treatment standards with advanced secondary treatment standards for carbonaceous biochemical oxygen demand after 5 days (CBOD5) and total suspended solids (TSS) with drip irrigation.