

OSTDS VARIANCE COMMITTEE MEETING MINUTES
Thursday, December 2, 2021

14223 Marion Pac 3 Properties LLC, Applicant Brooks Construction Services, LLC, Agent

STATUTE/RULE CITATION:

381.0065(4)(a), FS - Lot is not 1/2 acre and 100 ft wide (0.23 ac, 80 ft requested, 0.5 ac, 100 ft required)

RECOMMENDATIONS: Variance Committee: P (SHO-Y CHD-Y DEP-Y STI-2 HBI-1 REI-Y ENG-) Health Officer: P

Approved subject to the following conditions:

This variance applies only to the lot size requirements of section 381.0065(4)(a), F.S. The structure shall comply with the authorized sewage flow provisions of section 381.0065(4)(a), F.S. The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

14610 Marion Good Ol Boys, Applicant Rose Marie's Permit Service LLC, Agent

STATUTE/RULE CITATION:

381.0065(4)(a), F.S. - Lot is not 1/2 acre and 100 ft wide (0.24 ac, 88 ft requested, 0.5 ac, 100 ft required)

RECOMMENDATIONS: Variance Committee: P (SHO-2 CHD-Y DEP-1 STI-N HBI-N REI-N ENG-) Health Officer: P

Approved subject to the following conditions:

The onsite sewage treatment and disposal system shall include either an in-ground nitrogen reducing biofilter (INRB), an NSF 245 aerobic treatment unit, or a nitrogen-reducing performance-based treatment system designed to meet a 50% reduction in nitrogen before discharge to the drainfield.

*IMPORTANT NOTE: An INRB may not be able to be installed due to site restrictions.

This variance applies only to the lot size requirements of section 381.0065(4)(a), F.S. The structure shall comply with the authorized sewage flow provisions of section 381.0065(4)(a), F.S. The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

14611 Marion Good Ol Boys, Applicant Rose Marie's Permit Service LLC, Agent

STATUTE/RULE CITATION:

381.0065(4)(a), F.S. - Lot is not 1/2 acre and 100 ft wide (0.24 ac, 85 ft requested, 0.5 ac, 100 ft required)

RECOMMENDATIONS: Variance Committee: P (SHO-2 CHD-Y DEP-1 STI-N HBI-N REI-N ENG-) Health Officer: P

Approved subject to the following conditions:

The onsite sewage treatment and disposal system shall include either an in-ground nitrogen reducing biofilter (INRB), an NSF 245 aerobic treatment unit, or a nitrogen-reducing performance-based treatment system designed to meet a 50% reduction in nitrogen before discharge to the drainfield.

*IMPORTANT NOTE: An INRB may not be able to be installed due to site restrictions.

This variance applies only to the lot size requirements of section 381.0065(4)(a), F.S. The structure shall comply with the authorized sewage flow provisions of section 381.0065(4)(a), F.S. The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

14612 Marion Good Ol Boys, Applicant Rose Marie's Permit Service LLC, Agent

STATUTE/RULE CITATION:
381.0065(4)(a), F.S. - Lot is not 1/2 acre and 100 ft wide (0.26 ac, X ft requested, 0.5 ac, 100 ft required)

RECOMMENDATIONS: Variance Committee: P (SHO-2 CHD-Y DEP-1 STI-N HBI-N REI-N ENG-) Health Officer: P

Approved subject to the following conditions:
The onsite sewage treatment and disposal system shall include either an in-ground nitrogen reducing biofilter (INRB), an NSF 245 aerobic treatment unit, or a nitrogen-reducing performance-based treatment system designed to meet a 50% reduction in nitrogen before discharge to the drainfield.
*IMPORTANT NOTE: An INRB may not be able to be installed due to site restrictions.
This variance applies only to the lot size requirements of section 381.0065(4)(a), F.S. The structure shall comply with the authorized sewage flow provisions of section 381.0065(4)(a), F.S.
The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

14613 Marion Good Ol Boys, Applicant Rose Marie's Permit Service LLC, Agent

STATUTE/RULE CITATION:
381.0065(4)(a), F.S. - Lot is not 1/2 acre and 100 ft wide (0.23 ac, 80 ft requested, 0.5 ac, 100 ft required)

RECOMMENDATIONS: Variance Committee: P (SHO-2 CHD-Y DEP-1 STI-N HBI-N REI-N ENG-) Health Officer: P

Approved subject to the following conditions:
The onsite sewage treatment and disposal system shall include either an in-ground nitrogen reducing biofilter (INRB), an NSF 245 aerobic treatment unit, or a nitrogen-reducing performance-based treatment system designed to meet a 50% reduction in nitrogen before discharge to the drainfield.
*IMPORTANT NOTE: An INRB may not be able to be installed due to site restrictions.
This variance applies only to the lot size requirements of section 381.0065(4)(a), F.S. The structure shall comply with the authorized sewage flow provisions of section 381.0065(4)(a), F.S.
The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

14614 Marion Good Ol Boys, Applicant Rose Marie's Permit Service LLC, Agent

STATUTE/RULE CITATION:
381.0065(4)(a), F.S. - Lot is not 1/2 acre and 100 ft wide (0.25 ac, 80 ft requested, 0.5 ac, 100 ft required)

RECOMMENDATIONS: Variance Committee: P (SHO-2 CHD-Y DEP-1 STI-N HBI-N REI-N ENG-) Health Officer: P

Approved subject to the following conditions:
The onsite sewage treatment and disposal system shall include either an in-ground nitrogen reducing biofilter (INRB), an NSF 245 aerobic treatment unit, or a nitrogen-reducing performance-based treatment system designed to meet a 50% reduction in nitrogen before discharge to the drainfield.
*IMPORTANT NOTE: An INRB may not be able to be installed due to site restrictions.
This variance applies only to the lot size requirements of section 381.0065(4)(a), F.S. The structure shall comply with the authorized sewage flow provisions of section 381.0065(4)(a), F.S.
The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

14615 Marion Good Ol Boys, Applicant Rose Marie's Permit Service LLC, Agent

STATUTE/RULE CITATION:

381.0065(4)(a), F.S. - Lot is not 1/2 acre and 100 ft wide (0.24 ac, 80 ft requested, 0.5 ac, 100 ft required)

RECOMMENDATIONS: Variance Committee: P (SHO-2 CHD-Y DEP-1 STI-N HBI-N REI-N ENG-) Health Officer: P

Approved subject to the following conditions:

The onsite sewage treatment and disposal system shall include either an in-ground nitrogen reducing biofilter (INRB), an NSF 245 aerobic treatment unit, or a nitrogen-reducing performance-based treatment system designed to meet a 50% reduction in nitrogen before discharge to the drainfield.

*IMPORTANT NOTE: An INRB may not be able to be installed due to site restrictions.

This variance applies only to the lot size requirements of section 381.0065(4)(a), F.S. The structure shall comply with the authorized sewage flow provisions of section 381.0065(4)(a), F.S.

The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

14616 Marion Good Ol Boys, Applicant Rose Marie's Permit Service LLC, Agent

STATUTE/RULE CITATION:

381.0065(4)(a), F.S. - Lot is not 1/2 acre and 100 ft wide (0.32 ac, 80 ft requested, 0.5 ac, 100 ft required)

RECOMMENDATIONS: Variance Committee: P (SHO-2 CHD-Y DEP-1 STI-N HBI-N REI-N ENG-) Health Officer: P

Approved subject to the following conditions:

The onsite sewage treatment and disposal system shall include either an in-ground nitrogen reducing biofilter (INRB), an NSF 245 aerobic treatment unit, or a nitrogen-reducing performance-based treatment system designed to meet a 50% reduction in nitrogen before discharge to the drainfield.

*IMPORTANT NOTE: An INRB may not be able to be installed due to site restrictions.

This variance applies only to the lot size requirements of section 381.0065(4)(a), F.S. The structure shall comply with the authorized sewage flow provisions of section 381.0065(4)(a), F.S.

The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

14617 Marion Good Ol Boys, Applicant Rose Marie's Permit Service LLC, Agent

STATUTE/RULE CITATION:

381.0065(4)(a), F.S. - Lot is not 1/2 acre (0.31 acre requested, 0.5 acre required)

RECOMMENDATIONS: Variance Committee: P (SHO-2 CHD-Y DEP-1 STI-N HBI-N REI-N ENG-) Health Officer: P

Approved subject to the following conditions:

The onsite sewage treatment and disposal system shall include either an in-ground nitrogen reducing biofilter (INRB), an NSF 245 aerobic treatment unit, or a nitrogen-reducing performance-based treatment system designed to meet a 50% reduction in nitrogen before discharge to the drainfield.

*IMPORTANT NOTE: An INRB may not be able to be installed due to site restrictions.

This variance applies only to the lot size requirements of section 381.0065(4)(a), F.S. The structure shall comply with the authorized sewage flow provisions of section 381.0065(4)(a), F.S.

The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

14618 Marion Good Ol Boys, Applicant Rose Marie's Permit Service LLC, Agent

STATUTE/RULE CITATION:
381.0065(4)(a), F.S. - Lot is not 1/2 acre and 100 ft wide (0.24 ac, 85 ft requested, 0.5 ac, 100 ft required)

RECOMMENDATIONS: Variance Committee: P (SHO-2 CHD-Y DEP-1 STI-N HBI-N REI-N ENG-) Health Officer: P

Approved subject to the following conditions:
The onsite sewage treatment and disposal system shall include either an in-ground nitrogen reducing biofilter (INRB), an NSF 245 aerobic treatment unit, or a nitrogen-reducing performance-based treatment system designed to meet a 50% reduction in nitrogen before discharge to the drainfield.
*IMPORTANT NOTE: An INRB may not be able to be installed due to site restrictions.
This variance applies only to the lot size requirements of section 381.0065(4)(a), F.S. The structure shall comply with the authorized sewage flow provisions of section 381.0065(4)(a), F.S.
The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

14619 Marion Good Ol Boys, Applicant Rose Marie's Permit Service LLC, Agent

STATUTE/RULE CITATION:
381.0065(4)(a), F.S. - Lot is not 1/2 acre and 100 ft wide (0.23 ac, 80 ft requested, 0.5 ac, 100 ft required)

RECOMMENDATIONS: Variance Committee: P (SHO-2 CHD-Y DEP-1 STI-N HBI-N REI-N ENG-) Health Officer: P

Approved subject to the following conditions:
The onsite sewage treatment and disposal system shall include either an in-ground nitrogen reducing biofilter (INRB), an NSF 245 aerobic treatment unit, or a nitrogen-reducing performance-based treatment system designed to meet a 50% reduction in nitrogen before discharge to the drainfield.
*IMPORTANT NOTE: An INRB may not be able to be installed due to site restrictions.
This variance applies only to the lot size requirements of section 381.0065(4)(a), F.S. The structure shall comply with the authorized sewage flow provisions of section 381.0065(4)(a), F.S.
The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

14620 Marion Good Ol Boys, Applicant Rose Marie's Permit Service LLC, Agent

STATUTE/RULE CITATION:
381.0065(4)(a), F.S. - Lot is not 1/2 acre and 100 ft wide (0.43 ac, X ft requested, 0.5 ac, 100 ft required)

RECOMMENDATIONS: Variance Committee: P (SHO-2 CHD-Y DEP-1 STI-N HBI-N REI-N ENG-) Health Officer: P

Approved subject to the following conditions:
The onsite sewage treatment and disposal system shall include either an in-ground nitrogen reducing biofilter (INRB), an NSF 245 aerobic treatment unit, or a nitrogen-reducing performance-based treatment system designed to meet a 50% reduction in nitrogen before discharge to the drainfield.
*IMPORTANT NOTE: An INRB may not be able to be installed due to site restrictions.
This variance applies only to the lot size requirements of section 381.0065(4)(a), F.S. The structure shall comply with the authorized sewage flow provisions of section 381.0065(4)(a), F.S.
The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

14621 Marion Good Ol Boys, Applicant Rose Marie's Permit Service LLC, Agent

STATUTE/RULE CITATION:
381.0065(4)(a), F.S. - Lot is not 1/2 acre and 100 ft wide (0.23 ac, 80 ft requested, 0.5 ac, 100 ft required)

RECOMMENDATIONS: Variance Committee: P (SHO-2 CHD-Y DEP-1 STI-N HBI-N REI-N ENG-) Health Officer: P

Approved subject to the following conditions:
The onsite sewage treatment and disposal system shall include either an in-ground nitrogen reducing biofilter (INRB), an NSF 245 aerobic treatment unit, or a nitrogen-reducing performance-based treatment system designed to meet a 50% reduction in nitrogen before discharge to the drainfield.
*IMPORTANT NOTE: An INRB may not be able to be installed due to site restrictions.
This variance applies only to the lot size requirements of section 381.0065(4)(a), F.S. The structure shall comply with the authorized sewage flow provisions of section 381.0065(4)(a), F.S.
The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

14622 Marion VTW Fourth LLC, Applicant Rose Marie's Permit Service LLC, Agent

STATUTE/RULE CITATION:
381.0065(4)(a), F.S. - Lot is not 1/2 acre and 100 ft wide (0.23 ac, 80 ft requested, 0.5 ac, 100 ft required)

RECOMMENDATIONS: Variance Committee: P (SHO-2 CHD-Y DEP-1 STI-N HBI-N REI-N ENG-) Health Officer: P

Approved subject to the following conditions:
The onsite sewage treatment and disposal system shall include either an in-ground nitrogen reducing biofilter (INRB), an NSF 245 aerobic treatment unit, or a nitrogen-reducing performance-based treatment system designed to meet a 50% reduction in nitrogen before discharge to the drainfield.
*IMPORTANT NOTE: An INRB may not be able to be installed due to site restrictions.
This variance applies only to the lot size requirements of section 381.0065(4)(a), F.S. The structure shall comply with the authorized sewage flow provisions of section 381.0065(4)(a), F.S.
The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

14623 Marion VTW Fourth LLC, Applicant Rose Marie's Permit Service LLC, Agent

STATUTE/RULE CITATION:
381.0065(4)(a), F.S. - Lot is not 1/2 acre and 100 ft wide (0.24 ac, 80 ft requested, 0.5 ac, 100 ft required)

RECOMMENDATIONS: Variance Committee: P (SHO-2 CHD-Y DEP-1 STI-N HBI-N REI-N ENG-) Health Officer: P

Approved subject to the following conditions:
The onsite sewage treatment and disposal system shall include either an in-ground nitrogen reducing biofilter (INRB), an NSF 245 aerobic treatment unit, or a nitrogen-reducing performance-based treatment system designed to meet a 50% reduction in nitrogen before discharge to the drainfield.
*IMPORTANT NOTE: An INRB may not be able to be installed due to site restrictions.
This variance applies only to the lot size requirements of section 381.0065(4)(a), F.S. The structure shall comply with the authorized sewage flow provisions of section 381.0065(4)(a), F.S.
The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

14624 Marion VTW Fourth LLC, Applicant Rose Marie's Permit Service LLC, Agent

STATUTE/RULE CITATION:

381.0065(4)(a), F.S. - Lot is not 1/2 acre and 100 ft wide (0.23 ac, 80 ft requested, 0.5 ac, 100 ft required)

RECOMMENDATIONS: Variance Committee: P (SHO-2 CHD-Y DEP-1 STI-N HBI-N REI-N ENG-) Health Officer: P

Approved subject to the following conditions:

The onsite sewage treatment and disposal system shall include either an in-ground nitrogen reducing biofilter (INRB), an NSF 245 aerobic treatment unit, or a nitrogen-reducing performance-based treatment system designed to meet a 50% reduction in nitrogen before discharge to the drainfield.

*IMPORTANT NOTE: An INRB may not be able to be installed due to site restrictions.

This variance applies only to the lot size requirements of section 381.0065(4)(a), F.S. The structure shall comply with the authorized sewage flow provisions of section 381.0065(4)(a), F.S.

The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

14625 Marion VTW Fourth LLC, Applicant Rose Marie's Permit Service LLC, Agent

STATUTE/RULE CITATION:

381.0065(4)(a), F.S. - Lot is not 1/2 acre and 100 ft wide (0.23 ac, 80 ft requested, 0.5 ac, 100 ft required)

RECOMMENDATIONS: Variance Committee: P (SHO-2 CHD-Y DEP-1 STI-N HBI-N REI-N ENG-) Health Officer: P

Approved subject to the following conditions:

The onsite sewage treatment and disposal system shall include either an in-ground nitrogen reducing biofilter (INRB), an NSF 245 aerobic treatment unit, or a nitrogen-reducing performance-based treatment system designed to meet a 50% reduction in nitrogen before discharge to the drainfield.

*IMPORTANT NOTE: An INRB may not be able to be installed due to site restrictions.

This variance applies only to the lot size requirements of section 381.0065(4)(a), F.S. The structure shall comply with the authorized sewage flow provisions of section 381.0065(4)(a), F.S.

The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

14626 Marion VTW Fourth LLC, Applicant Rose Marie's Permit Service LLC, Agent

STATUTE/RULE CITATION:

381.0065(4)(a), F.S. - Lot is not 1/2 acre and 100 ft wide (0.32 ac, 80 ft requested, 0.5 ac, 100 ft required)

RECOMMENDATIONS: Variance Committee: P (SHO-2 CHD-Y DEP-1 STI-N HBI-N REI-N ENG-) Health Officer: P

Approved subject to the following conditions:

The onsite sewage treatment and disposal system shall include either an in-ground nitrogen reducing biofilter (INRB), an NSF 245 aerobic treatment unit, or a nitrogen-reducing performance-based treatment system designed to meet a 50% reduction in nitrogen before discharge to the drainfield.

*IMPORTANT NOTE: An INRB may not be able to be installed due to site restrictions.

This variance applies only to the lot size requirements of section 381.0065(4)(a), F.S. The structure shall comply with the authorized sewage flow provisions of section 381.0065(4)(a), F.S.

The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

14627 Marion Patrick Holdings LLC, Applicant Rogers, Agent

STATUTE/RULE CITATION:

381.0065(4)(a), F.S. - Lot is not 1/2 acre and 100 ft wide (0.24 ac, 85 ft requested, 0.5 ac, 100 ft required)

RECOMMENDATIONS: Variance Committee: P (SHO-2 CHD-Y DEP-1 STI-N HBI-N REI-N ENG-) Health Officer: P

Approved subject to the following conditions:

The onsite sewage treatment and disposal system shall include either an in-ground nitrogen reducing biofilter (INRB), an NSF 245 aerobic treatment unit, or a nitrogen-reducing performance-based treatment system designed to meet a 50% reduction in nitrogen before discharge to the drainfield.

*IMPORTANT NOTE: An INRB may not be able to be installed due to site restrictions.

This variance applies only to the lot size requirements of section 381.0065(4)(a), F.S. The structure shall comply with the authorized sewage flow provisions of section 381.0065(4)(a), F.S.

The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

14628 Marion Patrick Holdings LLC, Applicant Rogers, Agent

STATUTE/RULE CITATION:

381.0065(4)(a), F.S. - Lot is not 1/2 acre and 100 ft wide (0.23 ac, 80 ft requested, 0.5 ac, 100 ft required)

RECOMMENDATIONS: Variance Committee: P (SHO-2 CHD-Y DEP-1 STI-N HBI-N REI-N ENG-) Health Officer: P

Approved subject to the following conditions:

The onsite sewage treatment and disposal system shall include either an in-ground nitrogen reducing biofilter (INRB), an NSF 245 aerobic treatment unit, or a nitrogen-reducing performance-based treatment system designed to meet a 50% reduction in nitrogen before discharge to the drainfield.

*IMPORTANT NOTE: An INRB may not be able to be installed due to site restrictions.

This variance applies only to the lot size requirements of section 381.0065(4)(a), F.S. The structure shall comply with the authorized sewage flow provisions of section 381.0065(4)(a), F.S.

The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

14629 Marion Patrick Holdings LLC, Applicant Rogers, Agent

STATUTE/RULE CITATION:

381.0065(4)(a), F.S. - Lot is not 1/2 acre and 100 ft wide (0.26 ac, X ft requested, 0.5 ac, 100 ft required)

RECOMMENDATIONS: Variance Committee: P (SHO-2 CHD-Y DEP-1 STI-N HBI-N REI-N ENG-) Health Officer: P

Approved subject to the following conditions:

The onsite sewage treatment and disposal system shall include either an in-ground nitrogen reducing biofilter (INRB), an NSF 245 aerobic treatment unit, or a nitrogen-reducing performance-based treatment system designed to meet a 50% reduction in nitrogen before discharge to the drainfield.

*IMPORTANT NOTE: An INRB may not be able to be installed due to site restrictions.

This variance applies only to the lot size requirements of section 381.0065(4)(a), F.S. The structure shall comply with the authorized sewage flow provisions of section 381.0065(4)(a), F.S.

The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

14630 Marion Patrick Holdings LLC, Applicant Rogers, Agent

STATUTE/RULE CITATION:

381.0065(4)(a), F.S. - Lot is not 1/2 acre and 100 ft wide (0.23 ac, 80 ft requested, 0.5 ac, 100 ft required)

RECOMMENDATIONS: Variance Committee: P (SHO-2 CHD-Y DEP-1 STI-N HBI-N REI-N ENG-) Health Officer: P

Approved subject to the following conditions:

The onsite sewage treatment and disposal system shall include either an in-ground nitrogen reducing biofilter (INRB), an NSF 245 aerobic treatment unit, or a nitrogen-reducing performance-based treatment system designed to meet a 50% reduction in nitrogen before discharge to the drainfield.

*IMPORTANT NOTE: An INRB may not be able to be installed due to site restrictions.

This variance applies only to the lot size requirements of section 381.0065(4)(a), F.S. The structure shall comply with the authorized sewage flow provisions of section 381.0065(4)(a), F.S.

The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

14631 Marion Jen Homes, LLC, Applicant

STATUTE/RULE CITATION:

381.0065(4)(e)1., F.S. - Setback to private potable well (58 ft requested, 75 ft required)
62-6.005(1)(a), F.A.C. - Same as 381.0065(4)(e)1., F.S.
62-6.005(4)(a), F.A.C. - Inadequate unobstructed area available

RECOMMENDATIONS: Variance Committee: P (SHO-N CHD-Y DEP-Y STI-2 HBI-1 REI-Y ENG-) Health Officer: P

Approved subject to the following conditions:

The onsite sewage treatment and disposal system shall include an NSF 245 aerobic treatment unit.

The onsite sewage treatment and disposal system shall be set back from the adjacent property's private drinking water well by the maximum distance attainable but not less than 58 feet when installed.

**14632 Marion Worth Construction & Worth, Agent
Remodeling, Inc., Applicant**

STATUTE/RULE CITATION:

381.0065(4)(a), F.S. - Lot is not 1/2 acre and 100 ft wide (0.26 ac, 90 ft requested, 0.5 ac, 100 ft required)

RECOMMENDATIONS: Variance Committee: P (SHO-2 CHD-Y DEP-1 STI-N HBI-N REI-N ENG-) Health Officer: P

Approved subject to the following conditions:

The onsite sewage treatment and disposal system shall include either an in-ground nitrogen reducing biofilter (INRB), an NSF 245 aerobic treatment unit, or a nitrogen-reducing performance-based treatment system designed to meet a 50% reduction in nitrogen before discharge to the drainfield.

*IMPORTANT NOTE: An INRB may not be able to be installed due to site restrictions.

This variance applies only to the lot size requirements of section 381.0065(4)(a), F.S. The structure shall comply with the authorized sewage flow provisions of section 381.0065(4)(a), F.S.

The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

14633 Marion CEO Capital, LLC, Applicant Bakan Homes, LLC, Agent

STATUTE/RULE CITATION:

381.0065(4)(a), F.S. - Lot is not 1/2 acre and 100 ft wide (0.23 ac, 80 ft requested, 0.5 ac, 100 ft required)

RECOMMENDATIONS: Variance Committee: P (SHO-Y CHD-Y DEP-Y STI-2 HBI-1 REI-Y ENG-) Health Officer: P

Approved subject to the following conditions:

This variance applies only to the lot size requirements of section 381.0065(4)(a), F.S. The structure shall comply with the authorized sewage flow provisions of section 381.0065(4)(a), F.S.

The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

**14634 Marion Maronda Homes LLC of Florida, Friedman, Agent
Applicant**

STATUTE/RULE CITATION:

381.0065(4)(a), F.S. - Lot is not 1/2 acre and 100 ft wide (0.26 ac, 90 ft requested, 0.5 ac, 100 ft required)

RECOMMENDATIONS: Variance Committee: P (SHO-Y CHD-Y DEP-Y STI-2 HBI-1 REI-Y ENG-) Health Officer: P

Approved subject to the following conditions:

This variance applies only to the lot size requirements of section 381.0065(4)(a), F.S. The structure shall comply with the authorized sewage flow provisions of section 381.0065(4)(a), F.S.

The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

14635 Marion DRC 24, LLC, Applicant Salvador, Agent

STATUTE/RULE CITATION:

381.0065(4)(a), F.S. - Lot is not 1/2 acre and 100 ft wide (0.23 ac, 80 ft requested, 0.5 ac, 100 ft required)

RECOMMENDATIONS: Variance Committee: P (SHO-Y CHD-Y DEP-Y STI-2 HBI-1 REI-Y ENG-) Health Officer: P

Approved subject to the following conditions:

This variance applies only to the lot size requirements of section 381.0065(4)(a), F.S. The structure shall comply with the authorized sewage flow provisions of section 381.0065(4)(a), F.S.
The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

14636 Marion Baxton Homes, LLC, Applicant Buescher, Agent

STATUTE/RULE CITATION:

381.0065(4)(a), F.S. - Lot is not 1/2 acre (0.29 acre requested, 0.5 acre required)

RECOMMENDATIONS: Variance Committee: P (SHO-Y CHD-Y DEP-Y STI-2 HBI-1 REI-Y ENG-) Health Officer: P

Approved subject to the following conditions:

This variance applies only to the lot size requirements of section 381.0065(4)(a), F.S. The structure shall comply with the authorized sewage flow provisions of section 381.0065(4)(a), F.S.
The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

**14637 Marion Perfect Deed Homes LLC, Steiner, Agent
Applicant**

STATUTE/RULE CITATION:

381.0065(4)(a), F.S. - Lot is not 1/2 acre (0.3 acre requested, 0.5 acre required)

RECOMMENDATIONS: Variance Committee: P (SHO-Y CHD-Y DEP-Y STI-2 HBI-1 REI-Y ENG-) Health Officer: P

Approved subject to the following conditions:

This variance applies only to the lot size requirements of section 381.0065(4)(a), F.S. The structure shall comply with the authorized sewage flow provisions of section 381.0065(4)(a), F.S.
The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

**14638 Marion Marty & Huggins Development, Bakan Homes, LLC, Agent
LLC, Applicant**

STATUTE/RULE CITATION:

381.0065(4)(a), F.S. - Lot is not 1/2 acre and 100 ft wide (0.48 ac, X ft requested, 0.5 ac, 100 ft required)

RECOMMENDATIONS: Variance Committee: P (SHO-Y CHD-Y DEP-Y STI-2 HBI-1 REI-Y ENG-) Health Officer: P

Approved subject to the following conditions:

This variance applies only to the lot size requirements of section 381.0065(4)(a), F.S. The structure shall comply with the authorized sewage flow provisions of section 381.0065(4)(a), F.S.
The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

**14639 Marion Amatoso Investments, LLC, Angel, Agent
Applicant**

STATUTE/RULE CITATION:

381.0065(4)(a), F.S. - Lot is not 1/2 acre (0.29 acre requested, 0.5 acre required)

RECOMMENDATIONS: Variance Committee: P (SHO-Y CHD-Y DEP-Y STI-2 HBI-1 REI-Y ENG-) Health Officer: P

Approved subject to the following conditions:

This variance applies only to the lot size requirements of section 381.0065(4)(a), F.S. The structure shall comply with the authorized sewage flow provisions of section 381.0065(4)(a), F.S.
The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

14640 Marion Lennar Homes, LLC, Applicant Eggimann, Agent

STATUTE/RULE CITATION:

381.0065(4)(a), F.S. - Lot is not 1/2 acre and 100 ft wide (0.34 ac, X ft requested, 0.5 ac, 100 ft required)

RECOMMENDATIONS: Variance Committee: P (SHO-Y CHD-Y DEP-Y STI-2 HBI-1 REI-Y ENG-) Health Officer: P

Approved subject to the following conditions:

This variance applies only to the lot size requirements of section 381.0065(4)(a), F.S. The structure shall comply with the authorized sewage flow provisions of section 381.0065(4)(a), F.S.
The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

14641 Marion CEO Capital, LLC, Applicant Bakan Homes, LLC, Agent

STATUTE/RULE CITATION:

381.0065(4)(a), F.S. - Lot is not 1/2 acre and 100 ft wide (0.23 ac, 80 ft requested, 0.5 ac, 100 ft required)

RECOMMENDATIONS: Variance Committee: P (SHO-Y CHD-Y DEP-Y STI-2 HBI-1 REI-Y ENG-) Health Officer: P

Approved subject to the following conditions:

This variance applies only to the lot size requirements of section 381.0065(4)(a), F.S. The structure shall comply with the authorized sewage flow provisions of section 381.0065(4)(a), F.S.
The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

14642 Marion CASA 21 LLC, Applicant Fitzpatrick, Agent

STATUTE/RULE CITATION:

381.0065(4)(a), F.S. - Lot is not 1/2 acre and 100 ft wide (0.23 ac, 80 ft requested, 0.5 ac, 100 ft required)

RECOMMENDATIONS: Variance Committee: P (SHO-2 CHD-Y DEP-1 STI-N HBI-N REI-N ENG-) Health Officer: P

Approved subject to the following conditions:

The onsite sewage treatment and disposal system shall include either an in-ground nitrogen reducing biofilter (INRB), an NSF 245 aerobic treatment unit, or a nitrogen-reducing performance-based treatment system designed to meet a 50% reduction in nitrogen before discharge to the drainfield.

*IMPORTANT NOTE: An INRB may not be able to be installed due to site restrictions.

This variance applies only to the lot size requirements of section 381.0065(4)(a), F.S. The structure shall comply with the authorized sewage flow provisions of section 381.0065(4)(a), F.S.
The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

14643 Marion Elite Building Inc., Applicant Rose Marie's Permit Service LLC, Agent

STATUTE/RULE CITATION:

381.0065(4)(a), F.S. - Lot is not 1/2 acre and 100 ft wide (0.23 ac, 80 ft requested, 0.5 ac, 100 ft required)

RECOMMENDATIONS: Variance Committee: P (SHO-2 CHD-Y DEP-1 STI-N HBI-N REI-N ENG-) Health Officer: P

Approved subject to the following conditions:

The onsite sewage treatment and disposal system shall include either an in-ground nitrogen reducing biofilter (INRB), an NSF 245 aerobic treatment unit, or a nitrogen-reducing performance-based treatment system designed to meet a 50% reduction in nitrogen before discharge to the drainfield.

*IMPORTANT NOTE: An INRB may not be able to be installed due to site restrictions.

This variance applies only to the lot size requirements of section 381.0065(4)(a), F.S. The structure shall comply with the authorized sewage flow provisions of section 381.0065(4)(a), F.S.

The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

14644 Marion Elite Building Inc., Applicant Rose Marie's Permit Service LLC, Agent

STATUTE/RULE CITATION:

381.0065(4)(a), F.S. - Lot is not 1/2 acre and 100 ft wide (0.26 ac, X ft requested, 0.5 ac, 100 ft required)

RECOMMENDATIONS: Variance Committee: P (SHO-2 CHD-Y DEP-1 STI-N HBI-N REI-N ENG-) Health Officer: P

Approved subject to the following conditions:

The onsite sewage treatment and disposal system shall include either an in-ground nitrogen reducing biofilter (INRB), an NSF 245 aerobic treatment unit, or a nitrogen-reducing performance-based treatment system designed to meet a 50% reduction in nitrogen before discharge to the drainfield.

*IMPORTANT NOTE: An INRB may not be able to be installed due to site restrictions.

This variance applies only to the lot size requirements of section 381.0065(4)(a), F.S. The structure shall comply with the authorized sewage flow provisions of section 381.0065(4)(a), F.S.

The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

14645 Marion C&D Express Development, Mullins, Agent Applicant

STATUTE/RULE CITATION:

381.0065(4)(a), F.S. - Lot is not 1/2 acre and 100 ft wide (0.27 ac, X ft requested, 0.5 ac, 100 ft required)

RECOMMENDATIONS: Variance Committee: P (SHO-2 CHD-Y DEP-1 STI-N HBI-N REI-N ENG-) Health Officer: P

Approved subject to the following conditions:

The onsite sewage treatment and disposal system shall include either an in-ground nitrogen reducing biofilter (INRB), an NSF 245 aerobic treatment unit, or a nitrogen-reducing performance-based treatment system designed to meet a 50% reduction in nitrogen before discharge to the drainfield.

*IMPORTANT NOTE: An INRB may not be able to be installed due to site restrictions.

This variance applies only to the lot size requirements of section 381.0065(4)(a), F.S. The structure shall comply with the authorized sewage flow provisions of section 381.0065(4)(a), F.S.

The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

14646 Marion Worth Construction & Remodeling, Inc., Applicant Worth, Agent

STATUTE/RULE CITATION:
381.0065(4)(a), F.S. - Lot is not 1/2 acre and 100 ft wide (0.25 ac, 88 ft requested, 0.5 ac, 100 ft required)

RECOMMENDATIONS: Variance Committee: P (SHO-2 CHD-Y DEP-1 STI-N HBI-N REI-N ENG-) Health Officer: P

Approved subject to the following conditions:
The onsite sewage treatment and disposal system shall include either an in-ground nitrogen reducing biofilter (INRB), an NSF 245 aerobic treatment unit, or a nitrogen-reducing performance-based treatment system designed to meet a 50% reduction in nitrogen before discharge to the drainfield.
*IMPORTANT NOTE: An INRB may not be able to be installed due to site restrictions.
This variance applies only to the lot size requirements of section 381.0065(4)(a), F.S. The structure shall comply with the authorized sewage flow provisions of section 381.0065(4)(a), F.S.
The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

14647 Marion BRIJE, LLC, Applicant Wandersleben, Agent Modified

STATUTE/RULE CITATION:
381.0065(4)(a), F.S. - Lot is not 1/2 acre and 100 ft wide (0.26 ac, 88 ft requested, 0.5 ac, 100 ft required)

RECOMMENDATIONS: Variance Committee: P (SHO-N CHD-N DEP-N STI-Y HBI-1 REI-2 ENG-Y) Health Officer: P

Approved subject to the following conditions:
The onsite sewage treatment and disposal system shall include either an in-ground nitrogen reducing biofilter (INRB), an NSF 245 aerobic treatment unit, or a nitrogen-reducing performance-based treatment system designed to meet a 50% reduction in nitrogen before discharge to the drainfield.
*IMPORTANT NOTE: An INRB may not be able to be installed due to site restrictions.
This variance applies only to the lot size requirements of section 381.0065(4)(a), F.S. The structure shall comply with the authorized sewage flow provisions of section 381.0065(4)(a), F.S.
The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

14648 Marion Jason Rector Construction, Applicant Mullins, Agent

STATUTE/RULE CITATION:
381.0065(4)(a), F.S. - Lot is not 1/2 acre and 100 ft wide (0.25 ac, 90 ft requested, 0.5 ac, 100 ft required)

RECOMMENDATIONS: Variance Committee: P (SHO-2 CHD-Y DEP-1 STI-N HBI-N REI-N ENG-) Health Officer: P

Approved subject to the following conditions:
The onsite sewage treatment and disposal system shall include either an in-ground nitrogen reducing biofilter (INRB), an NSF 245 aerobic treatment unit, or a nitrogen-reducing performance-based treatment system designed to meet a 50% reduction in nitrogen before discharge to the drainfield.
*IMPORTANT NOTE: An INRB may not be able to be installed due to site restrictions.
This variance applies only to the lot size requirements of section 381.0065(4)(a), F.S. The structure shall comply with the authorized sewage flow provisions of section 381.0065(4)(a), F.S.
The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

14649 Marion BRIJE, LLC, Applicant Wandersleben, Agent
STATUTE/RULE CITATION:
381.0065(4)(a), F.S. - Lot is not 1/2 acre and 100 ft wide (0.25 ac, 90 ft requested, 0.5 ac, 100 ft required)
RECOMMENDATIONS: Variance Committee: P (SHO-2 CHD-Y DEP-1 STI-N HBI-N REI-N ENG-) Health Officer: P
Approved subject to the following conditions:
The onsite sewage treatment and disposal system shall include either an in-ground nitrogen reducing biofilter (INRB), an NSF 245 aerobic treatment unit, or a nitrogen-reducing performance-based treatment system designed to meet a 50% reduction in nitrogen before discharge to the drainfield.
*IMPORTANT NOTE: An INRB may not be able to be installed due to site restrictions.
This variance applies only to the lot size requirements of section 381.0065(4)(a), F.S. The structure shall comply with the authorized sewage flow provisions of section 381.0065(4)(a), F.S.
The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

14650 Duval Nugent, Applicant
STATUTE/RULE CITATION:
381.0065(4)(a), F.S. - Lot is not 1/2 acre and 100 ft wide (0.25 ac, 62 ft requested, 0.5 ac, 100 ft required)
RECOMMENDATIONS: Variance Committee: D (SHO-2 CHD-Y DEP-Y STI-N HBI-N REI-N ENG-1) Health Officer: D
Failure to satisfy the department that:
Any perceived hardship that you might experience because of the obligation to meet established standards comes about as a direct result of your own action.
Each of the above facts and conclusions, standing alone, is sufficient grounds for denial of your variance request.
The variance proposal would create a likelihood that the onsite system discharge may adversely affect the health of the applicant or the public and may significantly degrade the groundwater.

14651 Lake MC Rorie, Applicant Prime Plumbing, Agent
STATUTE/RULE CITATION:
62-6.015, Table V, F.A.C. - Setback to irrigation well (32 ft requested, 50 ft required)
RECOMMENDATIONS: Variance Committee: A (SHO-N CHD-N DEP-Y STI-2 HBI-1 REI-Y ENG-) Health Officer: A
Approved

14652 Volusia AE Point Inc., Applicant John C. Cascio Septic Service Inc., Agent Modified
STATUTE/RULE CITATION:
381.0065(4)(e)1., F.S. - Setback to private potable well (72/57 ft requested, 75 ft required)
62-6.005(1)(a), F.A.C. - Same as 381.0065(4)(e)1., F.S.
62-6.005(2), F.A.C. - Setback to property line (4 ft requested, 5 ft required)
62-6.005(4)(a), F.A.C. - Inadequate unobstructed area available
RECOMMENDATIONS: Variance Committee: P (SHO-N CHD-N DEP-N STI-1 HBI-2 REI-Y ENG-) Health Officer: P
Approved subject to the following conditions:
The onsite sewage treatment and disposal system shall include an NSF 245 aerobic treatment unit.
The onsite sewage treatment and disposal system shall be set back from the adjacent properties private drinking water wells by the maximum distance attainable but not less than proposed in the application (57' and 71').
The drainfield may be able to be installed longer and narrower to maximize the setbacks.
DEP Secretary: require an NSF 245 aerobic unit instead of conventional system.

14653 **Volusia** **Taylor, Applicant** **John C. Cascio Septic Service Inc., Agent** **Modified**

STATUTE/RULE CITATION:

62-6.015, Table V, F.A.C. - Setback to irrigation well (8 ft requested, 25 ft required)

RECOMMENDATIONS: **Variance Committee: P (SHO-2 CHD-Y DEP-Y STI-N HBI-1 REI-N ENG-) Health Officer: P**

Approved subject to the following conditions:

The onsite sewage treatment and disposal system drainfield shall be set back from the adjacent property's irrigation well by the maximum distance attainable but not less than 15 feet when installed.

DEP Secretary: conventional system rather than ATU recommended by committee.

14655 **Bay** **Bracho, Applicant** **Wilson, Agent** **Modified**

STATUTE/RULE CITATION:

381.0065(4)(e)7., F.S. - Setback to non-tidal surface water body (50 ft requested, 75 ft required)

62-6.005(3), F.A.C. - Same as 381.0065(4)(e)7., F.S.

62-6.005(2), F.A.C. - Setback to property line/building foundation (2 ft requested, 5 ft required)

62-6.005(4)(a), F.A.C. - Inadequate unobstructed area available

62-6, Table III, F.A.C. - Inadequate drainfield size (250 sf requested, 375 sf required)

RECOMMENDATIONS: **Variance Committee: P (SHO-N CHD-N DEP-Y STI-2 HBI-1 REI-Y ENG-) Health Officer: P**

Approved subject to the following conditions:

The onsite sewage treatment and disposal system shall be set back from the surface water by the maximum distance attainable but not less than 50 feet when installed.

The onsite sewage treatment and disposal system drainfield shall have at least 250 square feet of absorption area.

DEP Secretary: allowed reduction in drainfield size to meet requirement. Contractor will install as much drainfield possible.

14656 **Collier** **Deonarine, Applicant** **Reliable Drainfield Design LLC, Agent**

STATUTE/RULE CITATION:

381.0065(4)(e)8., F.S. - Setback to swale or normally dry retention area (6 feet requested, 15 feet required)

62-6.005(1)(f), F.A.C. - Same as 381.0065(4)(e)8., F.S.

381.0065(4)(e)2., F.S. - Setback to a public well producing >2000 gpd (129 ft requested, 200 ft required)

62-6.005(1)(c), F.A.C. - Same as 381.0065(4)(e)2., F.S.

62-6.005(4)(a), F.A.C. - Inadequate unobstructed area available

RECOMMENDATIONS: **Variance Committee: T (SHO-1 CHD-Y DEP-Y STI-2 HBI-Y REI-Y ENG-) Health Officer: T**

Tabled and asked to provide the following information

Alternative onsite sewage treatment and disposal system designs to maximize the setback to the public drinking water well.

14657 **Duval** **Crossbow Cattle, Inc., Applicant** **Roman, Agent**

STATUTE/RULE CITATION:

62-6, Table I, F.A.C. - Instead of Table I, Size on (150 gpd requested, 1500 gpd required)

RECOMMENDATIONS: **Variance Committee: P (SHO-N CHD-N DEP-Y STI-1 HBI-2 REI-Y ENG-N) Health Officer: P**

Approved subject to the following conditions:

The onsite sewage treatment and disposal system design shall be based on an anticipated sewage flow of no less than 300 gallons per day.