

14561 Volusia Hunt, Applicant Woody's Septic Tank Service, Agent

STATUTE/RULE CITATION:
62-6.015, Table V, FAC - Setback to irrigation well (16'-tank/25'-df requested, 25 ft required)

RECOMMENDATIONS: Variance Committee: P (SHO-N CHD-Y DEP-2 STI-1 HBI-Y REI-Y ENG-Y) Health Officer: P
Approved subject to the following conditions:
The onsite sewage treatment and disposal system drainfield shall be set back from the irrigation well by the maximum distance attainable but not less than 25 feet when installed.

14562 Volusia Maronda Homes, LLC, Applicant Franz, Agent

STATUTE/RULE CITATION:
381.0065(4)(e)1., FS - Setback to private potable well (56/63 ft requested, 75 ft required)
62-6.005(1)(a), FAC - Same as 381.0065(4)(e)1., FS
62-6.005(2), FAC - Setback to property line (3 ft requested, 5 ft required)
62-6.005(4)(a), FAC - Inadequate unobstructed area available

RECOMMENDATIONS: Variance Committee: P (SHO-N CHD-N DEP-Y STI-Y HBI-2 REI-1 ENG-Y) Health Officer: P
Approved subject to the following conditions:
The onsite sewage treatment and disposal system shall include an NSF 245 aerobic treatment unit with drip irrigation.
The onsite sewage treatment and disposal system shall be set back from the private drinking water wells the maximum distance attainable but not less than proposed in the application (56' and 63').

14563 Marion DRC 24, LLC, Applicant Salvador, Agent

STATUTE/RULE CITATION:
381.0065(4)(a), FS - Lot is not 1/2 acre (0.45 acre requested, 0.5 acre required)

RECOMMENDATIONS: Variance Committee: P (SHO-Y CHD-N DEP-N STI-1 HBI-2 REI-Y ENG-Y) Health Officer: P
Approved subject to the following conditions:
This variance applies only to the lot size requirements of section 381.0065(4)(a), F.S. The structure shall comply with the authorized sewage flow provisions of section 381.0065(4)(a), F.S.
The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

14564 Marion DRC 24, LLC, Applicant Salvador, Agent

STATUTE/RULE CITATION:
381.0065(4)(a), FS - Lot is not 1/2 acre (0.29 acre requested, 0.5 acre required)

RECOMMENDATIONS: Variance Committee: P (SHO-N CHD-Y DEP-Y STI-1 HBI-Y REI-2 ENG-N) Health Officer: P
Approved subject to the following conditions:
This variance applies only to the lot size requirements of section 381.0065(4)(a), F.S. The structure shall comply with the authorized sewage flow provisions of section 381.0065(4)(a), F.S.
The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

14565 Marion Belac Homes, Applicant Smallwood, Agent

STATUTE/RULE CITATION:

381.0065(4)(a), FS - Lot is not 1/2 acre and 100 ft wide (0.23 ac, 80 ft requested, 0.5 ac, 100 ft required)

RECOMMENDATIONS: Variance Committee: P (SHO-N CHD-Y DEP-Y STI-1 HBI-Y REI-2 ENG-N) Health Officer: P

Approved subject to the following conditions:

This variance applies only to the lot size requirements of section 381.0065(4)(a), F.S. The structure shall comply with the authorized sewage flow provisions of section 381.0065(4)(a), F.S.
The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

14566 Marion Aldana Contracting, LLC, Applicant

STATUTE/RULE CITATION:

381.0065(4)(a), FS - Lot is not 1/2 acre and 100 ft wide (0.31 ac, 82 ft requested, 0.5 ac, 100 ft required)

RECOMMENDATIONS: Variance Committee: P (SHO-N CHD-Y DEP-Y STI-1 HBI-Y REI-2 ENG-N) Health Officer: P

Approved subject to the following conditions:

This variance applies only to the lot size requirements of section 381.0065(4)(a), F.S. The structure shall comply with the authorized sewage flow provisions of section 381.0065(4)(a), F.S.
The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

14567 Marion Aldana Contracting, LLC, Applicant

STATUTE/RULE CITATION:

381.0065(4)(a), FS - Lot is not 1/2 acre (0.28 acre requested, 0.5 acre required)

RECOMMENDATIONS: Variance Committee: P (SHO-N CHD-Y DEP-Y STI-1 HBI-Y REI-2 ENG-N) Health Officer: P

Approved subject to the following conditions:

This variance applies only to the lot size requirements of section 381.0065(4)(a), F.S. The structure shall comply with the authorized sewage flow provisions of section 381.0065(4)(a), F.S.
The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

14568 Marion Aldana Contracting, LLC, Applicant

STATUTE/RULE CITATION:

381.0065(4)(a), FS - Lot is not 1/2 acre (0.39 acre requested, 0.5 acre required)

RECOMMENDATIONS: Variance Committee: P (SHO-N CHD-Y DEP-Y STI-1 HBI-Y REI-2 ENG-N) Health Officer: P

Approved subject to the following conditions:

This variance applies only to the lot size requirements of section 381.0065(4)(a), F.S. The structure shall comply with the authorized sewage flow provisions of section 381.0065(4)(a), F.S.
The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

14569 Marion Patrick Holdings, LLC, Applicant Rogers, Agent

STATUTE/RULE CITATION:

381.0065(4)(a), FS - Lot is not 1/2 acre and 100 ft wide (0.28 ac, 85 ft requested, 0.5 ac, 100 ft required)

RECOMMENDATIONS: Variance Committee: P (SHO-2 CHD-Y DEP-1 STI-N HBI-N REI-N ENG-Y) Health Officer: P

Approved subject to the following conditions:

The onsite sewage treatment and disposal system shall include either an in-ground nitrogen reducing biofilter (INRB), an NSF 245 aerobic treatment unit, or a nitrogen-reducing performance-based treatment system designed to meet a 50% reduction in nitrogen before discharge to the drainfield.

*IMPORTANT NOTE: An INRB may not be able to be installed due to site restrictions.

This variance applies only to the lot size requirements of section 381.0065(4)(a), F.S. The structure shall comply with the authorized sewage flow provisions of section 381.0065(4)(a), F.S. The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

14570 Marion Aldana Contracting, LLC, Applicant

STATUTE/RULE CITATION:

381.0065(4)(a), FS - Lot is not 1/2 acre and 100 ft wide (0.24 ac, 85 ft requested, 0.5 ac, 100 ft required)

RECOMMENDATIONS: Variance Committee: P (SHO-N CHD-Y DEP-Y STI-1 HBI-Y REI-2 ENG-N) Health Officer: P

Approved subject to the following conditions:

This variance applies only to the lot size requirements of section 381.0065(4)(a), F.S. The structure shall comply with the authorized sewage flow provisions of section 381.0065(4)(a), F.S. The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

14571 Marion Jen Homes, LLC, Applicant

STATUTE/RULE CITATION:

381.0065(4)(a), FS - Lot is not 1/2 acre and 100 ft wide (0.23 ac, 80 ft requested, 0.5 ac, 100 ft required)

RECOMMENDATIONS: Variance Committee: P (SHO-2 CHD-Y DEP-1 STI-N HBI-N REI-N ENG-Y) Health Officer: P

Approved subject to the following conditions:

The onsite sewage treatment and disposal system shall include either an in-ground nitrogen reducing biofilter (INRB), an NSF 245 aerobic treatment unit, or a nitrogen-reducing performance-based treatment system designed to meet a 50% reduction in nitrogen before discharge to the drainfield.

*IMPORTANT NOTE: An INRB may not be able to be installed due to site restrictions.

This variance applies only to the lot size requirements of section 381.0065(4)(a), F.S. The structure shall comply with the authorized sewage flow provisions of section 381.0065(4)(a), F.S. The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

14572 Marion Jen Homes, LLC, Applicant

STATUTE/RULE CITATION:

381.0065(4)(a), FS - Lot is not 1/2 acre (0.28 acre requested, 0.5 acre required)

RECOMMENDATIONS: Variance Committee: P (SHO-N CHD-Y DEP-Y STI-1 HBI-Y REI-2 ENG-N) Health Officer: P

Approved subject to the following conditions:

This variance applies only to the lot size requirements of section 381.0065(4)(a), F.S. The structure shall comply with the authorized sewage flow provisions of section 381.0065(4)(a), F.S. The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

14573 Marion Jen Homes, LLC, Applicant

STATUTE/RULE CITATION:

381.0065(4)(a), FS - Lot is not 1/2 acre and 100 ft wide (0.26 ac, 90 ft requested, 0.5 ac, 100 ft required)

RECOMMENDATIONS: Variance Committee: P (SHO-2 CHD-Y DEP-1 STI-N HBI-N REI-N ENG-Y) Health Officer: P

Approved subject to the following conditions:

The onsite sewage treatment and disposal system shall include either an in-ground nitrogen reducing biofilter (INRB), an NSF 245 aerobic treatment unit, or a nitrogen-reducing performance-based treatment system designed to meet a 50% reduction in nitrogen before discharge to the drainfield.

*IMPORTANT NOTE: An INRB may not be able to be installed due to site restrictions.

This variance applies only to the lot size requirements of section 381.0065(4)(a), F.S. The structure shall comply with the authorized sewage flow provisions of section 381.0065(4)(a), F.S. The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

14574 Marion Patrick Holdings, LLC, Applicant Rogers, Agent

STATUTE/RULE CITATION:

381.0065(4)(a), FS - Lot is not 1/2 acre and 100 ft wide (0.23 ac, 80 ft requested, 0.5 ac, 100 ft required)

RECOMMENDATIONS: Variance Committee: P (SHO-2 CHD-Y DEP-1 STI-N HBI-N REI-N ENG-Y) Health Officer: P

Approved subject to the following conditions:

The onsite sewage treatment and disposal system shall include either an in-ground nitrogen reducing biofilter (INRB), an NSF 245 aerobic treatment unit, or a nitrogen-reducing performance-based treatment system designed to meet a 50% reduction in nitrogen before discharge to the drainfield.

*IMPORTANT NOTE: An INRB may not be able to be installed due to site restrictions.

This variance applies only to the lot size requirements of section 381.0065(4)(a), F.S. The structure shall comply with the authorized sewage flow provisions of section 381.0065(4)(a), F.S. The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

14575 Marion Patrick Holdings, LLC, Applicant Rogers, Agent

STATUTE/RULE CITATION:

381.0065(4)(a), FS - Lot is not 1/2 acre and 100 ft wide (0.24 ac, 82 ft requested, 0.5 ac, 100 ft required)

RECOMMENDATIONS: Variance Committee: P (SHO-2 CHD-Y DEP-1 STI-N HBI-N REI-N ENG-Y) Health Officer: P

Approved subject to the following conditions:

The onsite sewage treatment and disposal system shall include either an in-ground nitrogen reducing biofilter (INRB), an NSF 245 aerobic treatment unit, or a nitrogen-reducing performance-based treatment system designed to meet a 50% reduction in nitrogen before discharge to the drainfield.

*IMPORTANT NOTE: An INRB may not be able to be installed due to site restrictions.

This variance applies only to the lot size requirements of section 381.0065(4)(a), F.S. The structure shall comply with the authorized sewage flow provisions of section 381.0065(4)(a), F.S. The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

14576 Marion Patrick Holdings, LLC, Applicant Rogers, Agent

STATUTE/RULE CITATION:

381.0065(4)(a), FS - Lot is not 1/2 acre and 100 ft wide (0.24 ac, 80 ft requested, 0.5 ac, 100 ft required)

RECOMMENDATIONS: Variance Committee: P (SHO-2 CHD-Y DEP-1 STI-N HBI-N REI-N ENG-Y) Health Officer: P

Approved subject to the following conditions:

The onsite sewage treatment and disposal system shall include either an in-ground nitrogen reducing biofilter (INRB), an NSF 245 aerobic treatment unit, or a nitrogen-reducing performance-based treatment system designed to meet a 50% reduction in nitrogen before discharge to the drainfield.

*IMPORTANT NOTE: An INRB may not be able to be installed due to site restrictions.

This variance applies only to the lot size requirements of section 381.0065(4)(a), F.S. The structure shall comply with the authorized sewage flow provisions of section 381.0065(4)(a), F.S. The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

14577 Marion Patrick Holdings, LLC, Applicant Rogers, Agent

STATUTE/RULE CITATION:

381.0065(4)(a), FS - Lot is not 1/2 acre and 100 ft wide (0.23 ac, 80 ft requested, 0.5 ac, 100 ft required)

RECOMMENDATIONS: Variance Committee: P (SHO-2 CHD-Y DEP-1 STI-N HBI-N REI-N ENG-Y) Health Officer: P

Approved subject to the following conditions:

The onsite sewage treatment and disposal system shall include either an in-ground nitrogen reducing biofilter (INRB), an NSF 245 aerobic treatment unit, or a nitrogen-reducing performance-based treatment system designed to meet a 50% reduction in nitrogen before discharge to the drainfield.

*IMPORTANT NOTE: An INRB may not be able to be installed due to site restrictions.

This variance applies only to the lot size requirements of section 381.0065(4)(a), F.S. The structure shall comply with the authorized sewage flow provisions of section 381.0065(4)(a), F.S. The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

14578 Marion Patrick Holdings, LLC, Applicant Rogers, Agent

STATUTE/RULE CITATION:

381.0065(4)(a), FS - Lot is not 1/2 acre and 100 ft wide (0.26 ac, 88 ft requested, 0.5 ac, 100 ft required)

RECOMMENDATIONS: Variance Committee: P (SHO-2 CHD-Y DEP-1 STI-N HBI-N REI-N ENG-Y) Health Officer: P

Approved subject to the following conditions:

The onsite sewage treatment and disposal system shall include either an in-ground nitrogen reducing biofilter (INRB), an NSF 245 aerobic treatment unit, or a nitrogen-reducing performance-based treatment system designed to meet a 50% reduction in nitrogen before discharge to the drainfield.

*IMPORTANT NOTE: An INRB may not be able to be installed due to site restrictions.

This variance applies only to the lot size requirements of section 381.0065(4)(a), F.S. The structure shall comply with the authorized sewage flow provisions of section 381.0065(4)(a), F.S. The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

14579 Marion Patrick Holdings, LLC, Applicant Rogers, Agent

STATUTE/RULE CITATION:

381.0065(4)(a), FS - Lot is not 1/2 acre and 100 ft wide (0.24 ac, 85 ft requested, 0.5 ac, 100 ft required)

RECOMMENDATIONS: Variance Committee: P (SHO-2 CHD-Y DEP-1 STI-N HBI-N REI-N ENG-Y) Health Officer: P

Approved subject to the following conditions:

The onsite sewage treatment and disposal system shall include either an in-ground nitrogen reducing biofilter (INRB), an NSF 245 aerobic treatment unit, or a nitrogen-reducing performance-based treatment system designed to meet a 50% reduction in nitrogen before discharge to the drainfield.

*IMPORTANT NOTE: An INRB may not be able to be installed due to site restrictions.

This variance applies only to the lot size requirements of section 381.0065(4)(a), F.S. The structure shall comply with the authorized sewage flow provisions of section 381.0065(4)(a), F.S. The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

14580 Marion The Emerald Group LLC, Applicant Marion Pumpers Inc., Agent

STATUTE/RULE CITATION:

381.0065(4)(a), FS - Lot is not 1/2 acre and 100 ft wide (0.23 ac, 80 ft requested, 0.5 ac, 100 ft required)

RECOMMENDATIONS: Variance Committee: P (SHO-N CHD-Y DEP-Y STI-1 HBI-Y REI-2 ENG-N) Health Officer: P

Approved subject to the following conditions:

This variance applies only to the lot size requirements of section 381.0065(4)(a), F.S. The structure shall comply with the authorized sewage flow provisions of section 381.0065(4)(a), F.S. The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

14581 Marion SBI Group, LLC, Applicant Day, Agent

STATUTE/RULE CITATION:

381.0065(4)(a), FS - Lot is not 1/2 acre (0.46 acre requested, 0.5 acre required)

RECOMMENDATIONS: Variance Committee: P (SHO-Y CHD-N DEP-N STI-1 HBI-2 REI-Y ENG-Y) Health Officer: P

Approved subject to the following conditions:

This variance applies only to the lot size requirements of section 381.0065(4)(a), F.S. The structure shall comply with the authorized sewage flow provisions of section 381.0065(4)(a), F.S.

The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

14582 Marion Binns, Applicant Ramkarran, Agent

STATUTE/RULE CITATION:

381.0065(4)(a), FS - Lot is not 1/2 acre and 100 ft wide (0.32 ac, X ft requested, 0.5 ac, 100 ft required)

RECOMMENDATIONS: Variance Committee: P (SHO-N CHD-Y DEP-Y STI-1 HBI-Y REI-2 ENG-N) Health Officer: P

Approved subject to the following conditions:

This variance applies only to the lot size requirements of section 381.0065(4)(a), F.S. The structure shall comply with the authorized sewage flow provisions of section 381.0065(4)(a), F.S.

The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

**14583 Marion Boavista Properties LLC, Terneus, Agent
Applicant**

STATUTE/RULE CITATION:

381.0065(4)(a), FS - Lot is not 1/2 acre (0.28 acre requested, 0.5 acre required)

RECOMMENDATIONS: Variance Committee: P (SHO-N CHD-Y DEP-Y STI-1 HBI-Y REI-2 ENG-N) Health Officer: P

Approved subject to the following conditions:

This variance applies only to the lot size requirements of section 381.0065(4)(a), F.S. The structure shall comply with the authorized sewage flow provisions of section 381.0065(4)(a), F.S.

The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

14584 Marion Raya, Applicant Terneus, Agent

STATUTE/RULE CITATION:

381.0065(4)(a), FS - Lot is not 1/2 acre and 100 ft wide (0.24 ac, 87 ft requested, 0.5 ac, 100 ft required)

RECOMMENDATIONS: Variance Committee: P (SHO-2 CHD-Y DEP-1 STI-N HBI-N REI-N ENG-Y) Health Officer: P

Approved subject to the following conditions:

The onsite sewage treatment and disposal system shall include either an in-ground nitrogen reducing biofilter (INRB), an NSF 245 aerobic treatment unit, or a nitrogen-reducing performance-based treatment system designed to meet a 50% reduction in nitrogen before discharge to the drainfield.

*IMPORTANT NOTE: An INRB may not be able to be installed due to site restrictions.

This variance applies only to the lot size requirements of section 381.0065(4)(a), F.S. The structure shall comply with the authorized sewage flow provisions of section 381.0065(4)(a), F.S.

The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

**14585 Lee Second Avenue SFR Holdings I L, Synergy Homes LLC, Agent
Applicant**

STATUTE/RULE CITATION:

381.0065(4)(a), FS - Lot is not 1/2 acre and 100 ft wide (0.26 ac, 90 ft requested, 0.5 ac, 100 ft required)

RECOMMENDATIONS: Variance Committee: P (SHO-Y CHD-Y DEP-2 STI-1 HBI-Y REI-Y ENG-Y) Health Officer: P

Approved subject to the following conditions:

The onsite sewage treatment and disposal system shall include either an in-ground nitrogen reducing biofilter (INRB), an NSF 245 aerobic treatment unit, or a nitrogen-reducing performance-based treatment system designed to meet a 50% reduction in nitrogen before discharge to the drainfield.

*IMPORTANT NOTE: An INRB may not be able to be installed due to site restrictions.

This variance applies only to the lot size requirements of section 381.0065(4)(a), F.S. The structure shall comply with the authorized sewage flow provisions of section 381.0065(4)(a), F.S.

The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

14586 Lee Cupola Homes 27 LLC, Applicant Synergy Homes LLC, Agent

STATUTE/RULE CITATION:

381.0065(4)(a), FS - Lot is not 1/2 acre and 100 ft wide (0.25 ac, 90 ft requested, 0.5 ac, 100 ft required)

RECOMMENDATIONS: Variance Committee: P (SHO-Y CHD-Y DEP-2 STI-1 HBI-Y REI-Y ENG-Y) Health Officer: P

Approved subject to the following conditions:

The onsite sewage treatment and disposal system shall include either an in-ground nitrogen reducing biofilter (INRB), an NSF 245 aerobic treatment unit, or a nitrogen-reducing performance-based treatment system designed to meet a 50% reduction in nitrogen before discharge to the drainfield.

*IMPORTANT NOTE: An INRB may not be able to be installed due to site restrictions.

This variance applies only to the lot size requirements of section 381.0065(4)(a), F.S. The structure shall comply with the authorized sewage flow provisions of section 381.0065(4)(a), F.S.

The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

14587 Lee MacClugage, Applicant Cay Homes Inc., Agent

STATUTE/RULE CITATION:

381.0065(4)(a), FS - Lot is not 1/2 acre and 100 ft wide (0.24 ac, 85 ft requested, 0.5 ac, 100 ft required)

RECOMMENDATIONS: Variance Committee: P (SHO-Y CHD-Y DEP-2 STI-1 HBI-Y REI-Y ENG-Y) Health Officer: P

Approved subject to the following conditions:

The onsite sewage treatment and disposal system shall include either an in-ground nitrogen reducing biofilter (INRB), an NSF 245 aerobic treatment unit, or a nitrogen-reducing performance-based treatment system designed to meet a 50% reduction in nitrogen before discharge to the drainfield.

*IMPORTANT NOTE: An INRB may not be able to be installed due to site restrictions.

This variance applies only to the lot size requirements of section 381.0065(4)(a), F.S. The structure shall comply with the authorized sewage flow provisions of section 381.0065(4)(a), F.S.

The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

14588 Lee MacClugage, Applicant Cay Homes Inc., Agent

STATUTE/RULE CITATION:

381.0065(4)(a), FS - Lot is not 1/2 acre and 100 ft wide (0.24 ac, 85 ft requested, 0.5 ac, 100 ft required)

RECOMMENDATIONS: Variance Committee: P (SHO-Y CHD-Y DEP-2 STI-1 HBI-Y REI-Y ENG-Y) Health Officer: P

Approved subject to the following conditions:

The onsite sewage treatment and disposal system shall include either an in-ground nitrogen reducing biofilter (INRB), an NSF 245 aerobic treatment unit, or a nitrogen-reducing performance-based treatment system designed to meet a 50% reduction in nitrogen before discharge to the drainfield.

*IMPORTANT NOTE: An INRB may not be able to be installed due to site restrictions.

This variance applies only to the lot size requirements of section 381.0065(4)(a), F.S. The structure shall comply with the authorized sewage flow provisions of section 381.0065(4)(a), F.S. The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

14589 Duval JWB, Applicant BGRP Engineering Group, Agent

STATUTE/RULE CITATION:

381.0065(4)(g)2., FS - Setback to surface water body (22 ft requested, 50 ft required)
64E-6.005(4)(a), FAC - Inadequate unobstructed area available

RECOMMENDATIONS: Variance Committee: O (SHO- CHD- DEP- STI- HBI- REI- ENG-) Health Officer: O

Took no action because:

You contacted this office and advised that the variance request was being withdrawn.

Presently, your variance request is not on any future agenda. Please advise this office and the Department of Health in Duval County when you wish the request to be placed on a future meeting agenda.

14590 Brevard Arturo Barcellona Custom Homes Franz, Agent LLC, Applicant

STATUTE/RULE CITATION:

381.0065(4)(e)1., FS - Setback to private potable well (52 ft requested, 75 ft required)
62-6.005(1)(a), FAC - Same as 381.0065(4)(e)1., FS
62-6.005(4)(a), FAC - Inadequate unobstructed area available

RECOMMENDATIONS: Variance Committee: P (SHO-N CHD-Y DEP-Y STI-1 HBI-Y REI-2 ENG-Y) Health Officer: P

Approved subject to the following conditions:

The onsite sewage treatment and disposal system shall include a performance-based treatment system meeting secondary treatment standards with drip irrigation.

The onsite sewage treatment and disposal system shall be set back from the adjacent private drinking water well by the maximum distance attainable but not less than 52 feet when installed.

14595 Dixie Snyder, Applicant Jones, Agent

STATUTE/RULE CITATION:

381.0065(4)(g)2., FS - Setback to surface water body (35 ft requested, 50 ft required)
62-6.005(4)(a), FAC - Inadequate unobstructed area available

RECOMMENDATIONS: Variance Committee: P (SHO-N CHD-N DEP-1 STI-2 HBI-Y REI-Y ENG-Y) Health Officer: P

Approved subject to the following conditions:

The onsite sewage treatment and disposal system shall include an NSF 245 aerobic treatment unit.

The onsite sewage treatment and disposal system shall be set back from the surface water by the maximum distance attainable but not less than 35 feet when installed.

14596 St. Johns Benedict, Applicant

STATUTE/RULE CITATION:

381.0065(4)(e)1., FS - Setback to private potable well (50 ft requested, 75 ft required)
64E-6.005(1)(a), FAC - Same as 381.0065(4)(e)1., FS
64E-6.005(4)(a), FAC - Inadequate unobstructed area available

RECOMMENDATIONS: Variance Committee: P (SHO-N CHD-N DEP-Y STI-Y HBI-Y REI-2 ENG-1) Health Officer: P

Approved subject to the following conditions:

The onsite sewage treatment and disposal system shall include an NSF 245 aerobic treatment unit with disinfection or a performance-based treatment system designed to meet advanced secondary treatment standards before discharge to the drainfield.

The onsite sewage treatment and disposal system shall be set back from the adjacent private drinking water well by the maximum distance attainable but not less than 50 feet when installed.

14597 Osceola Racetrac Petroleum Inc, Applicant JK Environmental Services, Agent

STATUTE/RULE CITATION:

381.0065(3)(b), FS - Take jurisdiction for commercial flow > 5,000 gpd (7080 gpd requested, <=5,000 gpd required)

RECOMMENDATIONS: Variance Committee: O (SHO- CHD- DEP- STI- HBI- REI- ENG-) Health Officer: O

Took no action because:

At the committee meeting, you advised that the variance request was being withdrawn to discuss the project with the Department of Health in Osceola County to determine if a variance is necessary.

Presently, your variance request is not on any future agenda. Please advise this office and the Department of Health in Osceola County when you wish the request to be placed on a future meeting agenda.

14598 Baker Spradley, Applicant Jones, Agent

STATUTE/RULE CITATION:

- 381.0065(4)(a), FS - Estimated sewage flow exceeds 1500 gpd/acre (460 gpd requested, 450 gpd required)
381.0065(4)(e)3., FS - Setback to a public well producing <=2000 gpd (75 ft requested, 100 ft required)
62-6.005(1)(b), FAC - Same as 381.0065(4)(e)3., FS
381.0065(4)(e)8., FS - Setback to swale or normally dry retention area (10 feet requested, 15 feet required)
62-6.005(1)(f), FAC - Same as 381.0065(4)(e)8., FS
62-6.015(6)(d), FAC - Inadequate drainfield size (540 sf requested, 575 sf required)

RECOMMENDATIONS: Variance Committee: P (SHO-2 CHD-Y DEP-Y STI-1 HBI-Y REI-Y ENG-Y) Health Officer: P

Approved subject to the following conditions:

- The onsite sewage treatment and disposal system shall be set back from the public drinking water well by the maximum distance attainable but not less than 75 feet when installed.
The onsite sewage treatment and disposal system shall be set back from swale by the maximum distance attainable but not less than 10 feet when installed.
The bottom surface of the drainfield shall be setback from the estimated wet season water table elevation by the maximum distance attainable but not less than six inches when installed.

14599 Bay Newsom, Applicant A-1 Septic, Agent

STATUTE/RULE CITATION:

- 381.0065(4)(a), FS - Lot is not 1/2 acre and 100 ft wide (0.48 ac, X ft requested, 0.5 ac, 100 ft required)

RECOMMENDATIONS: Variance Committee: A (SHO-Y CHD-Y DEP-2 STI-1 HBI-Y REI-Y ENG-Y) Health Officer: A

Approved

14600 Jackson Florida Foundation Seed Producers Inc., Applicant Gorman Environmental Services LLC, Agent

STATUTE/RULE CITATION:

- 381.0065(4)(i), FS - System likely to dispose of hazardous/toxic/industrial waste (Ind, tox, haz waste requested, Domestic, Commercial required)

RECOMMENDATIONS: Variance Committee: A (SHO-Y CHD-Y DEP-Y STI-1 HBI-Y REI-2 ENG-Y) Health Officer: A

Approved

14601 Dixie Rouse, Applicant Jones, Agent

STATUTE/RULE CITATION:

- 381.0065(4)(t)2., FS - Cannot add fill to property in regulatory floodway
381.0065(4)(g)2., FS - Setback to surface water body (48 ft requested, 50 ft required)
62-6.005(4)(a), FAC - Inadequate unobstructed area available

RECOMMENDATIONS: Variance Committee: P (SHO-N CHD-N DEP-Y STI-1 HBI-Y REI-Y ENG-2) Health Officer: P

Approved subject to the following conditions:

- The onsite sewage treatment and disposal system shall include an NSF 245 aerobic treatment unit. To maximize the setback to the surface water, the drainfield shall be installed in a bed configuration.
The onsite sewage treatment and disposal system shall be set back from the surface water by the maximum distance attainable but not less than 48 feet when installed.
The entire system; including shoulders, slopes, and the soil cap over the drainfield, shall be stabilized with sod.

14602 Bay GCT Capital Properties, LLC, Veteran Septic and Site
Applicant Construction, Agent

STATUTE/RULE CITATION:
381.0065(4)(b), FS - Lot density exceeds 4/acre

RECOMMENDATIONS: **Variance Committee: A (SHO-N CHD-N DEP-Y STI-1 HBI-2 REI-Y ENG-N) Health Officer: A**
Approved

14603 Marion Aldana Contracting, LLC,
Applicant

STATUTE/RULE CITATION:
381.0065(4)(a), FS - Lot is not 1/2 acre and 100 ft wide (0.23 ac, 80 ft requested, 0.5 ac, 100 ft required)

RECOMMENDATIONS: **Variance Committee: P (SHO-N CHD-Y DEP-Y STI-1 HBI-Y REI-2 ENG-N) Health Officer: P**
Approved subject to the following conditions:
This variance applies only to the lot size requirements of section 381.0065(4)(a), F.S. The structure shall comply with the authorized sewage flow provisions of section 381.0065(4)(a), F.S.
The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

14604 Marion Worldwide Alliance, LLC, Silva-Rice, Agent
Applicant

STATUTE/RULE CITATION:
381.0065(4)(a), FS - Lot is not 1/2 acre and 100 ft wide (0.23 ac, 80 ft requested, 0.5 ac, 100 ft required)

RECOMMENDATIONS: **Variance Committee: P (SHO-N CHD-Y DEP-Y STI-1 HBI-Y REI-2 ENG-N) Health Officer: P**
Approved subject to the following conditions:
This variance applies only to the lot size requirements of section 381.0065(4)(a), F.S. The structure shall comply with the authorized sewage flow provisions of section 381.0065(4)(a), F.S.
The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

14605 Marion Worldwide Alliance, LLC, Silva-Rice, Agent
Applicant

STATUTE/RULE CITATION:
381.0065(4)(a), FS - Lot is not 1/2 acre (0.33 acre requested, 0.5 acre required)

RECOMMENDATIONS: **Variance Committee: P (SHO-N CHD-Y DEP-Y STI-1 HBI-Y REI-2 ENG-N) Health Officer: P**
Approved subject to the following conditions:
This variance applies only to the lot size requirements of section 381.0065(4)(a), F.S. The structure shall comply with the authorized sewage flow provisions of section 381.0065(4)(a), F.S.
The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

14606 Marion Adams Homes of Northwest Florida, Inc., Applicant Riale, Agent

STATUTE/RULE CITATION:
381.0065(4)(a), FS - Lot is not 1/2 acre and 100 ft wide (0.23 ac, 80 ft requested, 0.5 ac, 100 ft required)

RECOMMENDATIONS: Variance Committee: P (SHO-N CHD-Y DEP-Y STI-1 HBI-Y REI-2 ENG-N) Health Officer: P
Approved subject to the following conditions:
This variance applies only to the lot size requirements of section 381.0065(4)(a), F.S. The structure shall comply with the authorized sewage flow provisions of section 381.0065(4)(a), F.S.
The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

14607 Marion Adams Homes of Northwest Florida, Inc., Applicant Riale, Agent

STATUTE/RULE CITATION:
381.0065(4)(a), FS - Lot is not 1/2 acre and 100 ft wide (0.36 ac, X ft requested, 0.5 ac, 100 ft required)

RECOMMENDATIONS: Variance Committee: P (SHO-N CHD-Y DEP-Y STI-1 HBI-Y REI-2 ENG-N) Health Officer: P
Approved subject to the following conditions:
This variance applies only to the lot size requirements of section 381.0065(4)(a), F.S. The structure shall comply with the authorized sewage flow provisions of section 381.0065(4)(a), F.S.
The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

14608 Marion Southern Impression Homes, LLC, Applicant

STATUTE/RULE CITATION:
381.0065(4)(a), FS - Lot is not 1/2 acre (0.29 acre requested, 0.5 acre required)

RECOMMENDATIONS: Variance Committee: P (SHO-N CHD-Y DEP-Y STI-1 HBI-Y REI-2 ENG-N) Health Officer: P
Approved subject to the following conditions:
This variance applies only to the lot size requirements of section 381.0065(4)(a), F.S. The structure shall comply with the authorized sewage flow provisions of section 381.0065(4)(a), F.S.
The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

14609 Marion Southern Impression Homes, LLC, Applicant

STATUTE/RULE CITATION:
381.0065(4)(a), FS - Lot is not 1/2 acre and 100 ft wide (0.35 ac, X ft requested, 0.5 ac, 100 ft required)

RECOMMENDATIONS: Variance Committee: P (SHO-N CHD-Y DEP-Y STI-1 HBI-Y REI-2 ENG-N) Health Officer: P
Approved subject to the following conditions:
This variance applies only to the lot size requirements of section 381.0065(4)(a), F.S. The structure shall comply with the authorized sewage flow provisions of section 381.0065(4)(a), F.S.
The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.