

DRAFT REPORT

Flow Projections and Liquids Processing Facilities Hydraulic Review

City Project No. 15073-121

City Task Order No. 12-06-CH2/W

Prepared for

City of St. Petersburg

November 2015



CH2M HILL Engineers, Inc.
4350 West Cypress Street
Suite 600
Tampa, FL 33607

Contents

Section	Page
List of Acronyms	0
1 Introduction	5
1.1 Background	5
1.1 Objective	5
1.2 Historical Document and Data Review	5
2 Site Observations of Liquid Processing Facilities.....	5
3 Average Flow Projections	6
3.1 Methodology.....	6
3.1.1 Data Inventory	6
3.1.2 Proposed Flow Projection Techniques	7
3.2 TAZ Population Projection	7
3.3 Findings	8
4 Peak Flow Projections.....	9
4.1 Historical Flow Data	9
4.2 Analysis	11
4.2.1 Maximum Month Average Day.....	11
4.2.2 Maximum Day.....	11
4.2.3 Peak Hour.....	11
4.2.4 Recommended Flow for Analysis.....	12
5 Process and Hydraulic Evaluations	12
5.1 Process Evaluation	12
5.1.1 Headworks	12
5.1.2 Activated Sludge	12
5.1.3 Secondary Clarification	13
5.1.4 Filtration.....	14
5.1.5 Disinfection	14
5.2 Hydraulic Evaluation	15
5.2.1 Design Capacity.....	15
5.2.2 Hydraulic Modeling of Gravity Flow	16
5.2.3 Effluent Pumping, Storage and Disposal.....	17
6 Identification of Hydraulic Limitations	21
6.1 Influent Pumping	21
6.2 Treatment Process.....	21
6.3 Gravity Flow	21
6.4 Effluent Pumping, Storage and Disposal.....	22
7 Summary and Recommendations	22
8 References.....	23

Appendix

- A SWWRF Process Flow Diagram

Tables

- 1 Wastewater Flow Projections based on Average Year Conditions
- 2 Wastewater Flow Projections based on Dry Year Conditions
- 3 Wastewater Flow Projections based on Wet Year Conditions
- 4 Historical Flow Data
- 5 Recommended Flows for SWWRF
- 6 Secondary Clarification Loading Criteria
- 7 Filtration Loading Criteria
- 8 Disinfection Criteria
- 9 Hydraulic Capacity Summary
- 10 Effluent Pumping and Disposal Analysis

Figures

- 1 Effluent Pumping Analysis
- 2 Example Diurnal Flow Curve

List of Acronyms

AADF – Annual Average Daily Flow

ASR – Aquifer Storage Recovery

AWWRF – Albert Whitted Water Reclamation Facility

FDEP – Florida Department of Environmental Protection

gpd – gallons per day

HMI – Human-machine Interface

MAIC – Maximum Available Injection Capacity

MDF – Maximum Day Flow

MMADF – Maximum Month Average Day Flow

mg – million gallon

mgd – million gallons per day

NEWRF – Northeast Water Reclamation Facility

NWWRF – Northwest Water Reclamation Facility

PHF – Peak Hour Flow

ppd – pounds per day

RAS – Return Activated Sludge

SPMRS – St. Petersburg Master Reuse System

SWWRF – Southwest Water Reclamation Facility

TAZ - Transportation Analysis Zone

UIC – Underground Injection Control

WAS – Waste Activated Sludge

WRF – Water Reclamation Facility

1 Introduction

1.1 Background

CH2M has been tasked by the City of St. Petersburg to perform a peer review of the hydraulic capacity and the emergency operations plan for each of its three wastewater treatment facilities: Southwest Water Reclamation Facility (SWWRF), Northeast Water Reclamation Facility (NEWRF), and the Northwest Water Reclamation Facility (NWWRF). As part of this project CH2M will review historical flow, review peaking factors and flow projections, identify hydraulic restrictions and emergency operations plans for peak wet-weather flow events. At the completion of this project CH2M will provide recommendations to mitigate future issues due to peak flow events such as capacity upgrades or operational procedures

1.2 Objective

The objective of this report is to evaluate the hydraulic and process capacity of three of the City of St. Petersburg's WRF: Southwest, Northwest and Northeast. The report includes a review of existing WRF conditions, a summary of flow projections for three WRFs, an identification of any hydraulic limitations and recommendations for a solution.

1.3 Historical Document and Data Review

The following data and documents were reviewed as part of the evaluation:

- Florida Department of Environmental Protection (FDEP) Facility Operating Permits for NEWRF, NWWRF, and SWWRF
- FDEP Injection Well Operating Permits for NEWRF, NWWRF, and SWWRF
- WRF Daily Flow and Rainfall data 2000 to 2015 (Excel spreadsheets)
- Transportation Analysis Zone Data (GIS data and Excel spreadsheet)
- Pump Curves for SWWRF Collection System Pump Station 28 (Lake Maggoire), Pump Station 85 (Albert Whitted Collection Basin), SWWRF Influent Pump Stations, SWWRF In-plant Lift Stations, and SWWRF Distribution Pump Station
- Biosolids to Energy Project Preliminary Design Report Draft (Brown and Caldwell, September 2013)
- Biosolids to Energy Project Preliminary Design Report Final (Brown and Caldwell, June 2015)
- Albert Whitted Water Reclamation Facility Operation Alternatives Report (CDM, October 2010)
- Southwest Water Reclamation Facility Reclaimed Water Pump Station Modifications (CDM, January, 2014)
- Southwest Water Reclamation Facility Treatment Process and Hydraulic Evaluation (Brown and Caldwell, April 2013)
- Southwest Water Reclamation Facility Wet Weather and Liquid Process Capacity Assessment (Brown and Caldwell, July 2014)

2 Site Observations of Liquid Processing Facilities

Site visits and discussions with operations staff were conducted on August 18, 2015, September 29, 2015 and September 30, 2015, at the City of St. Petersburg's Northeast Water Reclamation Facility,

Northwest Water Reclamation Facility, and Southwest Water Reclamation Facility with a focus on the liquid processing facilities and hydraulic capacity. Each visit began with a review of the current flows, observed hydraulic capacity and any known hydraulic restrictions or limitations with the respective chief operator as well as other operators as needed. The facilities were then observed and photographed.

A review of the liquid treatment facilities at the NEWRF, NWWRF, and SWWRF indicated that a majority of the equipment is well maintained, and sufficient redundancy is available. Some treatment assets were in moderate to poor condition, but plans are in the Capital Improvement Plan and in progress to address these in the next couple of years.

After discussions with operations at each WRF, it appears that the NEWRF and NWWRF had sufficient hydraulic capacity to effectively pass and treat all peak flows and loads received during the July/August wet weather event, although the City Operations has indicated that both of these facilities were reaching their treatment limits for short periods around August 3rd, 2015. The bottleneck at each of these facilities seemed to be the filters. The SWWRF however experienced sustained peak flows above the capacity of the treatment and disposal systems. Based on the City's Operations team, the high flows stressed the filters and increased head loss upstream of the filters causing water levels in the headworks and secondary treatment facilities to rise. The increased frequency of backwashing reduces hydraulic and process capacity (only three filters are available as one is backwashed; reducing capacity by 25%) and sends more flow back to the headworks of the plant. Operations have the ability to bypass the filters, but the City's Operating Protocol dictates that filtration must be used to produce reclaimed water which impacts the disposal of the treated wastewater.

3 Average Flow Projections

This section of the report presents the methodology that was used for calculating the updated flow projections for each facility. This section also includes the data inventory and subsequent methodology adopted for the analysis of each individual facility's flow projection in detail. The section concludes with draft projections for each facility. Based on reviewing previous reports (Brown and Caldwell, 2015) and using the engineering judgement, TAZ (transportation analysis zone) data was used for population projection and flow projection analysis for this study.

TAZ data is a commonly accepted for population projections and is based on Census data. TAZ data are well suited for determining population projections and calculating flow projections because each datum covers a generally small surface area, and the service area can be accurately represented. Places such as Pasco County, FL; Detroit, MI; King County, WA; and Raleigh-Durham, NC; among others, use TAZ as the basis for population projections in the prediction of future flows.

3.1 Methodology

3.1.1 Data Inventory

The following data sources were obtained and considered in developing the projection methodology:

- Pinellas County geographical information system (GIS) data were obtained from the Pinellas County GIS website (<http://opendata.pinellas-egis.opendata.arcgis.com>).
- Population projection data based on TAZ was obtained from the County Metropolitan Planning Organization.
- Population projection for single family and work population for the County based on TAZ distribution was available at five year increments from 2010 through 2040. School enrollment data and projections were only available for 2010, 2030 and 2040.
- Historical flow and rain data for all the treatment facilities from the City.

3.1.2 Proposed Flow Projection Techniques

Flows, loadings, and operational constraints must be forecasted at least ten years forward to determine the projected capacity exceedance date. Several potential scenarios were considered to project flow over the next twenty years:

- **Linear extrapolation of the historical growth rate.** In an area of stable, consistent change, and in the absence of global limiting factors (such as finite real estate, job market, etc.), the use of linear extrapolation is valid.
- **Use of power, exponential or logarithmic growth functions.** In an ordinary system, population growth follows a distinctive S-shaped curve described by a logistics function. In this function, the population increase is approximately exponential at first, followed by a declining rate of increase and ultimately a flattening of the population when growth ceases. This is a useful approach for a situation of rapid development, but requires a great deal of data that may not be available.
- **Use of TAZ population projections.** This method develops a flow projection model based on the planned growth within discrete analysis areas known as TAZ. The TAZ is a planning-level projection typically considered during the compilation of local and regional population projections, such as those used for state-required comprehensive planning. While this method achieves a conceptual level of agreement between planning populations and wastewater flow, such plans are typically somewhat aggressive in their growth rates. This could, in turn, lead to a higher projection than actually occurs. Therefore, it is appropriate to use scaling methods to choose an appropriate “time zero” value, and propagate the TAZ based projection through the analysis period to provide a more realistic population estimate.
- The TAZ population projection, corrected as described above, is used in this report as a basis for developing flow and load projections.

3.2 TAZ Population Projection

The step by step methodology used for flow projection analysis using the TAZ population projections is described below:

1. The GIS shape file delineating the County TAZs, obtained from the Metropolitan Planning Organization is intersected with existing service area boundaries for each of the WRFs. This provides the contributing TAZs for each service area. If a particular service area is composed of multiple TAZs, an area weighted coefficient is calculated to identify the contribution of each TAZ to the service area.
2. For this analysis, TAZ population is divided into three categories: Single Family, Work Population, and School Population. Since three TAZ projections are available, a quadratic interpolation technique is incorporated to obtain the growth rate slope.
3. Vander monde matrix (quadratic interpolation technique) and its inverse are calculated to determine the slope coefficients which are further used for population projection for each year.
4. Per Capita rates of 71, 9, and 18 gallons per day per person are assumed for single family, work population, and school population, respectively, and are used for converting the total population projection to total wastewater flow projection.
5. School enrollment data was interpolated for the years that were not available.
6. 2010 data was used as base year for TAZ projection.
7. Using the TAZ coefficients previously calculated, per capita flow is determined for the respective wastewater service area. Then WRF flow projections are determined by multiplying the population projection by the per capita flow rate. Since these projections are based on interpolation techniques, it is important to compare the flow projection with a base year for calibration. The calibration to actual flow is performed via a scaling factor based on historical

trends using five year average flows for each WRF. The scaling factor is calculated individually for each WRF, and then applied to the flow projection.

8. Flow projection analysis were done for average year, wet year and dry year conditions.
9. For an average year condition, historical flows from 2010 through 2014 date was used to estimate the average flow for each facility. The resulting average flow was used to calibrate the flow projections.
10. Rainfall data analysis was done to estimate wet and dry years. To do this, daily total rainfall data collected from the rain gauges at the NEWRF, NWWRF, and SWWRF from year 2000 through 2014 were averaged. Annual totals were calculated for each calendar year based on the average daily rainfall. Of these annual totals, the five wet years were 2004, 2009, 2011, 2013, and 2014, and the five dry years were 2005, 2006, 2007, 2008, and 2010. For each facility, the average flows during the five wet years and five dry years were computed for each facility to calibrate the flow projections for wet and dry year conditions.

3.3 Findings

This section presents the draft projected plant flows for each facility. Population and flow projections for each facility was done from 2016 through 2035. Three scenarios were reviewed for flow projection analysis. The scenarios are:

1. Flow projections under average year conditions (Table 1),
2. Flow projections under dry year conditions (Table 2),
3. Flow projections under wet year conditions Table 3)

Table 1. Wastewater Flow Projections based on Average Year Conditions

NEWRF, NWWRF, and SWWRF

Year	NEWRF (mgd)	NWWRF (mgd)	SWWRF (mgd)	Total (mgd)
2016	8.15	9.86	16.52	34.53
2020	8.18	10.13	16.86	35.17
2025	8.24	10.65	17.47	36.37
2030	8.33	11.41	18.30	38.04
2035	8.43	12.39	19.35	40.16

Table 2. Wastewater Flow Projections based on Dry Year Conditions

NEWRF, NWWRF, and SWWRF

Year	NEWRF (mgd)	NWWRF (mgd)	SWWRF (mgd)	Total (mgd)
2016	8.06	9.87	15.33	33.26
2020	8.10	10.13	15.67	33.90
2025	8.16	10.66	16.29	35.11
2030	8.24	11.41	17.13	36.79
2035	8.34	12.39	18.19	38.92

Table 3. Wastewater Flow Projections based on Wet Year Conditions*NEWRF, NWWRF, and SWWRF*

Year	NEWRF (mgd)	NWWRF (mgd)	SWWRF (mgd)	Total (mgd)
2016	9.12	10.10	16.77	35.99
2020	9.18	10.37	17.12	35.67
2025	9.23	10.91	17.75	37.89
2030	9.32	11.68	18.61	39.61
2035	9.44	12.68	19.69	41.80

Based on this analysis, it is recommended that design flows for hydraulic capacity of the three WRFs remain at the permitted Annual Average Daily Flow (AADF): NEWRF 16 mgd, NWWRF 20 mgd and SWWRF 20 mgd. By the year 2035, the total AADF to all WRFs is projected to be 42 mgd (total permitted AADF capacity 56 mgd).

B&C's projected 2035 flow rates for NEWRF, NWWRF, and SWWRF as indicated in their Biosolids to Energy Program Preliminary Design Report were 11.57 mgd, 10.11 mgd, and 17.91 mgd, respectively. B&C recommended that the design flow rates for their Biosolids to Energy program be designed around the higher value of either the permitted flow rate or the 2035 projected flow rate, which is also CH2M's recommendation.

In 2012, CDM's recommendation to divert flow from AWWRF to SWWRF in their Albert Whitted Water Reclamation Facility Operation Alternatives Report (October 2010) was in part due to flow projections performed to 2030, which predicted that NEWRF, NWWRF, and SWWRF would observe 8.65 mgd, 10.03 mgd, and 16.23 mgd, respectively. The methodology for performing these flow projections were not reviewed as they were located in a previous report titled 201 Facilities Plan, CDM (April 2010); however, the projections were reasonable for the time that they were generated.

4 Peak Flow Projections

A key component of this analysis is determining the peak flows experienced at the SWWRF and what the peak flows will be in the future. In order to determine the peak flows already experienced historical flow data along with operational observations were reviewed. Multiple methods were used to project future peak flows including referenced calculations, historical data including separating wet and dry periods and the installed capacity of the pump stations that convey flow to the SWWRF headworks.

4.1 Historical Flow Data

The combined flow data for the SWWRF and Albert Whitted Water Reclamation Facility (AWWRF) was provided from June 2000 to September 2015. The table below summarizes the AADF, Maximum Month Average Daily Flow (MMADF), and Maximum Day Flow (MDF) flows along with the MMADF and MDF peaking factors by year.

Table 4. Historical Flow Data*Combined SWWRF and AWWRF Flows from 2000 to 2015*

Timeframe	AADF	MMADF	Peaking Factor	MDF	Peaking Factor
2000	20.10	26.82	1.33	36.71	1.83
2001	17.50	25.74	1.47	45.03	2.57
2002	17.83	27.25	1.53	42.65	2.39
2003	21.29	32.20	1.51	45.46	2.14
2004	18.14	29.16	1.61	48.93	2.70
2005	15.98	20.75	1.30	29.90	1.87
2006	14.82	20.29	1.37	24.65	1.66
2007	14.54	18.22	1.25	27.37	1.88
2008	15.22	18.63	1.22	22.42	1.47
2009	15.52	21.48	1.38	27.64	1.78
2010	16.10	21.35	1.33	30.98	1.92
2011	16.18	22.98	1.42	32.97	2.04
2012	16.32	24.03	1.47	48.59	2.98
2013	17.15	27.50	1.60	46.12	2.69
2014	16.85	27.43	1.63	42.37	2.51
2015	18.65	33.49	1.80	46.96	2.52
15-year Average	16.91	24.83	1.45	37.42	2.18
5-year Average	17.03	27.08	1.58	43.40	2.55

Table Notes:

Peak hour data into the SWWRF and AWWRF from 2012 and 2015 was also provided and analyzed for this review. Some key points from this data set included:

- There were 181 instances where the peak hour flow was greater than 40 mgd—the current maximum hydraulic design for the SWWRF—out of more than 333,000 total values (< 0.1%)
- The 181 instances occurred over 6 periods
 - June 24th – 26th, 2012
 - August 21st – 22nd, 2012
 - July 2nd – 6th, 2013
 - September 24th – 27th, 2013
 - September 28th – 30th, 2014
 - July 27th – August 8th, 2015
- The single highest value recorded over this period was 60.72-mgd which occurred on September 25th, 2013.
- During the 2015 peak flow event, the headworks was bypassed during periods over four days. Operations estimated peak flow during this time at 65-mgd.

Prior to the 2015 instances where the peak hour flow at SWWRF was greater than 40 mgd, the City only recorded a sanitary sewer overflow in 2012 with the indication that Tropical Storm Debby may have been the cause.

4.2 Analysis

The historical flow data was analyzed to determine peaking factors for each of the key hydraulic and process flow conditions. The Southwest Water Reclamation Facility Wet Weather and Liquid Process Capacity Assessment (B&C, 2014) analyzed data from 2007 through 2013. The analysis led to a recommendation of using the following peaking factors:

- MMADF/AADF = 1.57
- MDF/AADF = 2.63
- PHF/AADF = 3.41

4.2.1 Maximum Month Average Day

The MMADF is not critical in the hydraulic analysis but is important in evaluating the capacity of some treatment processes. The peaking factor for the MMADF was calculated using the following means:

- Average of peaking factor from 2000 – 2015: 1.45
- Average of peaking factors from 2011 – 2015: 1.58
- Peaking factor based on percentile (0.917 or 92nd percentile of the rolling 30-day average which is equivalent to the maximum 30 consecutive days) of the data from 2000 – 2015: 1.33
- Peaking factor based on the 92nd percentile of the data from 2011-2015: 1.35

The average of these methods was 1.43; however the recent data has trended higher. Based on this trend it is recommended to use a MMADF/AADF peaking factor of 1.50 for this analysis.

4.2.2 Maximum Day

The MDF is an important flow condition both for treatment and hydraulic capacity. The peaking factor for the MDF was calculated using the following means:

- Average of peaking factor from 2000 – 2015: 2.18
- Average of peaking factors from 2011 – 2015: 2.55
- Peaking factor based on the percentile (0.997 or 99.7th percentile of the daily data which is equivalent to the maximum days) of the data from 2000 – 2015: 2.41
- Peaking factor based on the 99.7th percentile of the data from 2011-2015: 2.52

Similarly to the MMAD data the MD peaking factors have trended higher in recent years. In addition the recent average peaking factor and the peaking factor from the 99.7th percentile were very similar. Based on the values above it is recommended to use a MDF/AADF peaking factor of 2.55 for this analysis.

4.2.3 Peak Hour

The PHF is critical to evaluating the overall hydraulic capacity of the WRF. The peaking factor for the PHF was calculated using the following means:

- Calculation of peaking factor from 10 States Standards: 1.49
- Average peaking factor from peak hour data from 2012 and 2013: 3.50
- Instantaneous flow capacity to WRF headworks and the design AADF: The headworks at the SWWRF is fed raw wastewater from two offsite lift stations (LS28 and LS85) and an onsite Influent Pump

Station. A review of the design points for the pump stations indicate that there is 82.8-mgd of installed capacity and 64.5-mgd of firm capacity.

- Peaking factor calculated using observed peak flow at SWWRF during August event and 2015 AADF: 3.50

The calculation from 10 States Standards (1997) does not account for significant wet weather, so that value is not appropriate for SWWRF. The historical data indicates that the total installed pumping capacity has not been utilized thus far, but with this capacity in place should be considered in future evaluations. Based on the values above it is recommended to use a MDF/AADF peaking factor of 3.50 for this analysis.

4.2.4 Recommended Flow for Analysis

The peaking factors recommended by B&C were similar to the peaking factors determined above, and the process to determine those peaking factors was reasonable. Due to the availability of more recent data, it is recommended that the City uses the following peaking factors for SWWRF presented in Table 5 as determined above.

Table 5. Recommended Flows for SWWRF
AADF, MMADF, MDF and PHFs

Flow Condition	Value	Note
AADF	20	Projected AADF in 2035 below permitted AADF of 20-mgd
MMADF	30	Based on a peaking factor of 1.50
MDF	51	Based on a peaking factor of 2.55
PHF	70	Based on a peaking factor of 3.50

5 Process and Hydraulic Evaluations

The liquid treatment processes at SWWRF were evaluated for treatment and hydraulic capacity. A process flow diagram of the SWWRF developed by B&C as part of the Biosolids to Energy project is located in Appendix A.

5.1 Process Evaluation

A high level analysis of the key liquid treatment processes at SWWRF was performed in order to determine not just the ability to hydraulically pass peak flows, but also the quality of the treatment.

5.1.1 Headworks

The Headworks at the SWWRF consists of screening and grit removal, each with two units and a bypass channel. Previous design documents indicate that the maximum flow capacity for this process is 40 mgd. The process equipment (mechanical screens, grit chambers, etc.) are typically sized or selected for the hydraulic capacity with specific water surface elevations needed to achieve the desired performance. Therefore the hydraulic and process capacities are equivalent and equal to the design capacity.

5.1.2 Activated Sludge

The activated sludge process at SWWRF utilizes biological treatment by creating conditions (solids retention time, oxygen) for microorganisms to thrive and consume constituents found in municipal

wastewater. The influent loading of these constituents in the raw wastewater is the key factor for this process which is determined by the population served. Peak hydraulic events influenced by wet weather and infiltration and inflow do not increase the overall loading and therefore do not directly impact this process. The equipment and aeration basins that comprise the activated sludge process at SWWRF is appropriately sized for the population served. However, the capacity of the activated sludge process is linked to and impacted by the performance of the downstream secondary clarifier. For example, if the secondary clarifier does not have the required capacity, solids washout may occur during peak flows. This can potentially lower the solids retention time (SRT) to less than the require SRT resulting in the failure of the upstream activated sludge process.

5.1.3 Secondary Clarification

The effluent from the aeration basins (called mixed liquor) proceeds to three secondary clarifiers at SWWRF. Secondary clarifiers are often the most important unit process that determine the peak capacity of the entire facility. Hence a good understanding of the operating conditions that impact their performance is crucial. Secondary clarifiers are required to perform two functions: separation of the mixed liquor solids from the liquid stream (clarification) and conveyance of the separated solids to the bottom of the clarifier to be compacted and removed as underflow (thickening). Consequently, the capacity of secondary clarifiers is impacted by both hydraulic and solids loading rates. During peak flows, the high overflow rate can interfere with solids separation (clarification failure) resulting in solids washout (high effluent solids). Likewise, if the mass of solids entering the clarifier exceeds the mass of solids exiting the clarifier as underflow, the excess solids will accumulate in the sludge blanket. If this condition persists, the rising sludge blanket will eventually reach the effluent weir (thickening failure) leading to solids washout, which will manifest as high effluent solids. Hence, both clarification and thickening failures can potentially cause permit excursions due to high effluent solids and failure of the upstream activated sludge system due to reduced SRT. Based on the high loading rates additional secondary clarification capacity is required in order to effectively treat the projected peak flows.

Table 6. Secondary Clarification Loading Criteria
Hydraulic and Solids Loading Rates

Operating Condition	AADF	MMADF	MDF	PHF
Hydraulic Loading Rates (gpd/ft²)				
All Units in Service	466	699	1188	1631
One Unit Out of Service ¹	699	1048	1337	1835
Target Criteria ²		< 500		< 1200
Solids Loading Rates (ppd/ft²)³				
All Units in Service	19	24	32	38
One Unit Out of Service ¹	29	37	39	45
Target Criteria ²		< 20	< 50	

Table Notes: gpd – gallons per day; ppd – pounds per day

1. MDF and PHF rates are for 75% of rated flow to match reliability and redundancy requirement
2. Per 10 States Standards
3. Solids loading rates assume a mixed liquor of 2,500-mg/L and a RAS rate of 20-mgd

5.1.4 Filtration

The liquid stream from the secondary clarifiers (secondary effluent) flows by gravity to one of four deep-bed filters. Filtration is another process that physical separates particles from the liquid stream. At SWWRF the filters utilize a bed of sand media to trap particles. Hydraulics impact this process. Peak flows higher than the designed capacity increase the velocity through the media and hinder the removal of particles. In addition, a sustained period of elevated flows (even if lower than the design hydraulic maximum capacity) can impact operations. The elevated flows increase solids loading on the filters which then increases the frequency of backwashing required (backwashing includes pumping clean water through the filter in the reverse direction to fluidize the media and remove larger particles). Increased backwashing impacts the filtration capacity since a filter is temporarily off-line and impacts the overall WRF hydraulics since the water used for backwashing must be returned to the Headworks.

The hydraulic loading to filtration at SWWRF at the projected flow conditions is included in the table below. Sufficient capacity exists for the AADF and MMADF conditions. However, the project MDF of 51-mgd and peak flow of 70-mgd is above the filter design capacity. At these flows filtration would be bypassed and no effluent from the SWWRF could be sent to the St. Petersburg Master Reuse System (SPMRS), so all effluent must be retreated or rejected. Based on this analysis additional filtration capacity is required to effectively treat the projected peak flows to SWWRF.

Table 7. Filtration Loading Criteria
Hydraulic Loading Rates

Operating Condition	AADF	MMADF	MDF	PHF
<i>Hydraulic Loading Rates (gpd/ft²)</i>				
All Units in Service	2.5	3.7	6.3	8.6
One Unit Out of Service ¹	3.3	4.9	6.3	8.6
Target Criteria ²	< 5	< 5	< 5	< 5

Table Notes: gpd – gallons per day

1. MDF and PHF rates are for 75% of rated flow to match reliability and redundancy requirement
2. Per 10 States Standards

5.1.5 Disinfection

At SWWRF all effluent must be treated to high level disinfection in order to be utilized in the SPMRS or sent to the injection wells. The existing two chlorine contact basins have sufficient volume to provide high level disinfection at all of the projected flow conditions as presented in the table below.

Table 8. Disinfection Criteria
Hydraulic Detention Times

Operating Condition	AADF	MMADF	MDF	PHF
Hydraulic Retention Time (min)				
All Units in Service	68	46	37	20
One Unit Out of Service ¹	34	23	27	20
Target Criteria ²	> 15	> 15	> 15	> 15

Table Notes:

1. MDF and PHF rates are for 50% of rated flow to match reliability and redundancy requirement
2. 2. Minimum requirements per FAC 62-600

5.2 Hydraulic Evaluation

The hydraulic evaluation of the liquid processes at SWWRF included a review of the original design capacity of the processes, modeling the gravity flow through the plant and analyzing the effluent pumping storage and disposal capacities.

5.2.1 Design Capacity

The SWWRF has been operating for over five decades. Over that period the overall capacity has increased to a permitted flow of 20 mgd (AADF) through many design and construction projects. The SWWRF currently does not have primary clarification, but the addition of primary clarifiers to the treatment process is proposed as part of the Biosolids to Energy project to help treat the additional load from waste activated sludge that will be conveyed from the NEWRF and NWWRF. The listed design capacity and flow condition for key liquid processes as indicated in previous design project documents are included in the table below. These capacities consider all basins in service.

Table 9. Hydraulic Capacity Summary
Hydraulic and Solids Loading Rates

Process / Facility	Design Capacity	Notes
Preliminary Treatment		
Coarse Screening	AADF: 20-mgd PHF: 40-mgd	Used for screening of gravity influent flow only
Influent Pump Station	Installed Capacity: Firm Capacity:	Analysis ongoing; to be included in final report
Headworks	AADF: 20-mgd PHF: 40-mgd	Per SWWRF Headworks and Flow Splitter Box Expansion; CDM, 2001 As-Builts 48-in diameter bypass available for flows above design capacity
Primary Treatment (proposed)		
Primary Clarifiers	AADF: 20-mgd PHF: 40-mgd	Per GMP Biosolids Drawings Higher flows will proceed to secondary treatment from Step-Feed Splitter Box

Secondary Treatment		
Flow Splitter	AADF: 20-mgd PHF: 40-mgd	Per SWWRF Headworks and Flow Splitter Box Expansion; CDM, 2001 As-Builts
Aeration Basins	AADF: 20-mgd MDF: 40-mgd PHF: 70-mgd	Per GMP Biosolids Drawings
Secondary Clarifiers	AADF: 20-mgd PHF: 40-mgd	Per GMP Biosolids Drawings No hydraulic profile included in SWWRF Clarifier Improvements and Flow Splitter Box; CDM, 1998 Record Drawings
Tertiary Treatment		
Filtration	AADF: 20-mgd PHF: 40-mgd	Per GMP Biosolids Drawings 48-in bypass available for flows above design capacity ¹
Disinfection	AADF: 20-mgd PHF: 40-mgd	Per GMP Biosolids Drawings
Effluent Disposal		
Onsite Storage	Existing: 15-mg In Progress: 15-mg	One 5-mg and one 10-mg tanks One 15-mg under construction
Effluent Pumping	Existing Capacity: 39-mgd Future Capacity: 55-mgd	Five 250-hp pumps Two 450-hp pumps
Disposal Well Capacity	45-mgd at max wellhead pressure of 70 psi	Per FDEP Underground Injection Control Permit

Table Notes:

1. By-passing filtration impacts effluent disposal. Discussed further in following sections.

As indicated in the table a majority of the liquid processes at SWWRF were designed for a peak flow lower than those experienced. A review of the overall gravity flow through these facilities and available bypasses is included in the following section.

5.2.2 Hydraulic Modeling of Gravity Flow

The gravity flow through the SWWRF was modeled for this peer review using CH2M’s proprietary WinHydro software. Information on the various facilities was gleaned from multiple design documents listed earlier in this report. The following assumptions and techniques were utilized in developing, running and analyzing the hydraulic model and the results:

- A Manning’s n value of 0.013 was used for all channels and piping
- A Return Activated Sludge (RAS) rate of 20-mgd was included from the secondary clarifiers to Splitter Box No. 1
- An internal recycle rate of 5-mgd was included from the filters to the headworks.
- Available bypasses were used above the design flow for the Headworks and filtration.
- The PHF was assumed to pass through the existing secondary clarifiers despite the evaluation indicated this rate is higher than design. This was done because the out of service basins onsite-- which can now accept overflows from the mixed liquor splitter box—will no longer be available after the Biosolids to Energy Project is complete.

5.2.3 Effluent Pumping, Storage and Disposal

A critical component of keeping a water reclamation facility in operation is the storage and disposal of treated water. The effluent pumping, storage, and disposal for the SWWRF was investigated as it relates to peak flows recently observed.

5.2.3.1 Effluent Pumping

The SWWRF currently has two pump stations downstream of the chlorine contact chamber: the Filter Backwash Pump Station and the Distribution Pump Station. The Filter Backwash Station pumps water to back wash the filters and fill the ground storage tanks with either reclaimed water or reject water. A 54" gravity line hydraulically connects the wetwell of the Backwash Pump Station to the Distribution Pump Station. Reclaimed water stored in the ground storage tanks can be conveyed by gravity to the Distribution Pump Station by connection to the 54" line. The Distribution Pump Station is used to pump effluent that meets all permitted water quality criteria to the SPMRS, on-site Aquifer Storage and Recovery (ASR) well, and to the three on-site Deep Injection Wells. During the recent wet weather events in early August, the City disposed unfiltered effluent down the injection wells; however, the existing pumping capacity of five 250 horsepower pumps at the Distribution Pump Station would not allow for maximum disposal down the injection wells, which are rated for a combined capacity of 45 mgd provided that the wellhead pressures do not exceed 70 psi. The City is currently constructing an expansion to the Distribution Pump Station, which would add two 450 horsepower pumps.

On May 30, 2015, a Maximum Available Injection Capacity (MAIC) test was conducted on the SWWRF Injection Well System. During this test, the valves were configured so that only water could flow to the injection wells. The flow control valves to the injection wells were fully opened, and the five existing pumps were operated at full capacity for 15 minutes. The results from this test indicated that 39 mgd could be pumped to the injection wells, and the injection wells had an average wellhead pressure of 34 psi.

Using Applied Flow Technology's Fathom, a pressurized flow model, the pumping capacity to the injection wells including the two additional pumps were modelled. The model was developed using existing record drawings, the results of the last MAIC test, and the pump curves of the existing and new pumps. Based on this preliminary analysis, the model indicated that approximately 55 mgd could be pumped to the injection wells with all seven pumps in service, with an observed average pressure of approximately 66 psi. This flow rate and pressure was based on the above mentioned MAIC test that was performed after a recent well rehabilitation event that occurred from April 29, 2015, through May 14, 2015, which increased each of the injection wells' and the ASR well's ability to dispose of more water while keeping a reduced wellhead pressure. Over time, all of the wells begin to require higher wellhead pressures to discharge the same amount of water due to clogging of the porous disposal zones, so the actual maximum available injection capacity (MAIC) may be less than what was modelled.

Although this 55 mgd theoretical injection rate is greater than the injection well system's current permitted capacity, the injection wells have the potential to be re-rated up to a maximum injection rate of 19.05 mgd, if the wellhead pressure can remain below the maximum allowable of 70 psi.

A hydraulic limitation in the system is the 16" diameter branch pipes to each well, totaling approximately 1,200 linear feet. These pipes experience high velocities at these flowrates that increase the headloss and thus reduce the pumping capacity. The model was run again with these 16" diameter pipes increased to 24" diameter pipes. With 24" pipes in place of the existing 16" pipes, the model showed that the theoretical maximum injection rate would be approximately 59 mgd at an average

wellhead pressure of 70 psi, which preliminarily indicates that the wells could be re-rated to the theoretical maximum capacity of 19.05 mgd per well provided that the 16” diameter pipes are upgraded to 24” diameter pipes. Further investigation into the feasibility of this piping modification and coordination with FDEP would be required to determine the actual maximum disposal capacity.

5.2.3.2 Effluent Storage

Along with the NEWRF and NWWRF, the SWWRF’s ground storage tanks are primarily used for Part III Public Access Reuse effluent; however, FDEP has approved the use of these ground storage tanks for storage of off-spec effluent as well. Per the City’s Operating Protocol, if the ground storage tanks are used in this manner, the off-spec water is routed to the head of the plant for retreatment once the SWWRF is producing Part III reuse quality effluent again. The tank is then flushed out twice with Part III quality effluent by the volume of off-spec water that was stored in the tank before the tank can be used again to store Part III reuse quality effluent.

During the July/August rain event, the SWWRF used the storage tanks for off-spec water, and therefore the existing 15 mg volume was not available for the additional effluent that could not be disposed of down the injection wells. For this analysis it is assumed that the existing wells were not operating at the performance observed during the May 30, 2015 MAIC, and the injection wells were accepting an approximate 37 mgd during July/August. The influent flows experienced at the SWWRF in early August were greater than the existing capacity of the injection well system. The table and figure below illustrate the deficiency and the impact of the current improvements:

Table 10. Effluent Pumping and Disposal Analysis


Flow Data at SWWRF for August 1st – 6th

Date	Influent Flow (mgd)	Excess Effluent (mgd) – Existing Installed Capacity	Excess Effluent (mgd) – Future Installed Capacity¹	Excess Effluent (mgd) – Future Firm Capacity²
8/1/2015	41.35	4.35	0	0
8/2/2015	46.96	9.96	0	0
8/3/2015	45.80	8.80	0	0
8/4/2015	42.69	5.69	0	0
8/5/2015	39.98	2.98	0	0
8/6/2015	37.28	0.28	0	0
		32.06 mg	0	0

Table Notes:

1. 55-mgd
2. 50-mgd


Figure 1. Effluent Pumping Analysis
Flow Data at SWWRF for August 1st – 6th



The data above shows that insufficient pumping capacity was available during the July/August peak flow event to meet the daily flows experienced at SWWRF. However, preliminary modeling of the injection well system with the additional pumps currently being added will increase the installed capacity to 55-mgd, and the firm capacity (capacity with the largest unit out of service) to 50-mgd. This level of service would have been sufficient to meet the daily flows experienced during the July/August peak flow event.

The analysis above only considers the daily flows and not the PHFs during this period. As indicated earlier in this report, PHFs greater than 65-mgd have been recorded at SWWRF and the projected PHF for the future was 70-mgd. When the influent flow peaks above the maximum effluent disposal pumping capacity, the onsite storage can be used for mitigation. The figure below shows an example diurnal flow curve for a MDF of 51-mgd with a PHF of 70-mgd for 24 hours starting at 8 am. The influent flows are greater than the effluent pumping capacity during the morning peak and the excess can be stored onsite. As the flows decrease overnight the pumping capacity is greater than the flow received and additional effluent from storage can be disposed. In this scenario less than 4 mg of storage was necessary. Following the completion of the 15 mg storage tank currently under construction at SWWRF, operations will have a total of 30 mg of storage

Figure 2. Example Diurnal Flow Curve
Hourly Influent Flow, Effluent Pumping and Storage Requirements



5.2.3.3 Effluent Disposal

The SWWRF Underground Injection Control (UIC) Permit (Permit No. 36855-013-UO/1M, 36855-014-UO/1M, 36855-015-UO/1M) states that only water in compliance with 40 CFR 146.15 and 146.16 may be routed directly to the injection wells.

40 CFR 146.15 states that the injectate shall be treated using high-level disinfection in a manner that is no less stringent than the requirements of the Florida Administrative Code (FAC) 62-600.440(5)(a)-(f) within five years after notification by the Director that the well has caused or may cause fluid movement into a Underground Source of Drinking Water USDW.

FAC 62-600.440(5)(a)-(f) states that high-level disinfection shall include additional TSS control beyond secondary treatment levels to maximize disinfection effectiveness and shall be designed to result in fecal coliform values below detectable limits except as provided on FAC 62-600.440(5)(g) or FAC 62-600.440(5)(h). These two rules state other criteria for meeting high-level disinfection, but they do not apply to these injection wells. 62-600-440(5) states that rapid and uniform mixing provisions shall be designed when chlorine is used for disinfection, and a total chlorine residual of at least 1.0 mg/L must be maintained at all times. The SWWRF uses chlorine disinfection, and has rapid mixers installed upstream of the chlorine contact chambers. This rule gives design criteria for minimum chlorine contact times based on fecal coliform counts prior to disinfection. The rule also states that the facilities shall be designed to reduce TSS to 5.0 mg/L or less before disinfection, which does not preclude an additional application of disinfectant prior to filtration for the purpose of improving filter performance. Lastly, FAC 62-600.400(5)(f) states operational criteria for determining high level disinfection compliance states that 75% of fecal coliform values over a 30 day period shall be below detection limits, one sample shall not exceed 25 fecal coliform values per 100 mL of sample, and any one sample of TSS shall not exceed 5.0 mg/L prior to disinfection.

The SWWRF UIC Permit confirms the high-level disinfection requirement by stating that “Injection will be into the Avon Park Formation for the domestic effluent receiving a minimum of secondary treatment with high-level disinfection.

The SWWRF Operation Permit (Permit No. FLA128848) identifies the SPMRS as the primary disposal method of reclaimed water, and disposal of reclaimed water can be disposed in the ASR well and injection well system if necessary. However, effluent limitations for disposing into the injection well system is defined only as secondary treatment standards. Per the effluent limitations requirement B.8, treatment facilities shall be operated in accordance with the approved operating protocols. Reclaimed water that fails to meet the approved operating protocol criteria shall be directed to the on-site ground storage tanks or to the injection well system. The operating protocol shall be reviewed by FDEP and updated periodically and with each permit application to ensure compliance with the minimum disinfection and treatment requirements.

FAC 62-610.460 for Part III Public Access Reuse states that the reclaimed water shall not contain more than 5.0 mg/L before disinfection and that filtration shall be provided for TSS control; however, the requirement that effluent sent to the injection wells must meet Part III Public Access Reuse requirements is not identified in neither the SWWRF Operation Permit nor the SWWRF UIC Permit.

6 Identification of Hydraulic Limitations

The hydraulic evaluation included an analysis of the pumping systems into and out of the SWWRF, the gravity flow through the treatment processes within the SWWRF, the available storage of effluent and off-spec water and the capacity of the injection well system. From this analysis the following hydraulic limitations were identified:

6.1 Influent Pumping

This analysis is ongoing and will be included in the final report

6.2 Treatment Process

The following limitations were identified for processes at SWWRF:

- Screening and grit removal sized for 40-mgd, below projected MDF and PHF
- Secondary clarification loading rates above recommended for MMADF, MDF and PHF
- Hydraulic loading rates to tertiary filtration above recommended for MDF and PHF

6.3 Gravity Flow

The following locations were identified as hydraulic limitations within the gravity flow at the SWWRF:

- The 8-ft long weir at the effluent of the Headworks
- The 48-in diameter Screened Raw Sewage pipe between the Headworks and Splitter Box No. 1
- The 48-in diameter Secondary Effluent pipe between Secondary Clarifier No. 2 and Secondary Clarifier No. 1
- The 48-in diameter Secondary Effluent pipe between Secondary Clarifier No. 1 and the Filters
- The 54-in diameter Filter Effluent pipe between the Filters and the Chlorine Contact Basins

6.4 Effluent Pumping, Storage and Disposal

The following limitations were identified as part of the effluent pumping storage and disposal system:

- The existing effluent pumping capacity is below the MDF experienced at SWWRF (Note: additional pumps are currently being added).
- The SWWRF currently has 15-mgd of storage for reclaimed water or for off-spec water as needed. Due to the time frame of recent hydraulic peak events this storage was not sufficient to store flow in excess of the disposal capacity. (Note: an additional 15-mgd of storage is currently being added).
- Injection well maximum permitted disposal capacity of 45 mgd is below the MDF experienced at SWWRF. These wells could be re-rated up to a maximum of 19.05 mgd per well (57.15 mgd total), but maximum wellhead pressure of 70 psi must be considered, which may result in a smaller maximum capacity with the current injection well system piping constraints.

7 Summary and Recommendations

This report contains a description of the peer review performed on the wastewater flow projections and liquid processing facilities for the City of St Petersburg. The peer review included:

- Flow projections for the service areas were developed using TAZ data. The projected 2035 AADFs for each WRF was below the current permitted AADF so the permitted value should be used for all hydraulic evaluations, which are:
 - NEWRF – 16-mgd
 - NWWRF – 20-mgd
 - SWWRF – 20-mgd
- The following peaking factors and resulting design flows were developed for the SWWRF in order to evaluate the process and hydraulic capacity:
 - MMADF – 1.5; 30-mgd
 - MDF – 2.55; 51-mgd
 - PHF – 3.5; 70-mgd
- The treatment capacity of key liquid processes were evaluated using the projected flow conditions determined in this peer review. The following treatment processes had loading rates above the design capacity or recommended criteria
 - Headworks
 - Secondary clarification
 - Filtration
- The gravity flow through the SWWRF was modeled and evaluated using the projected flow conditions determined in this peer review and hydraulic limitations were identified. Hydraulic limitations were found at the following locations:
 - Headworks effluent weir
 - Secondary effluent piping
 - Filter effluent piping
- The capacity and operation of the effluent pumping, storage and disposal were also evaluated based on the peak flow conditions determined above. The existing pumping and storage capacity was not sufficient to handle the peak flows experience during the July/August 2015 event. The City currently has two projects underway that will address this deficiency: an additional 15-mgd storage and two additional 450-hp effluent pumps. Based on this preliminary analysis these additional storage and pumping capacity would have been sufficient to avoid the recent overflows during the July/August event.

The following recommendations are presented as part of this peer review:

- The current peak flows into the SWWRF are greater than the design capacity for multiple facilities. Currently, SWWRF operations utilizes by-pass piping, and out of services basins along with the existing effluent/off-spec storage to handle these events. Since these peak flow events are primarily caused by infiltration/inflow (I/I) due to wet weather there are two ways to solve this capacity issue: 1) reduce I/I with collection system improvement and 2) increase treatment and disposal capacity at the WRF
- The following process upgrades are recommended to increase treatment capacity at the SWWRF:
 - Upgrade/expand the Headworks to provide additional screening and grit removal capacity up to the design PHF
 - Add a fourth secondary clarifier
 - Add filtration capacity
 - Piping improvements would be required along with these new processes in order to increase the overall WRF capacity
- Collection system improvements to reduce the amplitude of flows coming into the SWWRF during wet-weather events could prove to have some cost-effective solutions which would require less significant improvements at the SWWRF to be made. Identifying specific improvements to the collection system is not included in this project but will be evaluated as part of a future project. This project will also provide additional detail for potential WRF upgrades including preliminary level costs estimates. These costs will be compared to estimates for potential collection system upgrades and the recommended approach will be developed which includes the optimum combination of collection system and WRF improvements.
- The following upgrades are recommended to increase disposal capacity at the SWWRF:
 - Consider modifying the City's Operating Protocol to allow disposal of effluent meeting secondary treatment and high-level disinfection standards without the requirement to go through the filters.
 - When the two new 450 horsepower pumps are online, consider rerating the injection wells up to 19.05 mgd each for a total of 57.15 mgd. With the new pump addition, the injection wells are anticipated to dispose of approximately 55 mgd. Replacing the existing 16" piping, valves, and meters in the injection well disposal system with 24" diameter piping would give the system less hydraulic restriction allowing the current pumps to provide the maximum allowable flowrate of 19.05 mgd to each injection well without exceeding the wellhead pressure limitation.

Redundancy in wet weather events is key. Consider adding a fourth deep injection well to use normally, reduce the current load on the three existing injection wells during normal operation scenarios, serve as a backup in case one injection well is offline, and bring the total permitted disposal capacity potentially up to 76.2 mgd

8 References

Policies for the Design, Review and Approval of Plans and Specifications for Wastewater Collection and Treatment Facilities (10 States Standards): A Report of the Wastewater Committee of the Great Lakes—Upper Mississippi River Board of State and Provincial Public Health and Environmental Managers. Health Research Inc., Health Education Services Division. 2004 Edition.

CH2M and ASRus, 2015. 2014 Summary Report: City of St. Petersburg Deep Injection Well and ASR Systems – January 2014 through December 2014. August.


CH2M and ASRus, 2015. Southwest Water Reclamation Facility Deep Injection Wells and ASR Well Acidization Summary Report. October.

Appendix A

SWWRF Process Flow Diagram

GENERAL NOTES			EQUIPMENT ABBREVIATIONS						GENERAL ABBREVIATIONS					
<p>1. ABBREVIATIONS FOR THE ENTIRE PROJECT EXCEPT ELECTRICAL ARE PROVIDED IN THESE GENERAL SHEETS.</p> <p>2. ALL MECHANICAL SYMBOLS ARE IDENTIFIED IN THESE GENERAL SHEETS. GENERAL SHEETS DO NOT PROVIDE SYMBOLS NOR DETAILS FOR ANY DISCIPLINE OTHER THAN MECHANICAL SYMBOLS. REFERENCE THE INDIVIDUAL DISCIPLINE SHEETS FOR ADDITIONAL DISCIPLINE-SPECIFIC SYMBOLS.</p>			<p>A AERATOR AB AERATION BASIN ACC AIR CONDITION COIL ACU AIR CONDITIONING UNIT AD AIR DRYER AF AIR FILTER AHC AIR HANDLING UNIT W/COIL AHU AIR HANDLING UNIT APU AIR PURIFICATION UNIT ASC ADJUSTABLE SPEED CONTROL ASD ADJUSTABLE SPEED DRIVE ARV AUTOMATIC AIR RELEASE VALVE</p> <p>B BLOWER BFP BELT FILTER PRESS BLR BOILER BNR BURNER</p> <p>C COIL CCT CHLORINE CONTACT TANK CDR CONDENSER CFR CHEMICAL FEEDER CHR CHILLER COL COLLECTOR COM COMMUNUTOR CON CONVEYOR CP COMPRESSOR CPUL CARBON POLISHER CRN CRANE CT COOLING TOWER CTF CENTRIFUGE CU CONDENSING UNIT CV CONTROL VALVE CVR FLOATING COVER CYL CYLINDER</p> <p>DIS DISTRIBUTOR DPR DAMPER DS DISCONNECT SWITCH DU DRIVE UNIT</p> <p>E ENGINE EB ENGINE BLOWER MODULE ED EQUIPMENT DRAIN EF EXHAUST FAN EPR EVAPORATOR</p> <p>F FAN FAR FLAME ARRESTER FCT FERRIC CHLORIDE TANK FLT FILTER FPU FLUID POWER UNIT FT FOG TANK FUR FURNACE</p> <p>GBT GRAVITY BELT THICKENER GDR GRINDER GEN GENERATOR GT GATE</p> <p>H HOIST HEX HEAT EXCHANGER HOP HYDRAULIC OPERATOR HP HEAT PUMP HPU HYDRAULIC POWER UNIT HTR HEATER HTT HEAT TRACE TAPE HV HAND OPERATED VALVE</p> <p>INJ INJECTOR IW INJECTION WELL</p> <p>LCP LOCAL CONTROL PANEL LVR LOUVER</p> <p>M MOTOR MME MISC. MECHANICAL EQUIPMENT MOP MOTOR OPERATOR MSP MOTOR STARTER PANEL MUX MULTIPLEXER MX MIXER MZ MULTIZONE UNIT</p> <p>ORT ODOR REMOVAL TOWER</p>						<p>A AMPERE OR AERATOR AB AERATION BASIN ABAND ABANDONED ACC AIR CONDITION COIL ACU AIR CONDITIONING UNIT AD AIR DRYER ADJ ADJUSTABLE AF AIR FILTER AFD ADJUSTABLE FREQUENCY DRIVE AFF ABOVE FINISHED FLOOR AFG ABOVE FINISHED GRADE AHC AIR HANDLING UNIT W/COIL AHU AIR HANDLING UNIT AL ALUMINUM APPROX APPROXIMATE ASC ADJUSTABLE SPEED CONTROL ASD ADJUSTABLE SPEED DRIVE ASPH ASPHALT ASR AQUIFIER SURFACE RECHARGE ASSOC ASSOCIATION ASTM AMERICAN SOCIETY OF TESTING MATERIALS ATS AUTOMATIC TRANSFER SWITCH AUTO AUTOMATIC AUX AUXILIARY AVG AVERAGE AWG AMERICAN WIRE GAGE</p> <p>B BLOWER BC BOTTOM OF CURB BEL BELOW BF BLIND FLANGE BFPF BELT FILTER PRESS FILTRATE BFPV BACKFLOW PREVENTER BFV BUTTERFLY VALVE BHP BRAKE HORSEPOWER BK BACK BL BASE LINE BLDG BUILDING BLR BOILER BM BENCH MARK BNR BURNER BOT BOTTOM BRG BEARING BRK BRICK BT BACKWASH TANK OR BATCH TANK BTDPDS BATCH TANK DISCHARGE PUMP STATION BUS BIOGAS UPRADE SYSTEM BV BALL VALVE</p> <p>C CELSIUS OR COIL CAB CABINET CATV CABLE TELEVISION CB CATCH BASIN CC CENTER TO CENTER CCT CHLORINE CONTACT TANK CDR CONDENSER CE CONSTRUCTION EASEMENT CF CUBIC FOOT CFM CUBIC FEET PER MINUTE CFR CHEMICAL FEEDER &G CURB AND GUTTER CHAN CHANNEL CHR CHILLER CI CAST IRON CIR CIRCLE CIRCUM CIRCUMFERENCE CJ CONSTRUCTION JOINT CL CENTERLINE OR CLASS CLG CEILING CLR CLEAR CMU CONCRETE MASONRY UNITS CON CLEANOUT COL COLUMN OR COLLECTOR COM COMMUNUTOR COMB COMBINED CON CONVEYOR CONC CONCRETE / CONCENTRIC</p> <p>CP COMPRESSOR OR COMPUTED POINT CPG COUPLING CR CRANE CS COMBINED SEWER CT CURRENT TRANSFORMER CTF CENTRIFUGE CTG COATING CULV CULVERT CYL CYLINDER</p> <p>D1 DIGESTER 1 D1PS DIGESTER 1 DISCHARGE PUMP STATION D1RPS DIGESTER 1 RECYCLE PUMP STATION D2 DIGESTER 2 D2PS DIGESTER 2 DISCHARGE PUMP STATION D3 DIGESTER 3 D3PS DIGESTER 3 DISCHARGE PUMP STATION DB DUCT BANK DC DIRECT CURRENT DEMO DEMOLITION / DEMOLISH DEPT DEPARTMENT DI DROP INLET DIA DIAMETER DIAG DIAGONAL DIM DIMENSION DIS DISTRIBUTOR DPR DAMPER DS DISCONNECT SWITCH DU DRIVE UNIT DWG DRAWING DWL DOWEL DWY DRIVEWAY</p> <p>E EAST OR ENGINE EA EACH EB ENGINE BLOWER MODULE ECC ECCENTRIC ECF EQUIPMENT CONNECTION FITTING ED EQUIPMENT DRAIN EF EACH FACE EL ELEVATION ELEC ELECTRICAL / ELECTRIC ELEV ELEVATION EMH ELECTRICAL MANHOLE ENGR ENGINEER EOP EDGE OF PAVEMENT EPR EVAPORATOR EPS EFFLUENT PUMP STATION EQ EQUAL EQUIP EQUIPMENT ES ELECT3RICAL SERVICE ESMT EASEMENT EW EACH WAY EST ESTIMATE / ESTIMATED EXIST EXISTING EXP EXPANSION EXT EXTERIOR EXIST EXISTING</p> <p>F FAHRENHEIT OR FAN FBW FILTER BACKWASH FC FAIL CLOSED FCO FLOOR CLEANOUT FCPS FERRIC CHLORIDE PUMP STATION FCT FERRIC CHLORIDE TANK FD FLOOR DRAIN F-F FACE TO FACE FFE FINISH FLOOR ELEVATION FG FINISHED GRADE FH FIRE HYDRANT FL FLOW LINE FLEX FLEXIBLE FLR FLOOR FLT FILTER FM FORCEMAIN FO FAIL OPEN FP&L FLORIDA POWER & LIGHT FPM FEET PER MINUTE FPS FOG DISCHARGE PUMP STATION FPU FLUID POWER UNIT</p> <p>FR/FPS FOG RECYCLE FEED PUMP STATION FSPS FOAM SUPPRESSION PUMP STATION FT FEET / FOOT OR FOG TANK FTP FLAME TRAP FUR FURNACE FURNISHED</p> <p>G GAS GC GRANITE CURB GBFT GRAVITY BELT THICKENER FILTRATE GBV GLOBE VALVE GDR GRINDER GEN GENERATOR GFI GROUND FAULT INTERRUPTER GM GAS METER GPD GALLONS PER DAY GPM GALLONS PER MINUTE GR GRADE GRT GROUT OR GRATE GSKT GASKET GT GATE GV GATE VALVE OR GAS VALVE</p> <p>H HIGH OR HOIST HC HEADER CURB HGL HYDRAULIC GRADE LINE HGR HANGER HOA HAND-OFF-AUTO HOP HYDRAULIC OPERATOR HOR HORIZONTAL HP HEAT PUMP OR HIGH POINT HPU HYDRAULIC POWER UNIT HTR HEATER HTT HEAT TRACE TAPE HV HAND OPERATED VALVE HZ HERTZ</p> <p>ID INSIDE DIAMETER IE INVERT ELEVATION IN INCH INSUL INSULATION INV INVERT IPS INFLUENT PUMP STATION IW INJECTION WELL</p> <p>JB JUNCTION BOX JT JOINT JT FLR JOINT FILLER</p> <p>KW KILOWATT</p> <p>L LENGTH LB POUND LCP LOCAL CONTROL PANEL LF LINEAR FEET LOC LOCATION LP LIGHT POLE / LIGHTING PANEL LPNG OPENING LS LIMIT SWITCH OR LIFT STATION L/S LANDSCAPE STRIP LT LEFT</p> <p>M MOTOR MAS MASONRY MATL MATERIAL MAX MAXIMUM MCC MOTOR CONTROL CENTER MECH MECHANICAL MFR MANUFACTURER MGD MILLION GALLONS PER DAY MH MANHOLE MIN MINIMUM / MINUTE MISC MISCELLANEOUS MON MONUMENT MOP MOTOR OPERATOR MPH MILES PER HOUR MSL MEAN SEA LEVEL MSP MOTOR STARTER PANEL MUX MULTIPLEXER MZ MULTIZONE UNIT</p> <p>N NORTH N/A NOT APPLICABLE NAVD NATIONAL AMERICAN VERTICAL DATUM N.C. NORMALLY CLOSED NE NORTHWEST NEC NATIONAL ELECTRICAL CODE NEG NEGATIVE NEUT NEUTRAL NGVD NATIONAL GEODETIC VERTICAL DATUM NO NUMBER N.O. NORMALLY OPEN NOM NOMINAL NTS NOT TO SCALE NW NORTHWEST</p> <p>OA OUTSIDE AIR OD OUTSIDE DIAMETER OH OVERHEAD OHP OVERHEAD POWER OPER OPERATOR OPNG OPENING</p> <p>P POWER PAR PARALLEL PC PROCESS OR PERSONAL COMPUTER OR PRIMARY CLARIFIER PE-CS PRIMARY EFFLUENT - CONTACT STABILIZATION PE-SF PRIMARY EFFLUENT - STEP FEED PH PHASE PL PROPERTY LINE PLC PROGRAMMABLE LOGIC CONTROLLER PLT PLANT PLYWD PLYWOOD PNL PANEL POI POINT OF INTERSECTION POL POLYMER POP PNEUMATIC OPERATOR POT POINT OF TANGENCY PP POWER POLE PROP PROPOSED PRPS PUBLIC REUSE PUMP STATION PS PUMP STATION PSA PRESSURE SWING ABSORPTION PSF POUNDS PER SQUARE FOOT PT POINT PTS PRELIMINARY TREATMENT STRUCTURE PV PLUG VALVE PVL PRESSURE VESSEL PVMT PAVEMENT</p> <p>Q FLOW QTY QUANTITY</p> <p>R RADIUS R/W RIGHT OF WAY RA RETURN AIR RC REINFORCED CONCRETE RD ROOF DRAIN RE RIM ELEVATION REC RECEIVER REF REFERENCE REINF REINFORCE / REINFORCED / REINFORCING RP REFERENCE POINT REQD REQUIRED REV REVISED OR REVISION RPM REVOLUTIONS PER MINUTE RT RIGHT R/W RIGHT OF WAY</p> <p>S SOUTH SA SUPPLY AIR SAN SANITARY SB SOIL BORING SC SECONDARY CLARIFIER SCUPPER DRAIN</p> <p>SCH SCHEDULE SCPS SCUM PUMP STATION SCR SCREEN OR SCRUBBER SD STORM DRAIN OR SANITARY DRAIN SE SOUTHEAST OR SECONDARY EFFLUENT SECTION SEP SEPARATOR SHT SHEET SLR SILENCER SMP SAMPLER SPEC SPECIFICATION SSC SECONDARY SCUM SERVICE SINK ST STEAM TRAP OR STREET STATION STD STANDARD STL STEEL STM STEAM STRUC STRUCTURE / STRUCTURAL STRW STORAGE REJECT WATER SUB SUBSTATION SV SOLENOID VALVE SW SW SWBD SWITCHBOARD SWGR SWITCHGEAR SWK SIDEWALK SYM SYMMETRICAL</p> <p>T TELEPHONE TBN TURBINE TC TOP OF CURB TCV TEMPERATURE CONTROL VALVE TEL TELEPHONE TEMP TEMPORARY / TEMPERATURE TRANSFORMER TFR TRANSFORMER TM TIMER T.O. TOP OF TP TRAP PRIMER TPS TRANSFER PUMP STATION TRS TRANSFER SWITCH TS TEMPERATURE SWITCH TYP TYPICAL TW TOP OF WALL</p> <p>UG UNDERGROUND UH UNIT HEATER US UTILITY STATION</p> <p>V VOLTS OR VENT VAC VACUUM OR VOLT VAR ALTERNATING CURRENT VARIABLE / VARIES VCP VENDOR CONTROL PANEL VE VESSEL VEL VELOCITY VEN VENTILATOR VERT VERTICAL VOL VOLUME VP VACUUM PUMP VTR VENT THROUGH ROOF</p> <p>W WEST OR WIDTH WATER COLUMN WCO WALL CLEANOUT W/ WITH WM WATER METER W/O WITHOUT WB WET BULB WH WATER HEATER WHR WASHER WL WATER LEVEL WSR WATER SOFTENER UNIT WT WATER TABLE WV WATER VALVE</p> <p>XFMR TRANSFORMER XP EXPLOSION PROOF</p> <p>YCO YARD CLEANOUT YR YEAR</p> <p>ZS POSITION SWITCH</p>					
PIPING SYSTEM ABBREVIATIONS			PIPING TYPE ABBREVIATIONS											
FLOW STREAM ABBREVIATIONS														
<p>A AERATION AIR ABE AERATION BASIN EFFLUENT ABI AERATION BASIN INFLUENT BFPF BELT FILTER PRESS FILTRATE CD CHEMICAL DRAIN CHEM CHEMICAL CEN CENTRATE CGR CHILLED GLYCOL RETURN CGS CHILLED GLYCOL SUPPLY CS CONTACT STABILIZATION CULV CULVERT CW COLD WATER CWR COLD WATER RETURN CWS COLD WATER SUPPLY D DRAIN DG DIGESTER GAS DG/OF DIGESTER GAS / OVERFLOW DS DIGESTED SLUDGE DSF DIESEL FUEL FA FOUL AIR FBW FILTER BACKWASH FECL FERRIC CHLORIDE FOG FATS OIL GREASE GBTF GRAVITY BELT THICKENER FILTRATE HDG HIGH PRESSURE DIGESTER GAS HPA HIGH PRESSURE AIR HW HOT WATER HWR HOT WATER RETURN HWS HOT WATER SUPPLY IA INSTRUMENT AIR ML MIXED LIQUOR NGA NATURAL GAS NIT NITROGEN OA OUTSIDE AIR ODO ODORANT OF OVERFLOW PD GRAVITY PROCESS DRAIN PE PRIMARY EFFLUENT PE-CS PRIMARY EFFLUENT - CONTACT STABILIZATION PE-SF PRIMARY EFFLUENT - STEP FEED PLW CHLORINATED PLANT WATER POL POLYMER PS PRIMARY SLUDGE PSC PRIMARY SCUM PPD PUMPED PROCESS DRAINAGE PW POTABLE WATER RAS RETURN ACTIVATED SLUDGE RD ROOF DRAIN RNG RENEWABLE NATURAL GAS RS RAW SEWAGE SD SANITARY DRAIN OR STORM DRAIN SE SECONDARY EFFLUENT SF STEP FEED SLW SEAL WATER SPW SPRAY WATER SRS SCREENED RAW SEWAGE SS SANITARY SEWER SSC SECONDARY SCUM STD STORM DRAIN STM STEAM THS THICKENED SLUDGE TD TANK DRAIN (PROCESS UNIT TANK DRAIN) UG UNDERDRAIN V VENT VC CHEMICAL VENT W WATER WAS WASTE ACTIVATED SLUDGE WGA WASTE GAS</p>			<p>304SS 304 STAINLESS STEEL 316SS 316 STAINLESS STEEL CI CAST IRON CIS CAST IRON SOIL PIPE CMLS CEMENT LINED STEEL CMP CORRUGATED METAL PIPE CPVC CHLORINATED POLYVINYL CHLORIDE CU COPPER PIPE CUK COPPER PIPE - TYPE K CUL COPPER PIPE - TYPE L DI DUCTILE IRON DIGL GLASS LINED DUCTILE IRON ELS EPOXY LINED STEEL FRP FIBER REINFORCED PLASTIC HDPE HIGH DENSITY POLYETHYLENE PCCP PRESTRESSED CONCRETE CYLINDER PIPE PE POLYETHYLENE PP POLYPROPYLENE PVC POLYVINYL CHLORIDE RCP REINFORCED CONCRETE PIPE ST STEEL VCP VITRIFIED CLAY PIPE</p>											

<p>Brown and Caldwell TAMPA, FLORIDA</p>	LINE IS 2 INCHES AT FULL SIZE (IF NOT 2" - SCALE ACCORDINGLY)	EXTERNAL REFERENCE FILES 144490-TBK-0001-01.dwg	REVISIONS <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th style="width: 10%;">ZONE</th> <th style="width: 10%;">REV.</th> <th style="width: 40%;">DESCRIPTION</th> <th style="width: 10%;">BY</th> <th style="width: 10%;">DATE</th> <th style="width: 10%;">APP.</th> </tr> </thead> <tbody> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table>	ZONE	REV.	DESCRIPTION	BY	DATE	APP.																															<p>CITY OF St. PETERSBURG 3800 54th AVE. S ST. PETERSBURG, FL. 33711</p>	GENERAL ABBREVIATIONS	FILENAME 144490-G-00-04.dwg BC PROJECT NUMBER 144490 CLIENT PROJECT NUMBER 13057-111 SHEET NUMBER G-00-04 CITY DRAWING NUMBER 10938-4
	ZONE	REV.	DESCRIPTION	BY	DATE	APP.																																				
SUBMITTED: _____ PROJECT MANAGER DATE APPROVED: _____ PROJECT MANAGER DATE	DESIGNED: B ELEAZER DRAWN: T DIMICELI CHECKED: B ELEAZER CHECKED: G ANIPSITAKIS APPROVED: B ELEAZER		BIOSOLIDS IMPROVEMENTS GUARANTEED MAXIMUM PRICE																																							



GENERAL NOTES:

1. ONLY MAJOR OPERATING FORWARD FLOW AND MAJOR BYPASSES ARE SHOWN. DETAILED PROCESS SCHEMATICS ARE PROVIDED IN THE I-DRAWINGS.
2. DRAWING G-00-31 FOR HEAT RESERVOIR SYSTEM AND SEE DRAWING G-00-32 FOR A SCHEMATIC OF THE DIGESTER GAS TREATMENT SYSTEM.

KEY NOTES:

- 1 TO FOUL AIR COLLECTION SYSTEM.
- 2 FUTURE POLYMER FEED SYSTEM FOR PRIMARY AND SECONDARY CLARIFIERS.
- 3 NOT USED.
- 4 RELOCATED LS-2. WORK DETAILED IN VOLUMES 4 AND 5 OF THIS CONTRACT.
- 5 PART OF GENERATOR ELECTRICAL IMPROVEMENTS PROJECT.
- 6 WORK DETAILED IN VOLUMES 5 AND 6 OF THIS CONTRACT.
- 7 WORK DETAILED IN VOLUME 4 OF THIS CONTRACT.

Sep 18, 2015 - 3:06pm
 P:\St. Petersburg\144490-St. Pete Solids-Generator Design\CAD\2-Sheets\G-General\144490-G-00-21.dwg

Brown and Caldwell
 TAMPA, FLORIDA

DESIGNED: B ELEAZER
 DRAWN: T DIMICELI
 CHECKED: B ELEAZER
 CHECKED: G ANIPSITAKIS
 APPROVED: B ELEAZER

LINE IS 2 INCHES
 AT FULL SIZE
 (IF NOT 2" - SCALE ACCORDINGLY)

DESIGNED: B ELEAZER
 DRAWN: T DIMICELI
 CHECKED: B ELEAZER
 CHECKED: G ANIPSITAKIS
 APPROVED: B ELEAZER

EXTERNAL REFERENCE FILES
 144490-TBK-0000-01.dwg

REVISIONS					
ZONE	REV.	DESCRIPTION	BY	DATE	APP.

CITY OF St. PETERSBURG
 3800 54th AVE. S
 St. PETERSBURG, FL. 33711

BIOSOLIDS IMPROVEMENTS
GUARANTEED MAXIMUM PRICE

GENERAL

NEW PROCESS FLOW DIAGRAM 1

G-00-21

FILENAME
 144490-G-00-21.dwg
 BC PROJECT NUMBER
 144490
 CLIENT PROJECT NUMBER
 13057-111
 SHEET NUMBER
G-00-21
 CITY DRAWING NUMBER
 10938-10

