

## Storage Tank Financial Responsibility (FR) Requirements

FR is required until tanks are properly closed (not just taken out of service).

Type of Tank	Definition	Regulated Product	Exemptions	Financial Responsibility [Per Occurrence]	Financial Responsibility [Annual Aggregate]	Applicable State Rules and Federal Code
<p><b>Aboveground Storage Tanks (AST)</b></p> <p>Greater than 550 gallons</p>	<p>An aboveground stationary device designed to hold regulated substances and the volume of which (include integral piping) is less than 10% beneath the surface of the ground.</p> <p>Details: <a href="#">Chapter 62-762.201, FAC</a></p>	<ul style="list-style-type: none"> <li>- Motor Fuels</li> <li>- Lubricating Oils</li> <li>- Naphtha</li> <li>- Distillates</li> <li>- Residual Oils</li> <li>- Waste Oil</li> <li>- Blends or Mixtures or Byproducts of oil or gas</li> <li>- Petroleum Solvents</li> </ul> <p>Details: <a href="#">40 CFR 280.12</a></p>	<p>• <b>EXCLUDES:</b></p> <ul style="list-style-type: none"> <li>- Tanks with 550-gallon capacity or less</li> <li>- Tanks less than 30,000 gallons storing heating oil for on-site consumption</li> <li>- LP Gas Tanks</li> <li>- Hazardous Waste Tanks</li> </ul> <p>Details: <a href="#">Chapter 62-762.301, FAC</a></p>	<p><b>Facility's cumulative tank system capacity:</b></p> <ul style="list-style-type: none"> <li>≤ 10,000 gallons [\$500,000]</li> <li>&gt; 10,000 &amp; ≤ 30,000 gallons [\$1,000,000]</li> <li>&gt; 30,000 &amp; ≤ 250,000 gallons [\$1,000,000]</li> <li>&gt; 250,000 gallons [\$3,000,000]</li> </ul> <p>Ref.: <a href="#">Chapter 62-762.421(3), FAC</a></p>	<p><b>Facility's cumulative tank system capacity:</b></p> <ul style="list-style-type: none"> <li>≤ 10,000 gallons [\$1,000,000]</li> <li>&gt; 10,000 &amp; ≤ 30,000 gallons [\$1,000,000]</li> <li>&gt; 30,000 &amp; ≤ 250,000 gallons [\$2,000,000]</li> <li>&gt; 250,000 gallons [\$6,000,000]</li> </ul> <p>Ref.: <a href="#">Chapter 62-762.421(3), FAC</a></p>	<p><a href="#">Chapter 62-762.421, FAC</a> - (AST FR rule) adopts most of <a href="#">40 CFR Part 280 Subpart H</a> (UST requirements) for AST FR</p> <p>(Note: DEP forms must be used)</p> <p>Relevant Florida Statutes are identified on Rule pages</p>
<p><b>Underground Storage Tanks (UST)</b></p> <p>Greater than 110 gallons</p>	<p>An underground stationary device designed to hold regulated substances and the volume of which (including integral piping) is more than 10% beneath the surface of the ground.</p> <p>Details: <a href="#">40 CFR 280.12</a></p>	<ul style="list-style-type: none"> <li>- Motor Fuels</li> <li>- Lubricating Oils</li> <li>- Naphtha</li> <li>- Distillates</li> <li>- Residual Oils</li> <li>- Waste Oil</li> <li>- Blends or Mixtures or Byproducts of oil or gas</li> <li>- Lubricants</li> <li>- Petroleum Solvents</li> </ul> <p>Details: <a href="#">40 CFR 280.12</a></p>	<p>• <b>EXCLUDES:</b></p> <ul style="list-style-type: none"> <li>- Tanks with 110-gallon capacity or less</li> <li>- LP Gas Tanks</li> <li>- Agricultural tanks: 550 gallons or less</li> <li>- Tanks less than 30,000 gallons storing heating oil for on-site consumption</li> <li>- Hazardous Waste Tanks</li> <li>- Residential Tanks less than 1,100 gal.</li> </ul> <p>Details: <a href="#">Chapter 62-761.300, FAC</a></p>	<p><b>Petroleum Marketing Facilities:</b></p> <p>[\$1,000,000]</p> <p><b>All Other Facilities:</b></p> <p>throughput ≤ 10,000 gallons/month (annual average) [\$500,000]</p> <p>throughput &gt; 10,000 gallons/month (annual average) [\$1,000,000]</p> <p>Ref: <a href="#">40 CFR 280.93(a)</a></p>	<p><b>All Facilities:</b></p> <ul style="list-style-type: none"> <li>≤ 100 tanks [\$1,000,000]</li> <li>&gt; 100 tanks [\$2,000,000]</li> </ul> <p>Ref: <a href="#">40 CFR 280.93(b)</a></p>	<p><a href="#">Chapter 62-761.420, FAC</a> - (UST FR rule) adopts <a href="#">40 CFR Part 280 Subpart H</a> for UST FR</p> <p>(Note: DEP forms must be used)</p> <p>Relevant Florida Statutes are identified on Rule pages</p>

Especially when an account owner has both UST and AST in multiple locations, see [Quick Guide of Financial Responsibility Amounts Required for UST and AST](#) on the [General Guidance for Tanks Financial Responsibility](#) webpage.