



USE OF INGROUND NITROGEN - REDUCING BIOFILTERS TO REDUCE NITROGEN LOADS FROM SEPTIC SYSTEMS

Xueqing Gao, Ph.D. and Tanya Welborn

Division of Water Resource Management / Onsite Sewage Program


Florida Department of Environmental Protection

Florida Onsite Wastewater Association 2022 Convention & Trade Show

Aug. 5, 2022



FLORIDA SPRINGS NITROGEN IMPAIRMENT





STATUTE REQUIREMENTS

SECTION 373.811, F.S.

“The following activities are prohibited within a priority focus area in effect for an Outstanding Florida Spring:

...(2) New onsite sewage treatment and disposal systems on lots of less than 1 acre, if the addition of the specific systems conflicts with an onsite treatment and disposal system remediation plan incorporated into a basin management action plan in accordance with s. 373.807(3).”



BASIN MANAGEMENT ACTION PLAN (BMAP)

Upon Basin Management Action Plan (BMAP) adoption, the onsite sewage treatment and disposal system (OSTDS) remediation plan prohibits new systems on lots of less than one acre within a Priority Focus Area (PFA) of an impaired Outstanding Florida Spring (OFS) **unless one of the two scenarios is applicable.**

- The system includes enhanced treatment of nitrogen (a nitrogen-reducing OSTDS).
- OSTDS permit applicant demonstrates that sewer connection will be available within five years.



NITROGEN-REDUCING OSTDS


- Aerobic treatment units (ATU) certified as meeting the NSF-245 standard.
- Nitrogen-reducing performance-based treatment systems (PBTS).
- [Inground nitrogen-reducing biofilter \(INRB\).](#)



REMOVING NITROGEN FROM DOMESTIC WASTEWATER


Nitrogen exists in various forms and must be dealt with progressively in each form to ensure removal.

CONCEPTUALLY





INGROUND NITROGEN – REDUCING BIOFILTER





LEON COUNTY PROJECT

UPGRADE EXISTING SEPTIC SYSTEMS

- DEP funded Leon County \$1.5 million to upgrade existing septic systems in Wakulla PFA to passive nitrogen-reducing systems (2016).
- Leon County selected two subdivisions as the pilot project area.
- The project recruited volunteer system owners to participate in the upgrade.
- Leon County and DEP cooperate in monitoring and sampling several upgraded systems.



INRB MONITORING PROJECT

- Experimental INRB systems installed previously showed about 65% of nitrogen-removal.
- More systems are needed to provide more robust evaluation of the performance of the technology in Florida.
- DEP's Onsite Sewage Program is monitoring two INRB systems and is looking for more volunteer INRB owners to participate in the monitoring.
- This monitoring project is funded by the U.S. Environmental Protection Agency.




GOALS OF THE MONITORING PROJECT

- Determine the nitrogen-reducing efficiency of INRB systems.
- Evaluate the capability of INRBs of removing total phosphorus, fecal coliform and organic carbon.
- Evaluate media decay through monitoring the change of elevations of the media layers.
- Compare monitoring results from different monitoring equipment (i.e., pan lysimeter and suction lysimeter).



PROJECT LOCATION



Subdivisions in the Wakulla Spring PFA, Leon County.
Both monitored systems were installed in June 2021.

BMAP Area



PFA





INRB SYSTEM MONITORING

- Inspect the systems to ensure proper function.
- Conduct elevation survey to evaluate change of depth of media layers.
- Collect samples.
 - Total Kjeldahl nitrogen (TKN).
 - Ammonium nitrogen (NH₄-N).
 - Nitrate/nitrite nitrogen (NO_x-N).
 - Total phosphorus (TP).
 - Total organic carbon (TOC).
 - Fecal coliform.
 - Alkalinity.
 - Chloride.



INRB SYSTEM MONITORING (2)

- Collect field measurements.
 - Water temperature.
 - Dissolved oxygen.
 - Specific conductivity.
 - pH.
 - Oxidation reduction potential.
 - Flowmeter reading.



MONITORING EQUIPMENT




Pan Lysimeter (PL)



Suction Lysimeter (SL)



MONITORING EQUIPMENT ARRANGEMENT




○ DNL-SL ● SFL-SL ● DNL-PL ● SFL-PL ● SFL-OP ● DNL-OP

SL: Suction Lysimeter. **PL:** Pan Lysimeter. **OP:** Observation Port.



MONITORING EQUIPMENT ARRANGEMENT (2)





MONITORING EQUIPMENT INSTALLATION



Bottom of INRB

Denitrification media




PL at the bottom of INRB



MONITORING EQUIPMENT INSTALLATION (2)

PL at bottom of SFL

SL at bottom of DNL



Top of DNL

Sand fill media



MONITORING EQUIPMENT INSTALLATION (3)




Top of sand fill media layer



SYSTEM 3 (S3)

INSTALLED IN JUNE 2021




| DNL | SFL |
|-----|-----|
| SL | SL |
| ● | ● |
| PL | PL |
| ● | ● |
| OP | OP |
| ● | ● |

No irrigation.



SYSTEM 4 (S4)

INSTALLED IN JUNE 2021



| DNL | SFL |
|-----|-----|
| SL | SL |
| ● | ● |
| PL | PL |
| ● | ● |
| OP | OP |
| ● | ● |

No irrigation.



PROPERTY CHARACTERISTICS

| System | # of Bedrooms | Drainfield Size (SQFT) | Soil Type | # of Occupants |
|--------|---------------|------------------------|-----------|----------------|
| S3 | 3 | 360 | Fine Sand | 1 |
| S4 | 3 | 375 | Fine Sand | 5 |



WATER USE SYSTEM 3

| Date & Time - Water Meter Reading | Cumulative Flow Meter Reading (gallons) | Time Lapse (days) | Daily Water Use (gallons/day) |
|-----------------------------------|---|-------------------|-------------------------------|
| 12/6/2021 13:57 | 1462 | - | - |
| 12/8/2021 11:32 | 1495 | 1.90 | 17.4 |
| 12/9/2021 12:02 | 1507 | 1.02 | 11.8 |
| 2/28/2022 11:46 | 3158.6 | 80.99 | 20.4 |
| 3/2/2022 8:42 | 3210.4 | 1.87 | 27.7 |
| 3/3/2022 12:57 | 3234.5 | 1.18 | 20.5 |
| 5/23/2022 9:09 | 4760.2 | 80.84 | 18.9 |
| 5/25/2022 8:44 | 4780.9 | 1.98 | 10.4 |
| 5/26/2022 10:58 | 4800.9 | 1.09 | 18.3 |
| Long-term average daily water use | - | - | 20.0 |




WATER USE SYSTEM 4

| Date & Time - Water Meter Reading | Cumulative Flow Meter Reading (gallons) | Time Lapse (days) | Daily Water Use (gallons/day) |
|--|---|-------------------|-------------------------------|
| 12/13/2021 15:10 | 24350.6 | - | - |
| 12/15/2021 8:16 | 25980.3 | 1.71 | 951.6 |
| 12/15/2021 15:13 | 26059.7 | 0.29 | 274.2 |
| 3/21/2022 11:35 | 63455.5 | 95.85 | 390.2 |
| 3/23/2022 8:18 | 63656 | 1.86 | 107.6 |
| 3/23/2022 13:33 | 63880.4 | 0.22 | 1025.8 |
| 5/31/2022 10:19 | 107110.1 | 68.87 | 627.7 |
| 5/31/2022 13:24 | 107530.3 | 0.13 | 3270.7 |
| 6/2/2022 14:20 | 111490.5 | 2.04 | 1942.3 |
| Long-term average daily water use | - | - | 570.0 |



ARRANGEMENT OF MONITORING EQUIPMENT





WATER DEPTHS IN OP (INCHES)

SYSTEM 3

| Sampling Event | Location in Drainfield | Bottom of Drainfield | Bottom of Sand Fill Layer |
|------------------------------|------------------------|----------------------|---------------------------|
| 1st sampling event (12/2021) | Beginning | 0.00 | 0.00 |
| 1st sampling event (12/2021) | Middle | 0.00 | 0.00 |
| 1st sampling event (12/2021) | End | 0.00 | 0.00 |
| 2nd sampling event (3/2022) | Beginning | 0.00 | 0.00 |
| 2nd sampling event (3/2022) | Middle | 0.00 | 0.00 |
| 2nd sampling event (3/2022) | End | 0.00 | 0.00 |
| 3rd sampling event (5/2022) | Beginning | 0.00 | 0.00 |
| 3rd sampling event (5/2022) | Middle | 0.00 | 0.00 |
| 3rd sampling event (5/2022) | End | 0.00 | 0.00 |



WATER DEPTHS IN OP (INCHES)

SYSTEM 4

| Sampling Event | Location in Drainfield | Bottom of Drainfield | Bottom of Sand Fill Layer |
|------------------------------|------------------------|----------------------|---------------------------|
| 1st sampling event (12/2021) | Beginning | 0.00 | 3.50 |
| 1st sampling event (12/2021) | Middle | 0.00 | 4.50 |
| 1st sampling event (12/2021) | End | 0.00 | 10.25 |
| 2nd sampling event (3/2022) | Beginning | 0.00 | 0.00 |
| 2nd sampling event (3/2022) | Middle | 0.00 | 5.75 |
| 2nd sampling event (3/2022) | End | 0.00 | 4.50 |
| 3rd sampling event (5/2022) | Beginning | 0.00 | 3.50 |
| 3rd sampling event (5/2022) | Middle | 0.00 | 13.0 |
| 3rd sampling event (5/2022) | End | 0.00 | 11.0 |



VOLUME OF SAMPLES GENERATED (ML)

SYSTEM 3

| Sampling Event | Location in Drainfield | Left SFL | Left DNL | Center SFL | Center DNL | Right SFL | Right DNL |
|----------------|------------------------|----------|----------|------------|------------|-----------|-----------|
| 1st sampling | Beginning | 600 | 200/80 | 0 | 0 | 800 | 1050 |
| 1st sampling | Middle | 0 | 0 | 850 | 150/50 | 800 | 160/100 |
| 1st sampling | End | 800 | 130/70 | 800 | 220/100 | 0 | 0 |
| 2nd sampling | Beginning | 800 | 150/160 | 0 | 0 | 822 | 1200 |
| 2nd sampling | Middle | 0 | 0 | 900 | 100/0 | 800 | 200/100 |
| 2nd sampling | End | 900 | 200/75 | 800 | 600 | 0 | 0 |
| 3rd sampling | Beginning | 850 | 0/40 | 0 | 0 | 950 | 1250 |
| 3rd sampling | Middle | 0 | 0 | 850 | 100/50 | 950 | 180/80 |
| 3rd sampling | End | 1000 | 180/80 | 675 | 220/100 | 0 | 0 |

Brown font: Pan lysimeter sample volume. **Blue** and **black** fonts: Suction lysimeter volume.



VOLUME OF SAMPLES GENERATED (ML)

SYSTEM 4

| Sampling | Location in | Left | Left | Center | Center | Right | Right |
|--------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|
| Event | Drainfield | SFL | DNL | SFL | DNL | SFL | DNL |
| 1st sampling | Beginning | 400 | 1000 | 1050 | 1250 | 825 | 850 |
| 1st sampling | Middle | 2800 | 2000 | 900 | 1200 | 900 | 1100 |
| 1st sampling | End | 1200 | 0 | 750 | 750 | 1900 | 2300 |
| 2nd sampling | Beginning | 900 | 600 | 1400 | 900 | 900 | N/A |
| 2nd sampling | Middle | 0 | 800 | 900 | 900 | 900 | N/A |
| 2nd sampling | End | 900 | 0 | 950 | 800 | 0 | 0 |
| 3rd sampling | Beginning | 850 | 1200 | 1000 | 1000 | 1200 | 1000 |
| 3rd sampling | Middle | 1000 | 2000 | 950 | 1000 | 950 | 180/80 |
| 3rd sampling | End | 950 | 0 | 950 | 1100 | 1000 | 2000 |

Brown font: Pan lysimeter sample volume. **Blue** and **black** fonts: Suction lysimeter volume.



NITROGEN REDUCTION IN SYSTEM 3


Lysimeter Results



CHLORIDE CONCENTRATION (MG/L)

SYSTEM 3

December 2021 Sampling Event






CHLORIDE CONCENTRATION (MG/L)

SYSTEM 3 (2)

March 2022 Sampling Event






TN CONCENTRATION (MG/L)

SYSTEM 3

December 2021 Sampling Event






TN CONCENTRATION (MG/L)

SYSTEM 3 (2)

March 2022 Sampling Event






TKN CONCENTRATION (MG/L)

SYSTEM 3

December 2021 Sampling Event






TKN CONCENTRATION (MG/L)

SYSTEM 3 (2)


March 2022 Sampling Event





NO_x CONCENTRATION (MG/L) SYSTEM 3


December 2021 Sampling Event





NO_x CONCENTRATION (MG/L) SYSTEM 3 (2)

March 2022 Sampling Event






ALKALINITY CONCENTRATION (MG/L)

SYSTEM 3

December 2021 Sampling Event






ALKALINITY CONCENTRATION (MG/L)

SYSTEM 3 (2)


March 2022 Sampling Event





PH SYSTEM 3


December 2021 Sampling Event





PH SYSTEM 3 (2)

March 2022 Sampling Event





NITROGEN REDUCING EFFICIENCY

SYSTEM 3

| Sampling Event | STE (mg/L) | Left Side (mg/L) | Right Side (mg/L) | Mean Effluent Concentration (mg/L) | Treatment Efficiency |
|----------------|---------------|------------------|-------------------|------------------------------------|----------------------|
| December 2021 | 230.00 | 1.00 | 156.70 | 78.85 | 65.7% |
| March 2022 | 205.01 | 6.31 | 130.02 | 68.17 | 66.7% |



NITROGEN REDUCTION IN SYSTEM 4


Lysimeter Results



CHLORIDE CONCENTRATION (MG/L)

SYSTEM 4

December 2021 Sampling Event






CHLORIDE CONCENTRATION (MG/L)

SYSTEM 4 (2)

March 2022 Sampling Event






TN CONCENTRATION (MG/L)

SYSTEM 4

December 2021 Sampling Event






TN CONCENTRATION (MG/L)

SYSTEM 4 (2)

March 2022 Sampling Event






TKN CONCENTRATION (MG/L)

SYSTEM 4

December 2021 Sampling Event






TKN CONCENTRATION (MG/L)

SYSTEM 4 (2)

March 2022 Sampling Event






NO_x CONCENTRATION (MG/L)

SYSTEM 4

December 2021 Sampling Event






NO_x CONCENTRATION (MG/L)

SYSTEM 4 (2)

March 2022 Sampling Event






NITROGEN REDUCING EFFICIENCY

SYSTEM 4

| Sampling Event | Location in Drainfield | Left Side (mg/L) | Center (mg/L) | Right Side (mg/L) | Mean Effluent Concentration (mg/L) | Treatment Efficiency |
|----------------|------------------------|------------------|---------------|-------------------|------------------------------------|----------------------|
| 12/2021 | Begin | 0.68 | 11.00 | 2.00 | | |
| 12/2021 | Middle | 3.04 | 5.60 | 21.60 | | |
| 12/2021 | End | | 4.11 | 4.54 | | |
| 12/2021 | Drainfield Mean | | | | 6.57 | |
| 12/2021 | STE | | | | 18.01 | 62.7% |
| 3/2022 | Begin | 5.4 | 14.0 | 9.3 | | |
| 3/2022 | Middle | 5.9 | 16.0 | 5.1 | | |
| 3/2022 | End | | 8.7 | | | |
| 3/2022 | Drainfield Mean | | | | 9.20 | |
| 3/2022 | STE | | | | 33.0 | 72.1% |




COMPARE MEAN TN FROM SL AND PL AT SYSTEM 4






ELEVATION CHANGE OF SYSTEM LAYERS





ELEVATION CHANGE OF SYSTEM LAYERS


SYSTEM 3





ELEVATION CHANGE OF SYSTEM LAYERS

SYSTEM 4





SUMMARY

- The sampled INRB systems reduced nitrogen from the septic tank effluent by about 63% to 72%.
- TN concentrations measured from the PL and SL at System 4 did not show a significant difference, suggesting that SL and PL can produce comparable results.
- Results from three monitoring events of elevations at finished grade, bottom of drainfield, and bottom of sand fill layer did show most changes at bottom of drainfield in System 4, and little change elsewhere during the first year of operation.



SUMMARY (2)

- The results from System 3 show uneven distribution of wastewater across the drainfield.
- Uneven distribution of wastewater across the drainfield may negatively impact the nitrogen-reducing efficiency.
- The results from System 4 showed accumulation of water in the sand fill layer and nitrification was incomplete. Still, between 63% and 72% of the nitrogen was removed.
- Longer sampling and sampling of more systems are needed to evaluate more thoroughly the performance of the INRBs.



THANK YOU

Xueqing Gao, Ph.D.

Division of Water Resource Management

Onsite Sewage Program

Florida Department of Environmental Protection

Contact Information:

850-245-8391

Xueqing.Gao@FloridaDEP.gov